

METROPOLITAN EDISON COMPANY SUBSIDIARY OF GENERAL PUBLIC UTILITIES CORPORATION

POST OFFICE BOX 542 READING, PENNSYLVANIA 19603

TELEPHONE 215 - 929-3601

August 27, 1975  
GQL 1434


Mr. J. P. O'Reilly, Director  
Office of Inspection and Enforcement, Region 1  
U. S. Nuclear Regulatory Commission  
631 Park Avenue  
King of Prussia, Pennsylvania 19406

Dear Mr. O'Reilly:

License No. CPPR-66  
Inspection No. 75-08  
Docket No. 50-320

In our letter of August 20, 1975 (GQL 1407), the referenced attachment was inadvertently omitted and we have included the attachment herein.

Sincerely,

  
R. C. Arnold  
Vice President

RCA:RSB:tas

File: 20.1.1  
7.7.3.2.2

63-252

7904210658

ALL RIGHTS RESERVED. THIS REPORT IS THE PROPERTY OF THE TESTING LABORATORY AND IS NOT TO BE REPRODUCED OR TRANSMITTED IN ANY FORM OR BY ANY MEANS, ELECTRONIC OR MECHANICAL, INCLUDING PHOTOCOPYING, RECORDING, OR BY ANY INFORMATION STORAGE AND RETRIEVAL SYSTEM. PERMISSION IS GRANTED TO MAKE A LIMITED COPY OF THIS REPORT FOR PERSONAL USE ONLY. PERMISSION IS RESERVED PENDING OUR WRITTEN APPROVAL.

Report No. EG-734  
Date Special Test

# REPORT

## REPORT OF TEST ON CONCRETE CYLINDERS 6" DIAMETER BY 12" LENGTH

Client: United Engineers & Constructors, Incorporated  
 Identification: Metropolitan Edison Nuclear Plant  
Three Mile Island Unit 2  
 Location: United Engineers & Constructors, Incorporated  
 Project: STRESS STEEL PUMP MIXED  
 Type of Concrete Placement: REACTOR Bldg 170' High VERTICAL Poured - 42 30"

Concrete Class 3000 P.S.I.  
6KMT

Spec. No.	Slump Inches	Air %	Concrete Temp. °F.	Area Sq. In.	Date Tested	Age Days	Total Load lbs.	Comp. St. P.S.I.
1577	Flowable			4.0	11-20	28	14,400	3600
76							15,000	3750
79						129	15,400	3850
								3570
1582	Flowable			4.0	11-20	28	14,800	3700
							14,800	3700
						129	14,000	3500
								3630

REMARKS: \* B = SAMPLE TAKEN FROM BOTTOM OF PUMP - INPUT  
 \* T = SAMPLE TAKEN FROM TOP OF PUMP - DISCHARGE

Tested by - KERR  
 Made by - Chickster

PITTSBURGH TESTING LABORATORY  
[Signature]