LICENSEE EVENT REPORT

CONTROL BLOCK: [ ] (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 | M A P P S 1 (2) | 0 0 0 0 0 0 0 0 0 0 0 (3) | 4 1 1 1 1 (4) | (5)
LICENSEE CODE — LICENSE NUMBER — LICENSE TYPE — CAT

CON'T

0 1 | REPORT SOURCE L (6) | 0 5 0 - 0 2 9 3 (7) | 0 7 2 7 7 9 (8) | 0 8 1 0 7 9 (9)
DOCKET NUMBER — EVENT DATE — REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 | On July 27, 1979 at 0101 hours, a reactor scram occurred as a result of a loss of all off-
0 3 | site power. The Diesel Generators func oned as required and assummed emergency loads.
0 4 | Relief/Safety valve 203-3D was manually actuated to control pressure and maneuver
0 5 | the reactor to a shutdown condition.
0 6 |
0 7 |
0 8 |

0 9 | SYSTEM CODE E A (11) | CAUSE CODE C (12) | CAUSE SUBCODE Z (13) | COMPONENT CODE Z Z Z Z Z Z (14) | COMP. SUBCODE Z (15) | VALVE SUBCODE Z (16)

(17) LER/RO REPORT NUMBER: EVENT YEAR 7 9 | — | SEQUENTIAL REPORT NO. 0 2 7 | / | OCCURRENCE CODE 0 1 | REPORT TYPE T | — | REVISION NO. 0

ACTION TAKEN X (18) | FUTURE ACTION X (19) | EFFECT ON PLANT A (20) | SHUTDOWN METHOD C (21) | HOURS (22) 0 0 8 5 | ATTACHMENT SUBMITTED N (23) | NPRD-4 FORM SUB. N (24) | PRIME COMP. SUPPLIER Z (25) | COMPONENT MANUFACTURER Z 9 9 9 (26)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 | The cause of this event was lightning striking the off-site distribution lines causing
1 1 | a backflash which resulted in a high speed relay operation for line to ground fault.
1 2 | Power was restored to the startup transformer and station loads returned to normal
1 3 | source after approximately 1½ hours.
1 4 |

5 | FACILITY STATUS E (28) | % POWER 1 0 0 (29) | OTHER STATUS (30) N.A. | METHOD OF DISCOVERY A (31) | DISCOVERY DESCRIPTION (32) Operational Event

6 | ACTIVITY RELEASED Z (33) | CONTENT OF RELEASE Z (34) | AMOUNT OF ACTIVITY (35) N.A. | LOCATION OF RELEASE (36) N.A.

7 | PERSONNEL EXPOSURES NUMBER 0 0 0 (37) | TYPE Z (38) | DESCRIPTION (39) N.A.

8 | PERSONNEL INJURIES NUMBER 0 0 0 (40) | DESCRIPTION (41) N.A.

9 | LOSS OF OR DAMAGE TO FACILITY TYPE Z (42) | DESCRIPTION (43) N.A.

7908170423

0 | PUBLICITY ISSUED N (44) | DESCRIPTION (45) N.A.

705 354

NRC USE ONLY

NAME OF PREPARER John M. Fulton PHONE: 617-746-7900