

TH

Thomas J. Martin
Vice President
Engineering and Construction

Public Service Electric and Gas Company 80 Park Place Newark, N.J. 07101 201/430-8316

July 25, 1979

Mr. Bryce H. Grier, Director
Office of Inspection and Enforcement
U.S. Nuclear Regulatory Commission
Region 1
631 Park Avenue
King of Prussia, Pennsylvania 19406

Dear Mr. Grier:

NRC IE BULLETIN NO. 79-11
FAULTY OVERCURRENT TRIP DEVICE IN CIRCUIT
BREAKERS FOR ENGINEERED SAFETY SYSTEMS
NO. 1 AND 2 UNITS
HOPE CREEK GENERATING STATION

In reply to IE Bulletin No. 79-11 dated May 22, 1979, we offer
the following response:

Investigation into the subject bulletin affirms that no Westinghouse
Type DB-50 or DP-75 circuit breakers are planned for use in safety
related systems at Hope Creek Generating Station.

Should additional information be desired, we will be pleased to
further discuss it with you.

Very truly yours,



CC: Office of Inspection and Enforcement
Division of Reactor Construction Inspection
Washington, D.C.

787015

7908230112