NRC FORM 366 (7-77)

U.S. NUCLEAR REGULATORY COMMISSION

LICENSEE EVENT REPORT

CONTROL BLOCK: (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 NCBEP2 (2) 00-00000-00 (3) 4 1 1 1 1 (4) (5)
LICENSEE CODE — LICENSE NUMBER — LICENSE TYPE — CAT

CON'T
01 REPORT SOURCE L (6) 0 5 0 - 0 3 2 4 (7) 0 7 1 9 7 9 (8) 0 8 1 5 7 9 (9)
DOCKET NUMBER — EVENT DATE — REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 While performing PT 1.1.1 PC, Reactor High Pressure Trip Calibration and functional
03 test, switch #1 of instrument 2B21-PS-N023C did not actuate until 1062 psig increasing.
04 The Technical Specification reportable limit is > 1058 psig which includes a 13 psig
05 head correction.
06 Technical Specification 2.2.1, 6.9.1.9a
07
08

09 SYSTEM CODE IA (11) CAUSE CODE X (12) CAUSE SUBCODE Z (13) COMPONENT CODE INSTRU (14) COMP. SUBCODE Y (15) VALVE SUBCODE Z (16)

(17) LER/RO REPORT NUMBER: EVENT YEAR 79 — SEQUENTIAL REPORT NO. 058 / OCCURRENCE CODE 03 — REPORT TYPE L — REVISION NO. 0

ACTION TAKEN E (18) FUTURE ACTION Z (19) EFFECT ON PLANT Z (20) SHUTDOWN METHOD Z (21) HOURS (22) 0000 ATTACHMENT SUBMITTED N (23) NPRD-4 FORM SUB. Y (24) PRIME COMP. SUPPLIER N (25) COMPONENT MANUFACTURER B069 (26)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 The out-of-tolerance reading was due to instrument drift. The instrument was recali-
11 brated per PT 1.1.1 PC. The calibration program requires that this instrument be cal-
12 ibrated when its "as-found" reading is > 1050 psig. This is considered an isolated
13 event and no further action is required based on a review of the past two years.
14

15 FACILITY STATUS G (28) % POWER 000 (29) OTHER STATUS (30) NA — METHOD OF DISCOVERY B (31) DISCOVERY DESCRIPTION (32) Periodic Test

16 ACTIVITY RELEASED Z (33) CONTENT OF RELEASE Z (34) AMOUNT OF ACTIVITY (35) NA — LOCATION OF RELEASE (36) NA

PERSONNEL EXPOSURES
17 NUMBER 000 (37) TYPE Z (38) DESCRIPTION (39) NA

PERSONNEL INJURIES
18 NUMBER 000 (40) DESCRIPTION (41) NA

LOSS OF OR DAMAGE TO FACILITY (43)
19 TYPE Z (42) DESCRIPTION NA

PUBLICITY
20 ISSUED N (44) DESCRIPTION (45) NA

7908230382

783 358

NRC USE ONLY

NAME OF PREPARER A. C. Tollison, Jr. PHONE 919-457-9521

GPO 917-926