

APPENDIX A

NOTICE OF VIOLATION

Based on the results of the NRC inspection conducted on May 10-13, 1976, it appears that one of your activities was not conducted in full compliance with conditions of your NRC Facility License No. CPFR-66 as indicated below:

10 CFR 50, Appendix B, Criterion XII which states: "Measures shall be established to assure that tools, gages, instruments, and other measuring and testing devices used in activities affecting quality are properly controlled, calibrated and adjusted at specified periods to maintain accuracy within necessary limits."

Contrary to the above, crimping of safety related cable and wire in circuits to motors and control cabinets for the Nuclear Services River Water System had been performed with crimping tools which were not controlled and calibrated.

This item is an infraction.

7908

POOR ORIGINAL

OFFICE▶									
SURNAME▶									7908230489
DATE▶									