



# Omaha Public Power District

1623 HARNEY • OMAHA, NEBRASKA 68102 • TELEPHONE 536-4000 AREA CODE 402

August 31, 1979


Mr. William Gammill  
Acting Assistant Director  
for Operating Reactors Projects  
Division of Operating Reactors  
U. S. Nuclear Regulatory Commission  
Washington D. C. 20555

Re: Docket 50-285

Gentlemen:

The Omaha Public Power District received the Commission's letter of August 8, 1979 requesting information in regard to the adequacy of station electrical distribution systems voltages. The reviews required by the letter were completed for the Fort Calhoun Station, as part of the District's response to the Commission's June 2, 1977, letter and, therefore, no further action is required. Electrical systems associated with the Fort Calhoun Station adhere to General Design Criteria 17(GDC-17).

Sincerely,

  
W. C. Jones  
Section Manager, Operations

WCJ/BJH/rh

xc: LeBoeuf, Lamb, Leiby & MacRae  
1333 New Hampshire Avenue, N.W.  
Washington, D. C. 20036

*A001  
S  
1/0*

315261

7909060 285 P