

TIC



UNITED STATES
NUCLEAR REGULATORY COMMISSION
REGION II
101 MARIETTA ST., N.W., SUITE 3100
ATLANTA, GEORGIA 30303

AUG 10 1979

In Reply Refer To:

RII:JPO

50-339

50-404

50-405

Virginia Electric and Power Company
ATTN: W. L. Proffitt
Senior Vice President, Power
P. O. Box 26666
Richmond, VA 23261

Gentlemen:

Enclosed is IE Bulletin No. 79-02, Revision 1, Supplement No. 1, which is forwarded to you for information. No written response is required. If you desire additional information regarding this matter, please contact this office.

Sincerely,

James P. O'Reilly
Director

Enclosures:

1. IE Bulletin No. 79-02,
Revision No. 1
(Supplement No. 1)
2. Listing of IE Bulletins
Issued in Last Six Months

POOR ORIGINAL

7909070295

919291

AUG 20 1979

Virginia Electric and
Power Company

-1-

SI NO: 587
Accession #
89089024

cc w/encl:
W. R. Cartwright, Station Manager
Post Office Box 402
Mineral, Virginia 23117

Arch copy
shall
maintain

P. G. Perry
Senior Resident Engineer
Post Office Box 38
Mineral, Virginia 23117

W. L. Stewart, Manager
Post Office Box 315
Surry, Virginia 23883

POOR
ORIGINAL

915292

SSINS: 6820
Accession No:
7908150164

UNITED STATES
NUCLEAR REGULATORY COMMISSION
OFFICE OF INSPECTION AND ENFORCEMENT
WASHINGTON, D.C. 20555

August 20, 1979

IE Bulletin No. 79-02
Revision No. 1
(Supplement No. 1)

PIPE SUPPORT BASE PLATE DESIGNS USING CONCRETE EXPANSION ANCHOR BOLTS

Description of Circumstances:

The supplement to IE Bulletin No. 79-02 is intended to establish criteria for the evaluation of interim acceptability of plant operation with less than the design factors of safety for piping supports due to as-built problems, under design, base plate flexibility, or anchor bolt deficiencies.

In the reviews for system operability of the Duane Arnold and Crystal River facilities, criteria have been developed by the NRC staff that defines pipe support operability. The criteria has been applied in lieu of other analysis or evaluation. Specifically, the licensees identified problems with pipe supports in which the original design factors of safety were not met but some lesser margin was available. The design margins of four or five are intended to be final design and installation objectives but systems may be classed as operable on an interim basis with some lesser margin providing a program of restoration to at least the Bulletin factors of safety has been developed. Facilities which fall outside the operability criteria are considered to probably require a Technical Specification exception and will require review on a case by case basis.

Action to be Taken by Licensees:

For the following two cases, plant operation may continue or may begin:

a. For the support as a unit, the factor of safety compared to ultimate strengths is less than the original design but equal to or greater than two.

b. For the anchor bolts the factor of safety is equal to or greater than two and for the support steel the original design factor of safety compared to ultimate strengths is equal to or greater than two.

The above criteria may be applied to design margins of safety and by the next refueling outage defined in Bulletin No. 79-14 of the plant which can be entered

DUPLICATE DOCUMENT

Entire document previously entered into system under:

ANO 7908150164

No. of pages: 6

ports
e-
s