

MONTHLY NARRATIVE REPORT
OF OPERATING
AND MAJOR MAINTENANCE EXPERIENCE

This report describes the operating and major maintenance experience for the month of August, 1979. This report was prepared by the Plant Staff and is submitted in accordance with Section IX:I.l.c. of the Technical Specifications.

During the report period the reactor remained in the cold shutdown mode of operation. There were no significant events associated with the operation of the Unit. There was no significant maintenance completed during the month.

961338

7909180 412

OPERATING DATA REPORT

DOCKET NO. 50-133
 DATE 9-6-79
 COMPLETED BY B. C. Getty
 TELEPHONE (707) 443-2787

OPERATING STATUS

1. Unit Name: H.B.P.P. No 3
2. Reporting Period: August 1, 1979
3. Licensed Thermal Power (MWt): 220
4. Nameplate Rating (Gross MWe): 65
5. Design Electrical Rating (Net MWe): 65
6. Maximum Dependable Capacity (Gross MWe): 65
7. Maximum Dependable Capacity (Net MWe): 63
8. If Changes Occur in Capacity Ratings (Items Number 3 Through 7) Since Last Report, Give Reasons: N/A

Notes

POOR ORIGINAL

9. Power Level To Which Restricted, If Any (Net MWe): N/A
10. Reasons For Restrictions, If Any: N/A

	This Month	Yr.-to-Date	Cumulative
11. Hours In Reporting Period	<u>744</u>	<u>5831</u>	<u>140999</u>
12. Number Of Hours Reactor Was Critical			<u>98171</u>
13. Reactor Reserve Shutdown Hours			<u>0</u>
14. Hours Generator On-Line			<u>97252</u>
15. Unit Reserve Shutdown Hours			<u>0</u>
16. Gross Thermal Energy Generated (MWH)			<u>15618456</u>
17. Gross Electrical Energy Generated (MWH)			<u>4739732</u>
18. Net Electrical Energy Generated (MWH)	<u>-204</u>	<u>-1553</u>	<u>4487214</u>
19. Unit Service Factor			<u>69.0 %</u>
20. Unit Availability Factor			<u>69.0 %</u>
21. Unit Capacity Factor (Using MDC Net)			<u>50.5 %</u>
22. Unit Capacity Factor (Using DER Net)			<u>49.0 %</u>
23. Unit Forced Outage Rate			<u>1.91 %</u>
24. Shutdowns Scheduled Over Next 6 Months (Type, Date, and Duration of Each):			<u>N/A</u>

25. If Shut Down At End Of Report Period, Estimated Date of Startup: Indeterminate

26. Units In Test Status (Prior to Commercial Operation): N/A

Forecast

Achieved

INITIAL CRITICALITY
 INITIAL ELECTRICITY
 COMMERCIAL OPERATION

961339

(P. 1)

UNIT SHUTDOWNS AND POWER REDUCTIONS

REPORT MONTH August, 1979

DOCKET NO. 50-133
 UNIT NAME H.B.P.P. No. 3
 DATE 7-6-79
 COMPLETED BY B.C. GETHY
 TELEPHONE (702) 443-2787

No.	Date	Type ¹	Duration (Hours)	Reason ²	Method of Shutting Down Reactor ³	Licensee Event Report #	System Code ⁴	Component Code ⁵	Cause & Corrective Action to Prevent Recurrence
76-6	760702	S	744	C, H	I	N/A	22	222222	Seismic Modifications

POOR ORIGINAL

1 F. Forced
S. Scheduled

2 Reason:
A. Equipment Failure (Explain)
B. Maintenance or Test
C. Refueling
D. Regulatory Restriction
E. Operator Training & License Examination
F. Administrative
G. Operational Error (Explain)
H. Other (Explain)

3 Method:
1. Manual
2. Manual Scram.
3. Automatic Scram.
4. Other (Explain)

4 Exhibit G - Instructions for Preparation of Data Entry Sheets for Licensee Event Report (LER) File (NUREG-0161)

5 Exhibit I - Same Source

961340

(9/77)

AVERAGE DAILY UNIT POWER LEVEL

POOR ORIGINAL

DOCKET NO. 50-133

UNIT H BPP No. 3

DATE 9-6-79

COMPLETED BY B C Getty

TELEPHONE (707) 443-2787

MONTH August, 1979

DAY AVERAGE DAILY POWER LEVEL
(MWe-Net)

1	0
2	0
3	0
4	0
5	0
6	0
7	0
8	0
9	0
10	0
11	0
12	0
13	0
14	0
15	0
16	0

DAY AVERAGE DAILY POWER LEVEL
(MWe-Net)

17	0
18	0
19	0
20	0
21	0
22	0
23	0
24	0
25	0
26	0
27	0
28	0
29	0
30	0
31	0

INSTRUCTIONS

On this format, list the average daily unit power level in MWe-Net for each day in the reporting month. Compute to the nearest whole megawatt.

(9/77)

961341