



MISSISSIPPI POWER & LIGHT COMPANY

Helping Build Mississippi

P. O. BOX 1640, JACKSON, MISSISSIPPI 39205

3/10/27 AID: 11

PRODUCTION DEPARTMENT

Office of Inspection and Enforcement
U. S. Nuclear Regulatory Commission
Region II - Suite 818
230 Peachtree Street, N. W.
Atlanta, Georgia 30303

Attention: Mr. J. P. O'Reilly, Director

Gentlemen:

SUBJECT: Grand Gulf Nuclear Station
File 0270/0498/15525
Interim Report No. 2 for
PRD-79/09 As Defined in
10 CFR 50.55(e)
AECM-79/92

On April 18, 1979, Mississippi Power & Light Company notified Mr. J. K. Rausch of your office of a potential reportable deficiency at the Grand Gulf Nuclear Station construction site concerning elbow fittings with incorrect carbon content.

The investigation has not been completed to determine the location of the elbows and the subsequent evaluation of the consequences had such a condition remained undetected. Therefore, our final report and determination of reportability will be provided to you by November 30, 1979.

Very truly yours,

L. F. Dale
Nuclear Project Manager

LFD:mlc

cc: Mr. N. L. Stampley
Mr. R. B. McGehee
Mr. T. B. Conner

Mr. John G. Davis, Director
Division of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Bols 10

977 116

7909190464

790188
OFFICIAL COPY