

NRC-PDR



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

AUG 21 1979

MEMORANDUM FOR: A. Schwencer, Chief, Operating Reactors Branch #1, DOR  
FROM: G. Lainas, Chief, Plant Systems Branch, DOR  
SUBJECT: FARLEY UNIT 1: EVALUATION OF THE ELECTRICAL,  
INSTRUMENTATION AND CONTROL (EI&C) ASPECTS OF  
THE DELETION OF REACTOR TRIP ON TURBINE TRIP  
BELOW 50 PERCENT POWER (TAC 11053)

In accordance with your request per TAC 11053, enclosed is the Plant Systems Branch Safety Evaluation Report pertaining to the Farley license amendment request for deletion of reactor trip on turbine trip below 50 percent power.

As indicated in the Safety Evaluation Report, we have concluded that the change is acceptable. However, this review was done prior to the B&O effort. The approval of this change may not be consistent with the B&O effort. Namely, that this modification deletes reactor trip on turbine trip below 50% power. We would recommend your holding the enclosed Safety Evaluation Report pending completion of the B&O effort, and that the licensee be so notified. In any event, we consider this TAC completed.

G. Lainas, Chief  
Plant Systems Branch  
Division of Operating Reactors

Enclosure:  
As stated

Contact:  
P. Shemanski  
X-28077

cc w/enclosure:  
D. Eisenhut      D. Tondi  
B. Grimes        P. Shemanski  
W. Gammill        PSB, Section A  
E. Reeves         D. Ross  
D. Neighbors     S. Newberry  
G. Lainas         J. Joyce

978135

7909210021