



UNITED STATES
NUCLEAR REGULATORY COMMISSION
REGION I
631 PARK AVENUE
KING OF PRUSSIA, PENNSYLVANIA 19406

September 7, 1979

Docket Nos. 50-336
50-245
50-423

Northeast Nuclear Energy Company
ATTN: Mr. W. G. Council
Vice President - Nuclear
Engineering and Operations
P. O. Box 270
Hartford, Connecticut 06101

Gentlemen:

The enclosed supplement to Bulletin No. 79-14 is forwarded to you to provide added guidance on the intent of the Bulletin. If you desire additional information regarding this matter, please contact this office.

Sincerely,


for Boyce H. Grier
Director

Enclosures:

1. Supplement 2 to IE Bulletin
No. 79-14
2. List of IE Bulletins Issued
in Last Six Months

cc w/encs:

K. W. Gray, Construction Quality Assurance Lead
H. R. Nims, Director of Nuclear Projects
J. F. Opeka, Station Superintendent
D. G. Diedrick, Manager of Quality Assurance
J. R. Himmelwright, Licensing Safeguards Engineer
A. Z. Roisman, Natural Resources Defense Council

978353

7909210 238

ENCLOSURE 1

SSINS: 6820
Accession No.: 7908220109

UNITED STATES
NUCLEAR REGULATORY COMMISSION
OFFICE OF INSPECTION AND ENFORCEMENT
WASHINGTON, D.C. 20555

IE Bulletin No. 79-14
Supplement 2
Date: September 7, 1979
Page 1 of 2

SEISMIC ANALYSIS FOR AS-BUILT SAFETY-RELATED PIPING SYSTEMS

Description of Circumstances:

IE Bulletin No. 79-14 was issued on July 2, revised on July 18, and first supplemented on August 15, 1979. The bulletin requested licensees to take certain actions to verify that seismic analyses are applicable to as-built plants. Supplement 2 provides the following additional guidance with regard to implementation of the bulletin requirements:

Nonconformances

One way of satisfying the requirements of the bulletin is to inspect safety-related piping systems against the specific revisions of drawings which were used as input to the seismic analysis. Some architect-engineers (A-E) however, are recommending that their customers inspect these systems against the latest revisions of the drawings and mark them as necessary to define the as-built configuration of the systems. These drawings are then returned to the AE's offices for comparison by the analyst to the seismic analysis input. For licensees taking this approach, the seismic analyst will be the person who will identify nonconformances.

The first supplement to the bulletin provided guidance with regard to evaluation of nonconformances. That guidance is appropriate for licensees inspecting against later drawings. The licensee should assure that he is promptly notified when the AE identifies a nonconformance, that the initial engineering judgment is completed in two days and that the analytical engineering evaluation is completed in 30 days. If either the engineering judgement or the analytical engineering evaluation indicates that system operability is in jeopardy, the licensee is expected to meet the applicable technical specification action statement.

Visual Approximations

Some licensees are visually estimating piping elements, and have not documented which data. Visual estimation of dimensions is not encouraged where visual estimates are used, the accuracy requirements. Further, in documenting, visually identify those data that were visually

DUPLICATE DOCUMENT

978354

Entire document previously entered into system under:

ANO 7908220109

No. of pages: 7