



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20585

August 15, 1979

Docket No. 50-286

LICENSEE: POWER AUTHORITY OF THE STATE OF NEW YORK

FACILITY: INDIAN POINT, UNIT NO. 3

SUBJECT: SUMMARY OF MEETING ON AUGUST 7, 1979, TO DISCUSS RESOURCE RECOVERY SYSTEM INTERFACE WITH INDIAN POINT, UNIT NO. 3

A meeting was held on August 7, 1979, between representatives of the Power Authority of the State of New York (PASNY), Black & Veatch, and the NRC staff. A list of attendees is given in Enclosure 1. The purpose of the meeting was to discuss the interface between Indian Point 3 and a municipal solid waste (MSW) incinerator plant being constructed by Westchester County. The material in Enclosure 2 was distributed at the meeting and summarizes the formal presentation given by the licensee.

In addition to the three plans listed in Enclosure 2, two other plans were discussed. Plan D uses the MSW facility as the heat input for a distillation plant, the output of which would be used for Indian Point 3 and others. Plan E involves constructing a turbine-generator at the MSW facility and tying its electrical output into the Indian Point 3 switchyard.

During the meeting the following comments were made by the NRC staff:

- (1) In several of the plans (especially Plan A), a steam generator tube leak could result in the transfer of radioactive water to the MSW facility. Therefore, radiation monitoring of the return line to the MSW facility would be required.
- (2) The licensee should determine if the proposed plan increases the consequences or probability of accidents or transients. For example, in Plan B, the loss of feedwater heating and, in Plan C, the partial loss of feedwater are transients that should be reviewed.
- (3) The licensee should demonstrate that a sudden loss of MSW steam would not create a transient that may result in reactor thermal output greater than that which is licensed.
- (4) If the plan chosen by the licensee requires a change to the license or Technical Specifications, the NRC must review the change. The review would probably be low priority and could take a significant amount of time. Although the licensee may conclude that a change tying Indian

1043 329

7909270648

Meeting Summary for
Indian Point, Unit 3

-2-

August 15, 1979

Point 3 with an incinerator plant could be made without prior Commission approval as provided for in 10CFR 50.59, it would be prudent to inform the NRC of such a conclusion before proceeding with the change.

- (5) The licensee should consider what effect rupture of the steam pipe from the MSW facility could have on the nuclear plant.

The licensee said that our comments would be used in the final decision on the interface between Indian Point 3 and Worcester County's Municipal Solid Waste Incinerator Plant.

L. N. Olshan

L. N. Olshan, Project Manager
Operating Reactors Branch #1
Division of Operating Reactors

Enclosures:

1. List of Attendees
2. Tentative Agenda for Meeting with NRC

cc: w/enclosures
See next page

1043 328

Enclosure 1

LIST OF ATTENDEES

POWER AUTHORITY OF THE STATE OF NEW YORK MEETING

PASNY

G. Stillman
A. Thau
S. Wayne

NRC

T. Decker *
L. Olshan
R. Samworth
J. Wilson
R. Woods

BLACK & VEATCH

S. Day
K. Habiger
E. Smith

* Part-time attendance

1043 328

Enclosure 2

WESTCHESTER COUNTY, NEW YORK
POWER AUTHORITY OF THE STATE OF NEW YORK
RESOURCE RECOVERY SYSTEM INTERFACE STUDY

MEETING WITH THE NUCLEAR REGULATORY COMMISSION, AUGUST 7, 1979

TENTATIVE AGENDA


I. Introduction

- A. Introduction of meeting participants
- B. Presentation of background information
 - 1. Westchester County Plans for a municipal solid waste (MSW) incinerator plant. Study program and consultant input.
 - 2. Location of MSW plant.
 - 3. Potential uses of MSW plant steam.
- C. Objectives of meeting
 - 1. Describe the alternative uses of MSW steam under consideration for IP3.
 - 2. Identify potential NRC concerns for each of the alternatives. Discuss potential solution to problem areas.
 - 3. Obtain listing of licensing requirements (Types of licenses, applications and hearing requirements, etc.).
 - 4. Obtain from the NRC preliminary estimates of the schedule for the licensing process. Identify differences between alternatives.
 - 5. Determine effect on IP3 license.

II. Alternative Uses of Steam at IP3

- A. Description of existing IP3 facilities
 - 1. General arrangement.
 - 2. Source of cooling water and makeup water.
 - 3. Turbine plant.
- B. Plan A - Inject MSW steam into IP3 secondary steam loop
 - 1. Plan description
 - 2. Advantages/disadvantages
 - 3. Concerns/potential solutions.

- C. Plan B - Use MSW steam to heat feedwater at IP3
 - 1. Plan description.
 - 2. Advantages/disadvantages.
 - 3. Concerns/potential solutions.
 - D. Plan C - Use MSW steam to drive an additional steam generator feedpump, to produce makeup water for IP3 and area industry, and to supply the auxiliary steam reboiler.
 - 1. Plan description.
 - 2. Advantages/disadvantages.
 - 3. Concerns/potential solutions.
 - E. Summary comparison
- III. NRC Comments
- A. Potential problem areas/potential solutions
 - B. Licensing schedule
 - C. Comparative licensing feasibility
 - D. Unresolved issues
- IV. Summary and conclusions



WESTCHESTER COUNTY, NEW YORK
POWER AUTHORITY OF THE STATE OF NEW YORK
RESOURCE RECOVERY SYSTEM INTERFACE STUDY

MEETING WITH THE NUCLEAR REGULATORY COMMISSION
AUGUST 7, 1979

MEETING OBJECTIVES

DESCRIBE ALTERNATIVE USES OF MSW STEAM AT IP3.


IDENTIFY POTENTIAL NRC CONCERNS. DISCUSS POTENTIAL SOLUTIONS.

OBTAIN LISTING OF LICENSING REQUIREMENTS.

OBTAIN ESTIMATES OF THE LICENSING SCHEDULE.

DETERMINE EFFECT ON THE CURRENT IP3 LICENSE.

1043 333



POOR
ORIGINAL

1043 334

POOR
ORIGINAL

1043 335





Fig. III-2. Schematic representation of Indian Point Plant cooling water systems.

INDIAN POINT 3 THERMAL CAPACITIES

		Capacities		
	<u>Rated (Licensed)</u>	<u>Maximum Guaranteed</u>	<u>Maximum Calculated</u>	
Reactor Power, MW(t)	3,025	3,087	3,216	
Gross Electrical Power, MW(e)	1,001	1,021	1,068	
Net Electrical Power, MW(e)	965	986	1,033	
Main Steam Flow, 10^6 lb/hr	12.97	13.28	13.95	

1043 335

EXISTING INDIAN POINT 3 TURBINE CYCLE ARRANGEMENT



POOR
ORIGINAL

1043 33%

POOR
ORIGINAL

TABLE 10.1-1

STEAM AND POWER CONVERSION SYSTEM COMPONENT
DESIGN PARAMETERS

Turbine-Generator

Turbine Type	Four element, tandem-compound six - flow exhaust
Turbine Capacity (KW)	
Maximum guaranteed	1,021,793
Maximum calculated	1,068,701
Generator Rating (KVA)	1,125,600
Turbine Speed (rpm)	1800

Condensers

Type	Radial flow, single pass, divided water box, deaerating
Number	3
Condensing Capacity (lbs of steam/hr)	7,230,000


Condensate Pumps

Type	8 stage, vertical pit type, centrifugal
Number	3
Design Capacity (each-gpm)	7860
Motor Type	Vertical Induction
Motor Rating (hp)	3000

Feedwater Pumps

Type	High Speed, barrel coring, single stage, centrifugal
Number	2
Design Capacity (each-gpm)	15,300
Pump Drive	Horizontal steam turbine
Drive Rating (hp)	8350

ORIGINAL



NET RATE = 13947446 (1158.8-610.9) = 1068701 BTU/KW HR

CALCULATIONS ARE BASED ON NO RADIATION LOSSES TO HEATERS OR EXTRACTION PIPING LOCATED IN THE CONDENSER NECK.

PRIMARY VALVE AND ABOVE HEAT RATES ARE CALCULATED ON LOCUS OF VALVE POINTS.

STEAM GEN FLOW AT MAX CALC IS NOT GUARANTEED.

MAX GUAR SG. FLOW = 13283282 LB/HR.

MAX CALC. SG. FLOW = 13947446 LB/HR.

TEP = 992.3 BTU/LB
ELEP = 973.4 BTU/LB
MECH LOSS = 3648 KW
ELECT LOSS = 11940 KW
0.90PF 73 Hz
FWP POWER = 13624 KW
FWP EFF = 85%


1021793 KW TURB-GEN. UNIT TC6F-44IN.
730 PSIA - 507.8 F 1.5 IN. HGA
1125400 KVA 0.90 PF 22000 VOLTS 75 Hz

1068701 KW NET LOAD HEAT BALANCE

MAXIMUM CALCULATED - NOT GUARANTEED

LESTER, PENNA.
ENGR. VJM
LCD-2099
DATE: 2/13/68
CT-21369
REV. A 7/68

FIGURE 10-2



NET
HEAT
RATE = 13283282 (1198.8-405.8)
1021793 = 10309

BTU/KW HR

B1 CALCULATIONS ARE BASED ON NO RADIATION LOSSES TO HEATERS OR EXTRACTION PIPING LOCATED IN THE CONDENSER NECK.

Q1 PRIMARY VALVE AND ABOVE HEAT RATES ARE CALCULATED ON LOCUS OF VALVE POINTS.

STEAM GEN FLOW AT MAX CALC. IS NOT GUARANTEED.

MAX GUAR. SG. FLOW = 13283282 LB/HR.

MAX.CALC. SG. FLOW = 13947446

LB/HR.

TEP = 994.0 BTU/LB
ELEP = 976.7 BTU/LB
MECH LOSS = 3648 KW
ELECT LOSS = 12661. KW
0.90 PF 73 H₂O
FWP POWER = 13226 KW
FWP EFF = 86%


1021793 KW TURB-GEN. UNIT TC6F-44 IN.
730PSIA = 507.8F 1.5IN.HGA
1123600 KVA 0.90 PF 22000 VOLTS 75 H₂O

1021793 KW NET LOAD HEAT BALANCE

MAXIMUM GUARANTEED

W
LESTER, PE
ENGR. V.JN-J
L.C.D-205
DATE: 2/13/86
CT- 21370
REV. A 4/1

FIGURE 10-3



WT HLC RATE	3661940 (1193.7-293.7) 255448	= 12902	BTU/KW HR
CALCULATIONS ARE BASED ON NO RADIATION LOSSES TO HEATERS OR EXTRACTION PIPING LOCATED IN THE CONDENSER NECK			
PRIMARY VALVE AND ABOVE HEAT RATES ARE CALCULATED ON LOCUS OF VALVE POINTS			
STEAM GEN FLOW AT MAX CALC. IS NOT GUARANTEED.			
MAX GUSH SG FLOW = 13233202. LB/hr.	MAX CALC. SG FLOW = 13947446	LB/HR.	

TEP = 1044.7 BTU/LB
 ELEP = 1038.8 BTU/LB
 MECH LOSS = 3648 KW
 ELECT LOSS = 3032 KW
 0.60 PF 75 Hz
 FWP POWER = 2391 KW
 TWP EFF. = 80%

1021793KW TURB-GEN UNIT TC6F-44IN.
 730 PSIA = 307.8 F 1.5 IN.HGA
 1125600KVA 0.90 PF 32000VOLTS 75 Hz


255448 KW NET LOAD HEAT BALANCE

25% LOAD

FIGURE 10-7

W
 LESTER, PENNA.
 ENGR. VJM-JLF
 LCD-2111
 DATE 2/12/00
 CT-21376
 REV A 4/1/00

POOR
ORIGINAL



PLAN A - INJECT MSW STEAM INTO IP 3 SECONDARY STEAM CYCLE

RESOURCE RECOVERY SYSTEM INTERFACE STUDY
PLAN A - INJECT MSW STEAM INTO THE IP3
SECONDARY STEAM CYCLE

ADVANTAGES AND DISADVANTAGES

ADVANTAGES

LARGE POTENTIAL FOR INCREASED ELECTRICAL OUTPUT
LOW CAPITAL COSTS

DISADVANTAGES

WATER CHEMISTRY AND MATERIAL REQUIREMENTS
LOAD FOLLOWING REQUIREMENTS
ADDITIONAL BOUNDARY SEPARATION REQUIREMENTS
RADIATION DOSE CONSIDERATIONS
TIME AND EFFORT REQUIRED FOR LICENSING

POOR
ORIGINAL

1043 343

RESOURCE RECOVERY SYSTEM INTERFACE STUDY
PLAN A - INJECT MSW STEAM INTO THE IP3
SECONDARY STEAM CYCLE

LICENSING CONCERNS AND POTENTIAL SOLUTIONS

CHEMISTRY AND MATERIALS

ALL VOLATILE MSW CHEMISTRY

MSW MATERIAL SPECIFICATIONS

LOAD FOLLOWING

CONTROL VALVES

BOUNDARY SEPARATION

STEAM ANALYZERS

ISOLATION VALVES (AUTOMATIC ISOLATION)


RADIATION DOSE

ADDITIONAL DOSE CALCULATIONS

RADIATION MONITORS

ISOLATION VALVES (AUTOMATIC ISOLATION)

**POOR
ORIGINAL**



**PLAN B - USE MSW STEAM TO HEAT AN
ADDITIONAL IP 3 FEEDWATER HEATER**

RESOURCE RECOVERY SYSTEM INTERFACE STUDY
PLAN B - USE MSW STEAM TO HEAT FEEDWATER
AT IP3

ADVANTAGES AND DISADVANTAGES

ADVANTAGES

MODERATELY LARGE POTENTIAL FOR INCREASED ELECTRICAL OUTPUT
INTERMEDIATE CAPITAL COSTS
SIMPLIFIED CONTROL
BARRIER BETWEEN IP3/MSW FLUIDS
MODERATE LICENSING REQUIREMENTS

DISADVANTAGES

REQUIRES NEW BUILDING
POTENTIAL HEAT EXCHANGER TUBE LEAKS (OFFSITE DOSE POTENTIAL)

RESOURCE RECOVERY SYSTEM INTERFACE STUDY
PLAN B - USE MSW STEAM TO HEAT FEEDWATER
AT IP3

LICENSING CONCERNS AND POTENTIAL SOLUTIONS

HEAT EXCHANGER TUBE LEAKS

ADDITIONAL DOSE CALCULATIONS

RADIATION MONITORS


ISOLATION VALVES (AUTOMATIC ISOLATION)

POTENTIAL CHANGE IN FEEDWATER TEMPERATURES

STEADY STATE/TRANSIENT ANALYSES

1043 348

POOR
ORIGINAL



RESOURCE RECOVERY SYSTEM INTERFACE STUDY
PLAN C - USE OF MSW STEAM TO PROVIDE MAKEUP WATER
FOR IP3, TO HEAT THE AUXILIARY STEAM
REBOILER, AND TO DRIVE AN ADDITIONAL
STEAM GENERATOR FEEDPUMP

ADVANTAGES/DISADVANTAGES

ADVANTAGES

PROVIDES ALTERNATE SOURCE OF MAKEUP WATER
IMPROVED PLANT AVAILABILITY
NO POTENTIAL FOR IP3/MSW FLUID MIXING
PARTIAL USER OF MSW STEAM WHEN IP3 IS DOWN
SIMPLIFIED LICENSING
ADDITIONAL ELECTRICAL OUTPUT

DISADVANTAGES

HIGH CAPITAL COSTS
REQUIRES NEW BUILDING
COMPLICATES FEEDPUMP CONTROL
REQUIRES ADDITIONAL INTAKE STRUCTURE OR MODIFICATION OF EXISTING
CIRCULATING WATER SYSTEM

LICENSING CONCERNS AND POTENTIAL SOLUTIONS

FEEDPUMP CONTROL

DETAILED STEADY STATE AND TRANSIENT ANALYSES

WESTCHESTER COUNTY, NEW YORK
POWER AUTHORITY OF THE STATE OF NEW YORK
RESOURCE RECOVERY SYSTEM INTERFACE STUDY

POTENTIAL INCREASE IN ELECTRICAL
GENERATING CAPACITY

<u>Plan</u>	<u>Additional Generating Capacity, MWe</u>
A (Inject steam into LP turbine)	18.2
B (Additional feedwater heater)	23.7
C (Feedpump turbine, aux. steam reboiler)	
Feedpump turbine	4.6
Aux. steam reboiler	5.5

1043 350

Mr. George T. Berry
Power Authority of the State of New York

cc: White Plains Public Library
100 Martine Avenue
White Plains, New York 10601

Mr. Vito J. Cassan
Assistant General Counsel
Power Authority of the
State of New York
10 Columbus Circle
New York, New York 10019

Anthony Z. Roisman
Natural Resources Defense Council
917 - 15th Street, N.W.
Washington, D. C. 20005

Dr. Lawrence D. Quarles
Apartment 51
Kendal at Longwood
Kennett Square, Pennsylvania 19348

Mr. George M. Wilverding
Licensing Supervisor
Power Authority of the
State of New York
10 Columbus Circle
New York, New York 10019

Mr. P. W. Lyon
Manager - Nuclear Operations
Power Authority of the
State of New York
10 Columbus Circle
New York, New York 10019

Mr. J. P. Bayne, Resident Manager
Indian Point 3 Nuclear Power Plant
P. O. Box 215
Buchanan, New York 10511

Mr. J. W. Blake, Ph.D., Director
Environmental Programs
Power Authority of the
State of New York
10 Columbus Circle
New York, New York 10019

Theodore A. Rebelski
U. S. Nuclear Regulatory Commission
P. O. Box 38
Buchanan, New York 10511

1043 35

Meeting Summary for
Indian Point 3

10/12/88

Docket File

NRC PDR

Local PDR

NRR Reading

ORB1 Reading

H. Denton

E. Case

D. Eisenhut

G. Zech

W. Gammill

J. Miller

L. Shao

R. Vollmer

W. Russell

B. Grimes

T. J. Carter

T. Ippolito

R. Reid

A. Schwencer

D. Ziemann

V. Noonan

P. Check

G. Lainas

G. Knighton

Chief, Systematic Evaluation Branch

Project Manager

DOE Licensing Assistant

OELD

OI&E (3)

R. Fraley, ACRS (16)

Program Support Branch

TERA

J. R. Buchanan

NRC Participants

Short Service List

1043 352