



435 Sixth Avenue
Pittsburgh, Pa.
15219

(412) 456-6000

DUQUESNE LIGHT COMPANY
Beaver Valley Power Station
Post Office Box 4
Shippingport, PA 15077

September 21, 1979
BVPS:JAW:721

Beaver Valley Power Station, Unit No. 1
Docket No. 50-334, License No. DPR-66
LERs 79-27/03L, 79-30/03L, 79-33/03L, 79-35/03L

Mr. B. H. Grier, Director of Regulation
United States Nuclear Regulatory Commission
Region 1
631 Park Avenue
King of Prussia, Pennsylvania 19406

Dear Mr. Grier:

In accordance with Appendix A, Beaver Valley Technical Specifications,
the following Licensee Event Reports are submitted:

LER 79-27/03L, Technical Specification 3.7.7.1, Control room air conditioning
system seismic support removed.

LER 79-30/03L, Technical Specification 6.9.1.9.c, missed surveillance test.

LER 79-33/03L, Technical Specification 6.9.1.9.b, NIS Power Range low
setpoint trip logic failure.

LER 79-35/03L, Technical Specification 4.7.8.12.3, Inoperable hydraulic
snubbers.

Very truly yours,

HP Williams

for J. A. Werling
Superintendent

Attachments

1035 049

7909280500

A002
5/11

Mr. E. H. Grier
September 21, 1979
BVPS:JAW:721
Page 2

cc: Director Of Management & Program Analysis ✓
United States Nuclear Regulatory Commission
Washington, D. C. 20555

D. L. Wigginton, BVPS Licensing Project Manager
United States Nuclear Regulatory Commission
Washington, D. C. 20555

D. A. Beckman, Nuclear Regulatory Commission, King of Prussia, PA

G. A. Olson, Secretary, Prime Movers Committee - EEI