

ATTACHMENT 1

SUPPLEMENT NO. 1

TO THE

SAFETY EVALUATION REPORT

BY THE

OFFICE OF NUCLEAR REACTOR REGULATION  
UNITED STATES NUCLEAR REGULATORY COMMISSION

IN THE MATTER OF

METROPOLITAN EDISON COMPANY  
NEW JERSEY CENTRAL POWER AND LIGHT COMPANY  
PENNSYLVANIA ELECTRIC COMPANY

THREE MILE ISLAND NUCLEAR STATION  
UNIT 2

DOCKET NUMBER 50-322

POOR ORIGINAL

7910050 018

G 1108 260

## 16.0 ACCIDENT ANALYSIS

### Additional Consequences of Accidents

#### General

As noted in the Safety Evaluation Report, we had previously concluded that with a containment leak rate of 0.10 percent per day and a dose reduction factor of 100, the effluents dose guidelines of 10 CFR Part 100 would be met.

We have reviewed the revised gaseous additive system described in Section 15.1 of this supplement, and conclude that this system, although slightly less effective than the system originally proposed in that it does not remove the organic form of iodine, results in a sufficiently high concentration of the inorganic elements' form to meet the effluents dose guidelines of 10 CFR Part 100 with a leak rate of 0.10 percent per day. Table 16.1 has been completed to show the total effluents dose resulting from the postulated accident.

#### Design Basis Accident Assumptions

In the Safety Evaluation Report, we had not considered the assumption of a 100 percent containment leakage with a 10 percent leakage rate for the design basis accident of a gaseous additive system. These assumptions are listed below.

The iodine removed by the gaseous additive system was based on:

Design basis containment volume	10,000 m <sup>3</sup>
Design basis containment leakage	100%
Leakage rate between design and accident regions	0.10 percent per day calculated for 100 days 10,000 cubic feet per day
Iodine removal coefficients	
Elemental	10.0 hours <sup>-1</sup>
Organic	0.0
Particulate	0.1 hours <sup>-1</sup>
Elemental iodine administration factor	100

TABLE 15.1

POTENTIAL FACILITY LOSSES DUE TO DESIGN-BASED ACCIDENTS

Accident	Two Hour Exclusion Boundary/ (617 Meters)		Course of Accidents Low Population Line (3216 Meters)	
	Person	Item	Person	Item
Loss of Offsite Power	280	0.2	108	0.1
Loss of Offsite Power with Cont. Ident. Isoline Turke			< 1	
Loss of Offsite Power with Cont. Ident. Isoline Turke	46	3		
Loss of Offsite Power with Cont. Ident. Isoline Turke	6	1		
Loss of Offsite Power with Cont. Ident. Isoline Turke	76	1		
Loss of Offsite Power	1	< 1		
Loss of Offsite Power with Cont. Ident. Isoline Turke	1	< 1		
Gas Cont. Tank Rupture	Negligible	3	Negligible	1
Rad. Emission** Case I:	24	< 1	11	1
Case II:	102	2	19	1

\*\* Actual rad. emission drops will not exceed the losses for Case I (leak of through the containment) or Case II (leakage through the secondary system).