

APPENDIX A

NOTICE OF VIOLATION

Philadelphia Electric Company

Docket Nos. 50-277
50-278

Based on the results of an NRC inspection conducted February 13-16, 1979, it appears that one of your activities was not conducted in full compliance with NRC regulations and the conditions of your licenses as indicated below. This item is an infraction.

10 CFR 20.201(b), "Surveys," requires that such surveys be conducted as may be necessary to comply with the regulations contained in each section of Part 20. A "survey," as defined in Paragraph 20.201(a), means "an evaluation of the radiation hazards incident to production, use, release, disposal, or presence of radioactive materials or other sources of radiation under a specific set of conditions. When appropriate, such evaluation includes a physical survey of the location of materials and equipment, and measurements of levels of radiation or concentrations of radioactive materials present."

Contrary to this requirement, during the period from January through December, 1978, evaluations adequate to assure compliance with 10 CFR 20.101 were not made when accumulated daily Thermoluminescent Dosimetry (TLD) badge results were discounted and the monthly TLD badge results used in determining quarterly accumulated exposure, when no factual basis for discounting the accumulated daily TLD badge results had been identified.

1127 056

7910050 49.