

NAL PDR



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

AUG 24 1979

Docket Nos. 50-445
and 50-446

Mr. R. J. Gary
Executive Vice President and
General Manager
Texas Utilities Generating Company
2001 Bryan Towers
Dallas, Texas 75201

Dear Mr. Gary:

SUBJECT: SECONDARY WATER CHEMISTRY CONTROL
(Comanche Peak Steam Electric Station)

In late 1975 we incorporated provisions into the Standard Technical Specifications (STS) that required limiting conditions for operation and surveillance requirements for secondary water chemistry parameters. The proposed Technical Specifications for your plant(s), as well as for other Pressurized Water Plants that have been issued an Operating License since 1974 or are now under review for an Operating License, contain either these provisions or a requirement to establish these provisions after baseline chemistry conditions have been determined. The intent of the provisions was to provide added assurance that the operators of newly licensed plants would properly monitor and control secondary water chemistry to limit corrosion of steam generator tubes.

In a number of instances the Technical Specifications have significantly restricted the operational flexibility of some plants with little or no benefit with regard to limiting corrosion of steam generator tubes. Based on this experience and the knowledge gained in recent years, we have concluded that Technical Specification limits are not the most effective way of assuring that steam generator tube corrosion will be minimized.

Due to the complexity of the corrosion phenomena involved and the state-of-the-art as it exists today, we believe that, in lieu of Technical Specifications, a more effective approach would be to institute a license condition that requires the implementation of a secondary water chemistry monitoring and control program containing appropriate procedures and administrative controls.

1123 356

10
7910 0446

AUG 24 1979

The required program and procedures would be developed by the licensee (or applicant) with any needed input from their reactor vendors or other consultants, and thus could more readily account for site and plant-specific factors that affect chemistry conditions in the steam generators. In our view, plant operation following such procedures would provide assurance that licensees would devote proper attention to controlling secondary water chemistry, while also providing the needed flexibility to allow them to deal more effectively with any off-normal conditions that might arise.

Consequently, we request that you amend your FSAR to include your proposed secondary water chemistry program which will be referenced in a condition to your operating license and will replace any proposed Technical Specifications on secondary water chemistry. A model license condition is enclosed. We have concluded that such a license condition, in conjunction with existing Technical Specifications on steam generator tube leakage and inservice inspection, would provide the most practical and comprehensive means of assuring that steam generator tube integrity would be maintained.

If you have any questions, please contact us.

Sincerely,

Robert L. Baer

for

Robert L. Baer, Chief
Light Water Reactors Branch No. 2
Division of Project Management

Enclosure:
Model License Condition

cc w/enclosure:
See next page

1123 357

Mr. R. J. Gary

Mr. R. J. Gary
Executive Vice President and
General Manager
Texas Utilities Generating Company
2001 Bryan Towers
Dallas, Texas 75201

Nicholas S. Reynolds, Esq.
Debevoise & Liberman
1200 Seventeenth Street
Washington, D.C. 20036

Spencer C. Relyea, Esq.
Worsham, Forsythe & Sampels
2001 Bryan Tower
Dallas, Texas 75201

Mr. Homer C. Schmidt
Project Manager - Nuclear Plants
Texas Utilities Generating Company
2001 Bryan Tower
Dallas, Texas 75201

Mr. H. R. Rock
Gibbs and Hill, Inc.
393 Seventh Avenue
New York, New York 10001

Mr. A. T. Parker
Westinghouse Electric Corporation
P. O. Box 355
Pittsburgh, Pennsylvania 15230

Richard W. Lowerre, Esq.
Assistant Attorney General
Environmental Protection Division
P. O. Box 12548, Capitol Station
Austin, Texas 78711

Mrs. Juanita Ellis, President
Citizens Association for Sound
Energy
1426 South Polk
Dallas, Texas 75224

Geoffrey M. Gay, Esq.
West Texas Legal Services
406 W.T. Waggoner Building
810 Houston Street
Fort Worth, Texas 76102

1123 350

Mr. R. J. Gary

Ms. Nancy Holdam Jacobson
Citizens for Fair Utility
Regulation
1400 Hemphill
Fort Worth, Texas 76104

Mr. Richard Fouke
1668-B Carter Drive
Arlington, Texas 76010

1123 359

ENCLOSURE

MODEL LICENSE CONDITION

SECONDARY WATER CHEMISTRY MONITORING

The licensee shall implement a secondary water chemistry monitoring program in accordance with (reference Licensee's Procedure) to inhibit steam generator tube degradation. This program includes:

1. Identification of a sampling schedule for the critical parameters and of control points for these parameters;
2. Identification of the procedures used to measure the value of the critical parameters;
3. Identification of process sampling points;
4. Procedure for the recording and management of data;
5. Procedures defining corrective actions for off-control point chemistry conditions; and
6. A procedure identifying (1) the authority responsible for the interpretation of the data and (2) the sequence and timing of administrative events required to initiate corrective action.

1123 360