

YANKEE ATOMIC ELECTRIC COMPANY



Rowe, Massachusetts 01367

October 8, 1979

Mr. B. H. Grier, Director
U.S. Nuclear Regulatory Commission
Office of Inspection and Enforcement
Region I
631 Park Avenue
King of Prussia, Pennsylvania 19406

Subject: Reportable Occurrence 50-29/79-22/03L
Secondary Water Chloride Ion Concentration
Greater Than 0.5 ppm

Mr. Grier:

In accordance with Technical Specifications, Section 6.9.4.b, the attached Licensee Event Report is hereby submitted.

Very truly yours,

Herbert A. Antio
Plant Superintendent

ELM/amt

Enclosure:

cc: [30] Director, Office of Inspection and Enforcement
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

[3] Director, Office of Management Information & Program Control
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

1129 244

7910110

331

5