

BALTIMORE GAS AND ELECTRIC COMPANY

P.O. BOX 1475

BALTIMORE, MARYLAND 21203

ARTHUR E. LUNDVALL, JR.
VICE PRESIDENT
SUPPLY

August 27, 1979

U. S. Nuclear Regulatory Commission
Region I
631 Park Avenue
King of Prussia, Pennsylvania 19406

Docket Nos. 50-317/50-318
License Nos. DPR-53/DPR-69


ATTENTION: George H. Smith, Chief
Fuel Facility and Materials, Safety Branch

Gentlemen:

This refers to your Inspection Report 50-317/79-08 and 50-318/79-07, which transmitted an item of apparent non-compliance with NRC requirements. Enclosure (1) to this letter is a written statement in reply to the item noted in your letter of August 8, 1979.

Should you have further questions regarding this reply, we will be pleased to discuss them with you.

Very truly yours,



A. E. Lundvall, Jr.
Vice President-Supply

Enclosure (1)

1147 199

7910160

190

Q

ENCLOSURE (1)

REPLY TO NRC LETTER DATED AUGUST 8, 1979
NRC INSPECTION REPORT 50-217/79-03 AND 50-318/79-07

ITEM A RESPONSE:

Upon notification, the Radiation Safety and Chemistry Group immediately posted the low level radioactive storage trailer, Spent Fuel Storage Room, and storage pad West of Units 1 and 2 Auxiliary Building in accordance with 10CFR20.203. Additionally, an inspection was performed by Rad-Chem of our entire facility which revealed that no other areas or rooms required similar posting. Particular attention was given this item by reinstruction of all Rad-Chem Technicians by the Radiation Safety and Chemistry Foreman in the requirements of posting radioactive materials storage areas. To aid in preventing recurrence of this item procedural change was made to clarify when an area became a radioactive materials storage area; i.e., whenever radioactive materials that exceed 10 times the quantity of such materials specified in Appendix C of 10CFR20 are intended to be stored in any area for periods greater than twenty-four (24) hours.

Full compliance is considered to have been achieved as of May 24, 1979.