

### LICENSEE EVENT REPORT

CONTROL BLOCK: \_\_\_\_\_ (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 P A B V S 1 2 0 0 - 0 0 0 0 0 0 - 0 0 3 4 1 1 1 1 8 5  
7 8 9 LICENSEE CODE 14 15 LICENSE NUMBER 25 26 LICENSE TYPE 30 57 CAT 58

CON'T  
01 REPORT SOURCE L 6 0 5 0 0 0 3 3 4 7 0 9 1 0 7 9 8 1 0 1 0 7 9 9  
7 8 60 DOCKET NUMBER 58 69 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)  
02 | During surveillance testing of the 1A LHSI Pump, the pump did not develop the required  
03 | recirculation flow. The recirculation check valve was removed and two pieces of  
04 | one and one-half inch plastic fire hose nozzle were discovered in the valve. The line  
05 | was flushed and a new valve installed. The surveillance test was repeated and a third  
06 | piece of the nozzle was found in the valve. The redundant LHSI Pump was operable and  
07 | the 1A Pump was still capable of injecting as the injection flow path was not  
08 | restricted.

09 SYSTEM CODE S E 11 CAUSE CODE A 12 CAUSE SUBCODE X 13 COMPONE \* CODE V A L E X 14 COMP. SUBCODE C 15 VALVE SUBCODE A 16  
17 LER/RO REPORT NUMBER 7 9 21 22 SEQUENTIAL REPORT NO. 0 3 6 24 26 OCCURRENCE CODE 0 3 28 29 REPORT TYPE L 30 REVISION NO. 0 32  
ACTION TAKEN C 18 FUTURE ACTION X 19 EFFECT ON PLANT Z 20 SHUTDOWN METHOD Z 21 HOURS 0 0 0 0 22 ATTACHMENT SUBMITTED N 23 NRPD-4 FORM SUB. N 24 PRIME COMP. SUPPLIER Z 25 COMPONENT MANUFACTURER Z 9 9 9 26

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)  
10 | The incident resulted from the introduction of a Wilco Company, Model No. HN-4-L, fire  
11 | hose nozzle into the LHSI pump line. It is not known when it was put in the system nor  
12 | who is responsible. The surveillance frequency was increased to daily for one week and  
13 | then weekly for four weeks. No additional pieces have been located. The LHSI system  
14 | piping will be inspected to the extent possible during the refueling outage.

15 FACILITY STATUS E 28 % POWER 1 0 0 29 OTHER STATUS N/A 30 METHOD OF DISCOVERY B 31 DISCOVERY DESCRIPTION Surveillance test 32

16 ACTIVITY CONTENT Z 33 RELEASED OF RELEASE Z 34 AMOUNT OF ACTIVITY N/A 35 LOCATION OF RELEASE N/A 36

17 PERSONNEL EXPOSURES NUMBER 0 0 0 37 TYPE Z 38 DESCRIPTION N/A 39

18 PERSONNEL INJURIES NUMBER 0 0 0 40 DESCRIPTION N/A 41

19 LOSS OF OR DAMAGE TO FACILITY TYPE Z 42 DESCRIPTION N/A 43

20 PUBLICITY ISSUED N 44 DESCRIPTION N/A 45

NAME OF PREPARER J. A. Werling PHONE 412-643-1258  
7910170 2/2  
1148 31