

# NORTHEAST UTILITIES



THE CONNECTICUT LIGHT AND POWER COMPANY  
THE HARTFORD ELECTRIC LIGHT COMPANY  
WESTERN MASSACHUSETTS ELECTRIC COMPANY  
HOLYOKE WATER POWER COMPANY  
NORTHEAST UTILITIES SERVICE COMPANY  
NORTHEAST NUCLEAR ENERGY COMPANY

P.O. BOX 270  
HARTFORD, CONNECTICUT 06101  
(203) 666-6911

July 23, 1979

Docket No. 50-245

Mr. Eldon J. Brunner, Chief  
Reactor Operations and Nuclear Support Branch  
U. S. Nuclear Regulatory Commission  
Region I  
631 Park Avenue  
King of Prussia, PA 19406

References: (1) Inspection No. 50-245/78-25, Additional Information.  
(2) Letter, E. J. Brunner to W. G. Council dated February 5, 1979.

Gentlemen:

Millstone Nuclear Power Station, Unit No. 1  
Personnel Air Lock Testing

During the recent refueling outage, Millstone Unit No. 1 personnel successfully completed a leak test of the personnel air lock test at 43 psig (Pa).

In accordance with previous correspondence with the NRC, Millstone will propose revisions to plant technical specifications to locally leak rate test the drywell air lock at 43 psig at least once every six (6) months. Any additional tests required due to drywell entry for maintenance will be performed at 10 psig.

Very truly yours,

NORTHEAST NUCLEAR ENERGY COMPANY

W. G. Council  
Vice President

1177 280

7910180 231