

*tie*



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
REGION III  
799 ROOSEVELT ROAD  
GLEN ELLYN, ILLINOIS 60137

OCT 1 1979

Docket Nos. 50-10, 50-237, 50-249,  
50-254, 50-265, 50-295, 50-304, 50-373,  
50-374, 50-454, 50-455, 50-456 and 50-457

Commonwealth Edison Company  
ATTN: Mr. Byron Lee, Jr.  
Vice President  
Post Office Box 767  
Chicago, IL 60690

Gentlemen:

The enclosed IE Information Notice No. 79-24 provides information with regard to an analysis that identifies an event that could result in over-pressurization of containment at a pressurized water reactor.

Sincerely,

*James G. Keppler*  
James G. Keppler  
Director

Enclosure: IE Information  
Notice No. 79-24

cc w/encl:

Mr. B. B. Stephenson,  
Station Superintendent  
Mr. N. Kalivianakis,  
Station Superintendent  
Mr. N. Wandke, Station  
Superintendent  
Mr. L. J. Burke, Site  
Project Superintendent  
Mr. T. E. Quaka, Quality  
Assurance Supervisor  
Mr. R. H. Holyoak, Station  
Superintendent  
Mr. Gunner Sorensen, Site  
Project Superintendent

Mr. R. Cosaro, Project  
Superintendent  
Central Files  
Director, NRR/DPM  
Director, NRR/DOR  
PDR  
Local PDR  
NSIC  
TIC  
Anthony Roisman, Esq.,  
Attorney  
Mr. Dean Hansell, Office  
of Assistant Attorney  
General

1177 109

7910180 598

*Q*

SSINS: 6870  
Accession No:  
7908220123

UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
OFFICE OF INSPECTION AND ENFORCEMENT  
WASHINGTON, D. C. 20555

DUPLICATE

October 1, 1979

IE Information Notice No. 79-24

OVERPRESSURIZATION OF CONTAINMENT OF A PWR PLANT AFTER A MAIN STEAM LINE BREAK

Virginia Electric and Power Co. submitted a report dated September 7, 1979 that identified a deficiency in the original analyses of containment pressurization as a result of a steam line break for North Anna Power Station, Units 3 and 4.

Stone and Webster Engineering Corporation performed a reanalysis of containment pressure following a main steam line break and determined that, if the auxiliary feedwater system continued to supply feedwater at runout conditions to the steam generator that had experienced the steam line break, containment design pressure would be exceeded in approximately 10 minutes. The long term blowdown of the water supplied under runout conditions by the auxiliary feedwater system had not been considered in the earlier analyses. The corrective action is now under review by the owner, architect engineer, and NSSS supplier.

This Information Notice is provided as an early notification of a possibly significant matter that is still under review by the NRC staff. It is expected that recipients will review the information for possible applicability to their facilities. No specific action or response is requested at this time. If NRC evaluations so indicate, further licensee actions may be requested or required.

No written response to this Information Notice is required. If you have any questions regarding this matter please contact the Director of the appropriate NRC Regional Office.

Enclosure: List of IE Information  
Notices Issued in the Last Six Months

1177 110

LISTING OF IE INFORMATION NOTICES  
ISSUED IN LAST SIX MONTHS

Information Notice No.	Subject	Date Issued	Issued To
79-10	Nonconforming Pipe Support Struts	4/16/79	All power reactor facilities with a CP
79-11	Lower Reactor Vessel Head Insulation Support Problem	5/7/79	All holders of Reactor OLs and CPs
79-12	Attempted Damage to New Fuel Assemblies	5/11/79	All Fuel Facilities Research Reactors, and Power Reactors with an OL or CP
79-13	Indication of Low Water Level in the Oyster Creek Reactor	5/29/79	All Holders of reactor OLs and CPs
79-14	NRC Position of Electrical Cable Support Systems	5/11/79	All Power Reactor Facilities with a CP
79-15	Deficient Procedures	6/7/79	All Holders of Reactor OLs and CPs
79-16	Nuclear Incident at Three Mile Island	6/22/79	All Research Reactors and Test Reactors with OLs
79-17	Source Holder Assembly Damage From Misfit Between Assembly and Reactor Upper Grid Plate	6/20/79	All Holders of Reactor OLs and CPs
79-18	Skylab Reentry	7/5/79	All Holders of Reactor OLs
79-19	Pipe Cracks In Stagnant Borated Water Systems At PWR Plants	7/17/79	All Holders of Reactor OLs and CPs

1177 111

LISTING OF IE INFORMATION NOTICES  
ISSUED IN 1979

Information Notice No.	Subject	Date Issued	Issued To
79-20	NRC Enforcement Policy NRC Licensed Individuals	8/10/79	All Holders of Reactor OLs and CPs and Production Licensees with Licensed Operators
79-21	Transportation and Commercial Burial of Radioactive Material	9/7/79	All power and research reactors with OL's
79-22	Qualification of Control Systems	9/14/79	All power reactor facilities with operating licenses and construction permits.
79-23	Emergency Diesel Generator Lube Oil Coolers	9/26/79	All Power facilities holding OLs and CPs

1177 112