METROPOLITAN EDISON COMPANY SUBSIDIARY OF GENERAL PUBLIC UTILITIES CORPORATION

OFFICE BOX 480 MIDDLETOWN, PENNSYLVANIA 17057 TELEPHONE 717-944-4041

June 17, 1975

POOR ORIGINAL

Mr. J.P. O'Reilly, Director
Directorate of Regulatory
Region I
631 Park Avenue
King of Prussia, Pa. 19406

Operating License DPR-50
Docket 50-289

Subject: Abnormal Occurrence No. AO 75-18

Dear Mr. O'Reilly:

This telegram is to confirm the conversation between Lee Spessard (Region I-NRC), and J.J. Colitz (TMI Unit 1 Superintendent) at 1330 hours 17 June 1975.

The following report is submitted in accordance with paragraph 6.7.2.a.5 (page 6-11) of the technical specifications.

Following motor shaft failure described in AO 75-14, the motor for Decay Heat River Water Pump DR-P-1B was repaired at the vendors repair facility (Westinghouse - Philadelphia). The motor was returned to Three Mile Island, installed in the system and placed in operation without appropriate quality control documentation.

The installation and use of the motor without proper documentation as to repairs actually performed constitutes an inadequacy in the implementation of QA Plan administrative control that could have caused an unsafe condition in the operation of the plant.

The events leading to the violation of the quality control procedures are being investigated and corrective action will be taken to preclude such inadequacies in the future.

Very truly yours,

J.J. Colitz

J.J. Colitz
Unit 1 Superintendent

JJC/dmm

1490 108

7910240 890