

LICENSEE EVENT REPORT

CONTROL BLOCK:

(PLEASE PRINT ALL REQUIRED INFORMATION)

01	LICENSEE NAME P A T M I Z	LICENSE NUMBER 00-00000-00	LICENSE TYPE / / / /	EVENT TYPE 04
01	CONT	REPORT TYPE 7	REPORT SOURCE L	DOCKET NUMBER 050-0289
	CATEGORY 57		EVENT DATE 03/19/77	REPORT DATE 0401/77

EVENT DESCRIPTION

02 During Reactor cooldown conditions the discharge temperature
 03 changed by more than 2°F during any one hour. Previous
 04 occurrences of this type were 74-1, 74-8, 75-7, 75-8, 75-9. The
 05 total river water flow was increased and the primary plant cooldown
 06 rate was decreased to maintain the AT within the limits

07	SYSTEM CODE CF	CAUSE CODE E	COMPONENT CODE ZZZZZZ	PRIME COMPONENT SUPPLIER Z	COMPONENT MANUFACTURER Z999	VIOLATION N
----	-------------------	-----------------	--------------------------	-------------------------------	--------------------------------	----------------

CAUSE DESCRIPTION

08 The valves would not respond to small demand open/close signals.
 09 One MDCT fan would not operate. The fan is scheduled for repair.
 10 The valves shall be inspected & repaired as necessary

11	FACILITY STATUS D	% POWER 000	OTHER STATUS NA	METHOD OF DISCOVERY A	DISCOVERY DESCRIPTION NA
----	----------------------	----------------	--------------------	--------------------------	-----------------------------

12	FORM OF ACTIVITY RELEASED Z	CONTENT OF RELEASE 0	AMOUNT OF ACTIVITY NA	LOCATION OF RELEASE NA
----	--------------------------------	-------------------------	--------------------------	---------------------------

PERSONNEL EXPOSURES

13	NUMBER 000	TYPE Z	DESCRIPTION NA
----	---------------	-----------	-------------------

PERSONNEL INJURIES

14	NUMBER 000	DESCRIPTION NA
----	---------------	-------------------

OFFSITE CONSEQUENCES

15 VA

LOSS OR DAMAGE TO FACILITY

16	TYPE Z	DESCRIPTION NA
----	-----------	-------------------

PUBLICITY

17 Included in regular weekly news release

ADDITIONAL FACTORS

18 1476 351

19

NAME: W. E. Potts PHONE: 929-3601-(ext. 114)