

NRC DISTRIBUTION FOR PART 50 DOCKET MATERIAL

FILE NUMBER

TO:  
Mr. Robert W. Reid

FROM:  
Metropolitan Edison Company  
Reading, Pa.  
R. C. Arnold

DATE OF DOCUMENT  
7/21/76  
DATE RECEIVED  
7/24/76

LETTER  
 ORIGINAL  
 COPY

NOTORIZED  
 UNCLASSIFIED

PROP

INPUT FORM

NUMBER OF COPIES RECEIVED  
one signed  
39 copies encl recvd.

DESCRIPTION

Ltr. re our 2/18/76 ltr..trans the following:

APPENDIX I DISTRIBUTION AFTER ISSUANCE OF A LICENSE

(1-P)

Plant Name:  
Three Mile Island #1

ENCLOSURE

Furnishing responses to questions raised in enclosure 2 of the N.R.C.'s 2/18/76 ltr. to TMI-1 concerning Appendix I.

(27-P)

FOR ACTION/INFORMATION 7/26/76

RJL

ASSIGNED AD:  
BRANCH CHIEF: (3) Reid  
PROJECT MANAGER: Bridges  
LIC. ASST.: Ingram

ASSIGNED AD:  
BRANCH CHIEF:  
PROJECT MANAGER:  
LIC. ASST.:

INTERNAL DISTRIBUTION

<input checked="" type="checkbox"/> RES FILE	SYSTEMS SAFETY	PLANT SYSTEMS	ENVIPO TECH
<input checked="" type="checkbox"/> NRC PDR	HEINEMAN	TEDESCO	ERMST
<input checked="" type="checkbox"/> I & E (2)	SCHROEDER	BEMAROYA	BALLARD
<input checked="" type="checkbox"/> OELD		IAINAS	SPANGLER
<input checked="" type="checkbox"/> COSSICK & STAFF	ENGINEERING	IPPOLITO	
MIPC	MCCARY		SITE TECH
CASE	KNIGHT	OPERATING REACTORS	CASHILL
HANAUER	STWELL	STELLO	STEPP
HARLESS	PAWLICKI		HITMAN
		OPERATING TECH	MARKER
PROJECT MANAGEMENT	REACTOR SAFETY	EISENHUT	SITE ANALYSIS
BOYD	ROSS	SHAO	VOLLNER
P COLLINS	NOVAK	EAER	BUNCH
HOUSTON	ROSZTOCZY	<del>Butler</del>	J. COLLINS (2)
PETERSON	CHECK	GRIMES	KREGER
MELTZ			Verdery
HELTERMES	AT & I	SITE SAFETY & ENVIRO	
SKOVHOLT	SALTZMAN	ANALYSIS	
	RUTBERG	DENTON & MULLER - 44	

EXTERNAL DISTRIBUTION

<input checked="" type="checkbox"/> LPDR:Harrisburg, Pa.	NATL LAB	FROCKHAVEN NATL LAB
<input checked="" type="checkbox"/> TIC	REG. V-1E	ULRIKSON (ORNL)
<input checked="" type="checkbox"/> NSIC	LA PDR	
<input checked="" type="checkbox"/> ASLB	CONSULTANTS	
<input checked="" type="checkbox"/> ACNS 16 HOLDING/SENT : INGRAM		

CONTROL NUMBER

1469 511  
7456



METROPOLITAN EDISON COMPANY

POST OFFICE BOX 542 READING, PENNSYLVANIA 19603

TELEPHONE 215 - 929-3601

July 21, 1976  
GQL 0998



Director of Nuclear Reactor Regulation  
Attn: Robert W. Reid, Chief  
Operating Reactors Branch No. 4  
U. S. Nuclear Regulatory Commission  
Washington, D.C. 20555

Dear Mr. Reid:

Three Mile Island Nuclear Station Unit No. 1  
Docket Number 50-289

Enclosed please find forty (40) copies of our response to Enclosure 2 of your letter of February 18, 1976 concerning Appendix I to 10 CFR Part 50. We have sent under separate cover six (6) copies of a document entitled, "Meteorological Information and Diffusion Estimates to Conform with Appendix I Requirements". This data was used to perform the Appendix I Analyses for both Three Mile Island Units 1 and 2.

It is our opinion that these submittals answer all outstanding questions with respect to Appendix I for Three Mile Island Unit 1.

Sincerely,

R. C. Arnold  
Vice President

RCA:JJM:tas

7458

1469 312

Errata Sheet to responses to questions raised in Enclosure 2  
of the NRC's 2-18-76 letter to TMI-1 concerning Appendix I

The following changes should be made to the above  
referenced document. These errors were inadvertently  
over looked in the initial printing.

Question 2a - typo change "nearest mile cow...." to  
"nearest milk cow...."

Responses to questions 3, 4, 5 and 7 indicate that  
meteorological information is attached. This  
information was sent under separate cover, GQL 0998.

1469 313

RESPONSES TO QUESTIONS RAISED IN ENCLOSURE 2

OF THE NRC'S 2-18-76 LETTER TO TMI-1

CONCERNING APPENDIX I

QUESTION 1

Provide the information requested in Appendix D of Draft Regulatory Guide 1.BB or 1.CC, as appropriate.

RESPONSE

The analysis submitted on 6/4/76 contains the necessary information required by Draft Regulatory Guide 1.BB.

QUESTION 2

Provide, in tabular form, the distances from the centerline of the first nuclear unit to the following for each of the 22-1/2 degree radial sectors centered on the 16 cardinal compass directions.

- a. Nearest milk cow (to a distance of 5 miles)
- b. Nearest meat animal (to a distance of 5 miles)
- c. Nearest milk goat (to a distance of 5 miles)
- d. Nearest residence (to a distance of 5 miles)
- e. Nearest vegetable garden greater than 500 ft<sup>2</sup> (to a distance of 5 miles)
- f. Nearest site boundary.

For radioactivity releases from stacks which qualify as elevated releases as defined in Draft Regulatory Guide 1.DD, identify the locations of all milk cows, milk goats, meat animals, residences, and vegetable gardens, in a similar manner, out to a distance of 3 miles for each radial sector.

RESPONSE

See attached Table 2-1.

QUESTION 3

Based on considerations in Draft Regulatory Guide 1.DD, provide estimates of relative concentration (X/Q) and deposition (D/Q) at locations specified in response to item 2 above for each release point specified in response to item 1 above.

RESPONSE

See Tables 1.3-11A to 1.3-14B of attached Meteorological Information for Three Mile Island Units 1 & 2.

1469 14



QUESTION 4

Provide a detailed description of the meteorological data, models and parameters used to determine the X/Q and D/Q values. Include information concerning the validity and accuracy of the models and assumptions for your site and the representativeness of the meteorological data used.

RESPONSE

See Sections 1.1, 1.1.1, 1.1.2, 1.1.3, 1.1.4, 1.2.1, 1.2.2, 1.2.3, 1.3, 1.32 & 1.3.3 and Tables 1.1-1, 1.1-4, 1.3-2, 1.3-3, 1.3-4 and 1.3-5 of attached Meteorological Information for Three Mile Island Units 1 & 2.

QUESTION 5

If an onsite program commensurate with the recommendations and intent of Regulatory Guide 1.23 exists:

- a. Provide representative annual and monthly, if available, joint frequency distributions of wind speed and direction by atmospheric stability class covering at least the most recent one year period of record, preferably two or more years of record. Wind speed and direction should be measured at levels applicable to release point elevations and stability should be determined from the vertical temperature gradient between measurement levels that represent conditions into which the effluent is released.
- b. Describe the representativeness of the available data with respect to expected long-term conditions at the site.

RESPONSE

- a. See Tables 1.1-2 and 1.1-3 of attached Meteorological Information for Three Mile Island Units 1 & 2.
- b. See Section 1.1-4 of attached Meteorological Information for Three Mile Island Units 1 & 2.

QUESTION 6

If recent onsite meteorological data are not available, or if the meteorological measurements program does not meet the recommendations and intent of Regulatory Guide 1.23:

- a. Provide the best available meteorological data in the format described in item 5,a above.
- b. Describe the representativeness of the available data with respect to onsite and near site atmospheric transport and diffusion conditions, and with respect to expected long term conditions at and near the site.

QUESTION 6 (Cont'd.)

- c. Provide a description of the meteorological measurements used for collection of the data presented. This description should include the location of the sensors with respect to the power plant(s) and other prominent topographic features (including buildings) and accuracy of the instrumentation.
- d. Provide a commitment to establish a program to meet the recommendations and intent of Regulatory Guide 1.23, or provide sufficient justification to allow the present program to remain unchanged.

RESPONSE

Since acceptable onsite meteorological data is available for Three Mile Island Unit 1, the Applicant will not respond to this question.

QUESTION 7

Describe airflow trajectory regimes of importance in transporting effluents to the locations for which dose calculations are made.

RESPONSE

See Sections 1.1.5, 1.2.2 and 1.2.3 of attached Meteorological Information for Three Mile Island Units 1 & 2.

QUESTION 8

Provide a map showing the detailed topographical features (as modified by the plant) on a large scale, within a 10-mile radius of the plant and a plot of the maximum topographic elevation versus distance from the center of the plant in each of the sixteen 22-1/2 degree cardinal compass point sectors (centered on true north), radiating from the center of the plant, to a distance of 10 miles.

RESPONSE

See attached Table 8-1 and Figures 8-1 through 8-16.

1469 316

QUESTION 9

Provide the dates and times of radioactivity releases from intermittent sources by source location based on actual plant operation and, if available, appropriate hourly meteorological data (i.e., wind direction and speed, and atmospheric stability) during each period of release.

RESPONSE

Since it is our understanding that the first full year of effluent release data is not considered representative, we are enclosing copies of the effluent release data contained in the Semi-Annual Reports for 1975 at Three Mile Island Unit 1.

1469 317

TABLE 2-1

THREE MILE ISLAND NUCLEAR GENERATING STATION

<u>Sector</u>	<u>Milk</u>		<u>Meat Animal</u>	<u>Residence</u>	<u>Vegetable Garden</u>	<u>Site Boundary</u>
	<u>Cow</u>	<u>Goat</u>				
1. N	2.00	1.02	1.02	.94	1.0	1,248
2. NNE	2.34	2.34	1.8	.73	.73	1,690
3. NE	2.28	3.20	1.5	.53	.53	1,300
4. ENE	1.05	-	1.05	.45	.45	1,105
5. E	1.0	-	.81	.43	.81	1,072
6. ESE	2.33	-	2.2	1.32	1.32	1,105
7. SE	1.2	4.62	1.0	.79	.79	1,241
8. SSE	-	-	1.8	.79	.79	1,690
9. S	-	-	3.2	2.26	2.26	1,690
10. SSW	4.86	4.91	2.7	.58	.58	1,040
11. SW	-	-	2.5	.54	.54	715
12. WSW	4.03	4.40	3.3	.45	.45	585
13. W	-	-	2.8	.37	.37	585
14. WNW	2.68	3.23	2.0	.37	.37	585
15. NW	-	-	2.5	.42	.42	650
16. NNW	-	-	4.2	.41	.41	715

NOTE: All the above figures are in miles, except for site boundary, which is in feet.

1469 318

MAXIMUM TOPOGRAPHIC ELEVATIONS FOR

THREE MILE ISLAND UNITS 1 & 2


TABLE 8-1

Sector	D I S T A N C E I N M I L E S									
	1	2	3	4	5	6	7	8	9	10
N	330	520	420	420	500	540	500	540	500	540
NNE	340	520	520	520	900	900	760	820	700	420
NE	360	500	540	560	760	760	820	760	540	660
ENE	360	420	480	440	440	560	520	500	560	550
E	360	400	440	560	640	640	600	580	620	620
ESE	380	460	540	560	640	640	640	540	460	450
SE	400	480	520	500	500	480	420	480	680	940
SSZ	380	500	480	380	440	540	580	660	700	1020
S	300	280	515	580	440	480	500	715	725	560
SSW	300	300	500	535	460	680	760	760	560	540
SW	300	460	545	760	645	740	1040	920	1040	1100
WSW	300	520	560	720	790	660	785	785	1000	1100
W	300	520	500	500	760	850	980	1050	840	940
WNW	300	480	615	830	965	880	825	1040	940	600
NW	300	480	600	700	680	590	550	510	515	490
NNW	300	505	320	360	540	580	590	620	520	520

1469 519

FIGURE 8-1

THREE MILE ISLAND UNITS 1 & 2



1469 520



FIGURE 8-2  
THREE MILE ISLAND UNITS 1 & 2




FIGURE 8-3  
THREE MILE ISLAND UNITS 1 & 2





FIGURE 8-4

THREE MILE ISLAND UNITS 1 & 2



1469 23



FIGURE 8-5

THREE MILE ISLAND UNITS 1 & 2




FIGURE 8-6

THREE MILE ISLAND UNITS 1 & 2

Sector: East-Southeast




FIGURE 8-7

THREE MILE ISLAND UNITS 1 & 2






FIGURE 8-8

THREE MILE ISLAND UNITS 1 & 2

Sector: South-Southeast




FIGURE 8-9  
THREE MILE ISLAND UNITS 1 & 2




FIGURE 8-10

THREE MILE ISLAND UNITS 1 & 2

Sector: South-Southwest






FIGURE 8-11

TREE MILE ISLAND UNITS 1 & 2






FIGURE 8-12  
THREE MILE ISLAND UNITS 1 & 2



1469.331

FIGURE 8-13

THREE MILE ISLAND UNITS 1 & 2



1469 532



FIGURE 8-14

THREE MILE ISLAND UNITS 1 & 2




FIGURE 8-15

THREE MILE ISLAND UNITS 1 & 2



FIGURE 8-16  
THREE MILE ISLAND UNITS 1 & 2





TMI Nuclear Station Unit #1  
 Year 1975

REPORTS OF RADIOACTIVE EFFLUENTS  
 (Table 6.1)

I. LIQUID RELEASES	UNIT	MONTH						TOTAL
		JULY	AUGUST	SEPTEMBER	OCTOBER	NOVEMBER	DECEMBER	
1. GROSS RADIOACTIVITY - ( $\beta, \gamma$ ) (Includes Dissolved Noble Gases)								
a. Total Release	Curies	5.89E-02	1.90E-01	2.29E-01	1.49E-01	1.83E-01	2.03E-01	1.01E+00
b. Average Concentration Released	$\mu\text{Ci/ml}$	2.31E-08	1.06E-07	5.47E-08	3.50E-08	4.29E-08	1.99E-07	5.58E-08
c. Maximum Concentration Released	$\mu\text{Ci/ml}$	6.65E-07	2.27E-07	3.27E-07	2.12E-07	1.21E-06	2.44E-07	1.21E-06
2. TRITIUM - (Determined from measurement of each batch)								
a. Total Release	Curies	2.25E+01	6.70E+01	4.28E+01	4.56E+01	1.54E+01	2.03E+01	2.14E+02
b. Average Concentration Released	$\mu\text{Ci/ml}$	8.82E-06	3.76E-05	1.02E-05	1.07E-05	3.61E-06	1.99E-05	1.18E-05
3. DISSOLVED NOBLE GASES - (Determined from measurement of each batch)								
a. Total Release	Curies	4.18E-02	1.85E-01	2.25E-01	1.41E-01	1.75E-01	1.94E-01	9.62E-01
b. Average Concentration Released	$\mu\text{Ci/ml}$	1.64E-08	1.04E-07	5.37E-08	3.32E-08	4.09E-08	1.90E-07	5.31E-08
4. GROSS ALPHA RADIOACTIVITY - (Determined from measurement of monthly composite of all tanks)								
a. Total Release	Curies	< MDA	< MDA	< MDA	< MDA	< MDA	< MDA	< MDA
b. Average Concentration Released	$\mu\text{Ci/ml}$	< MDA	< MDA	< MDA	< MDA	< MDA	< MDA	< MDA
5. VOLUME OF LIQUID WASTE TO DISCHARGE CANAL								
	Liters	2.24E+05	6.31E+05	4.37E+05	8.08E+05	5.16E+05	6.68E+05	3.28E+06
6. VOLUME OF DILUTION WATER								
	Liters	2.55E+09	1.78E+09	4.19E+09	4.25E+09	4.27E+09	1.02E+09	1.81E+10

- 37 -

1469 356

TMI Nuclear Station Unit #1  
 Year 1975

REPORTS OF RADIOACTIVE EFFLUENTS  
 (Table 6.1)

I. LIQUID RELEASES	UNIT	MONTH						TOTAL
		JULY	AUGUST	SEPTEMBER	OCTOBER	NOVEMBER	DECEMBER	
7. ISOTOPES RELEASED - (Determined from measurement of each batch released except Sr-89 & Sr-90 which are determined from measurement of monthly composite of all tanks)								
Ba-La-140	Curies	< MDA	< MDA	< MDA	< MDA	< MDA	< MDA	< MDA
Sr-89	Curies	< MDA	2.09E-05	2.89E-06	6.35E-06	< MDA	3.66E-04	3.96E-06
Na-24	Curies	< MDA	< MDA	< MDA	< MDA	< MDA	< MDA	< MDA
Sr-90	Curies	< MDA	3.90E-06	< MDA	< MDA	< MDA	1.09E-04	1.13E-04
I-131	Curies	2.49E-04	1.33E-04	3.58E-04	1.04E-03	8.43E-04	1.00E-03	3.62E-03
Xe-133	Curies	3.97E-02	1.80E-01	2.10E-01	1.38E-01	1.73E-01	1.87E-01	9.28E-01
Xe-135	Curies	4.72E-04	3.48E-03	1.25E-02	1.45E-03	1.03E-03	4.81E-03	2.37E-02
Cs-137	Curies	2.51E-05	1.23E-04	2.99E-04	1.03E-03	6.11E-04	8.24E-04	2.91E-03
Cs-134	Curies	< MDA	< MDA	< MDA	1.84E-04	< MDA	1.10E-04	2.94E-04
Mo-99	Curies	< MDA	< MDA	< MDA	< MDA	< MDA	< MDA	< MDA
Co-60	Curies	2.37E-04	7.96E-05	1.00E-04	2.77E-04	2.43E-03	4.85E-04	3.61E-03
Co-58	Curies	1.63E-02	3.38E-03	3.49E-03	5.01E-03	4.24E-03	6.14E-03	3.86E-02
Zr-97	Curies	< MDA	< MDA	< MDA	< MDA	< MDA	< MDA	< MDA
Cr-51	Curies	< MDA	6.67E-04	< MDA	1.93E-04	1.06E-04	1.02E-04	1.07E-03
Mn-54	Curies	1.25E-04	8.67E-05	1.30E-04	2.25E-04	1.53E-04	3.47E-04	1.07E-03
Zn-65	Curies	< MDA	< MDA	< MDA	< MDA	< MDA	< MDA	< MDA
Cs-136	Curies	< MDA	< MDA	< MDA	< MDA	< MDA	< MDA	< MDA
Fe-59	Curies	1.91E-04	1.07E-04	3.84E-05	2.93E-05	< MDA	6.37E-05	4.29E-06
Zr-95	Curies	< MDA	< MDA	< MDA	< MDA	< MDA	1.52E-04	1.52E-04
Nb-95	Curies	< MDA	2.49E-06	< MDA	2.44E-05	4.74E-05	3.09E-04	3.83E-04
Xe-133m	Curies	3.70E-04	1.77E-03	2.58E-03	1.15E-03	7.82E-04	1.85E-03	8.50E-03
Kr-85	Curies	1.22E-03	< MDA	< MDA	< MDA	< MDA	< MDA	1.22E-03
8. PERCENT OF TECHNICAL SPECIFICATION LIMIT FOR TOTAL ACTIVITY RELEASED - (Exclude H-3 & Dissolved Noble Gases: Limit 10 Ci/QTR)								
	%	1.7E-01	5.0E-02	4.0E-02	8.0E-02	8.0E-02	9.0E-02	5.8E-01

- 38 -

1469 537

TMI Nuclear Station Unit #1  
Year 1975

REPORTS OF RADIOACTIVE EFFLUENTS  
(Table 6.1)

II. AIRBORNE RELEASES	UNIT	MONTH						TOTAL
		JULY	AUGUST	SEPTEMBER	OCTOBER	NOVEMBER	DECEMBER	
1. TOTAL NOBLE GASES	Curies	2.10E+02	2.60E+02	3.77E+02	2.50E+02	5.88E+02	8.27E+02	2.51E+03
2. TOTAL HALOGENS	Curies	2.14E-05	2.39E-10	< MDA	4.34E-05	9.97E-05	2.02E-04	3.67E-04
3. TOTAL PARTICULATE, GROSS RADIOACTIVITY ( $\beta, \gamma$ )	Curies	1.71E-10	4.01E-09	1.61E-07	8.03E-05	1.19E-05	< MDA	9.22E-05
4. TOTAL TRITIUM	Curies	3.98E+00	5.53E+00	8.34E+00	1.13E+00	1.63E+00	1.12E+00	2.17E+01
5. TOTAL PARTICULATE GROSS ALPHA RADIOACTIVITY	Curies	< MDA	< MDA	< MDA	< MDA	< MDA	< MDA	< MDA
6. MAXIMUM NOBLE GAS RELEASE RATE	$\mu\text{Ci}/\text{sec}$	7.92E+03	1.60E+04	1.50E+04	7.85E+03	1.24E+04	4.68E+05	4.68E+05
7a. PERCENT OF APPLICABLE LIMIT FOR: Noble Gases (Limit: $\text{EQ}_1/\text{MPC}_1 - 4.8 \times 10^3 \text{ m}^3/\text{sec}$ avg over QTR)	%	2.10E+00	2.67E+00	4.74E+00	4.29E+00	5.45E+00	9.46E+00	N/A
7b. PERCENT OF APPLICABLE LIMIT FOR: Halogens & Particulates (Limit: 0.024 $\mu\text{Ci}/\text{sec}$ avg. over QTR)	%	1.14E-02	2.25E-05	6.62E-02	5.98E-02	1.47E-03	1.06E-01	N/A
8a. ISOTOPE RELEASED: Particulates								
Cs-137	Curies	< MDA	< MDA	< MDA	< MDA	< MDA	< MDA	< MDA
Ba-140	Curies	< MDA	< MDA	< MDA	< MDA	< MDA	< MDA	< MDA
Sr-90 - (Determined from monthly composite)	Curies	9.78E-12	< MDA	< MDA	< MDA	< MDA	< MDA	9.78E-12
Cs-134	Curies	< MDA	< MDA	< MDA	< MDA	< MDA	< MDA	< MDA
Sr-89 - (Determined from monthly composite)	Curies	< MDA	< MDA	1.61E-07	< MDA	< MDA	< MDA	1.61E-07

- 39 -

1469 538



TMI Nuclear Station Unit #1  
Year 1975

REPORTS OF RADIOACTIVE EFFLUENTS  
(Table 6.1)

II. AIRBORNE RELEASES	UNIT	MONTH						TOTAL
		JULY	AUGUST	SEPTEMBER	OCTOBER	NOVEMBER	DECEMBER	
Co-60	Curies	< MDA	1.40E-09	< MDA	< MDA	< MDA	< MDA	1.40E-09
Co-58	Curies	1.61E-10	4.99E-10	< MDA	8.03E-05	1.19E-05	< MDA	9.22E-05
Cr-51	Curies	< MDA	1.64E-09	< MDA	< MDA	< MDA	< MDA	1.64E-09
Mn-54	Curies	< MDA	4.67E-10	< MDA	< MDA	< MDA	< MDA	4.67E-10
8b. ISOTOPE RELEASED:								
Halogens								
I-131	Curies	2.14E-05	2.39E-10	< MDA	4.34E-05	9.97E-05	2.02E-04	3.66E-04
I-132	Curies	< MDA	< MDA	< MDA	< MDA	< MDA	< MDA	< MDA
I-133	Curies	< MDA	< MDA	< MDA	< MDA	< MDA	< MDA	< MDA
I-135	Curies	< MDA	< MDA	< MDA	< MDA	< MDA	< MDA	< MDA
8c. ISOTOPE RELEASED:								
Gases								
Kr-85	Curies	< MDA	3.64E-02	< MDA	< MDA	1.62E-01	8.75E-02	2.86E-01
Kr-85m	Curies	< MDA	4.54E-01	6.30E-01	3.31E-01	4.29E-01	2.46E-01	2.09E+00
Kr-87	Curies	< MDA	< MDA	2.11E-02	< MDA	2.52E-02	< MDA	4.63E-02
Kr-88	Curies	< MDA	< MDA	2.22E-01	1.25E-01	1.34E-01	2.48E-02	5.06E-01
Xe-131m	Curies	< MDA	1.53E-02	5.39E-02	2.33E-01	5.93E-02	2.81E-01	6.42E-01
Xe-133	Curies	1.99E+02	2.38E+02	3.24E+02	1.95E+02	5.78E+02	7.30E+02	2.26E+03
Xe-133m	Curies	2.92E+00	1.74E+00	< MDA	9.26E-01	1.44E+00	2.18E+00	9.21E+00
Xe-135	Curies	6.49E+00	1.85E+01	4.37E+01	2.59E+01	6.57E+00	8.48E+01	1.86E+02
Xe-135m	Curies	< MDA	< MDA	1.75E+00	< MDA	< MDA	< MDA	1.75E+00
Xe-138	Curies	< MDA	< MDA	< MDA	< MDA	< MDA	< MDA	< MDA
Ar-41	Curies	1.38E+00	1.01E+00	6.99E+00	2.71E+01	9.90E-01	9.50E+00	4.70E+01

40

1469 539