A081 2/78

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)
DISTRIBUTION FOR INCOMING MATERIAL 50-289

REC: MADONALD W G
NRC

ORG: HERBEIN J G
METROPOL EDISON

DOCDATE: 08/15/78
DATE RCVD: 08/22/78

DOCTYPE: LETTER NOTARIZED: NO
SUBJECT:
FORWARDING SUBJECT FACILITY"S MONTHLY OPERATING REPT FOR THE MONTH OF JULY, 1978.

COPIES RECEIVED
LTR 1 ENCL 1

PLANT NAME: THREE MILE ISLAND -- UNIT 1

REVIEWER INITIAL: XJM
DISTRIBUTOR INITIAL:

********** DISTRIBUTION OF THIS MATERIAL IS AS FOLLOWS **********

ANNUAL, SEMI-ANNUAL & MONTHLY OPERATING RPTS (OL STAGE)
(DISTRIBUTION CODE A008)

FOR ACTION: BR CHIEF ORB#4 BC**W/6 ENCL

INTERNAL:
REG FILE**W/ENCL
I & E**W/2 ENCL
HANAUER**W/ENCL
AD FOR SYS & PROJ**W/ENCL
REACTOR SAFETY BR**W/ENCL
EEB**W/ENCL
EFFLUENT TREAT SYS**W/ENCL
NRC PDR**W/ENCL
MIPC**W/2 ENCL
DIRECTOR DOR**W/ENCL
ENGINEERING BR**W/ENCL
PLANT SYSTEMS BR**W/ENCL
CORE PERFORMANCE BR**W/ENCL

EXTERNAL:
LPDR'S
HARRISBURG, PA**W/ENCL
NATL LAB ANL**W/ENCL
TERA**W/ENCL
NSIC**W/ENCL
ACRS CAT B**W/15 ENCL

1589 051

DISTRIBUTION: LTR 41 ENCL 41
SIZE: 1P+4P

CONTROL NBR: 782160207

********** THE END **********

7910810674

METROPOLITAN EDISON COMPANY SUBSIDIARY OF GENERAL PUBLIC UTILITIES CORPORATION

POST OFFICE BOX 542 READING, PENNSYLVANIA 19603 TELEPHONE 215 – 929-3601

August 15, 1978
GQL 1353

Office of Management Information & Program Control
Attn: W. G. McDonald
c/o Distribution Services Branch DPC, ADM
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Dear Sir:

Three Mile Island Nuclear Station Unit 1 (TMI-1)
Operating License No. DPR-50
Docket No. 50-289

Enclosed please find two (2) copies of the July Operating Report for Three Mile Island Nuclear Station, Unit 1.

Sincerely,

J. G. Herbein
Vice President-Generation

JGH:DGM:dkf

Enclosures

cc: Mr. B. E. Grier, Director
Office of Inspection and Enforcement
U. S. Nuclear Regulatory Commission
631 Park Avenue
King of Prussia, PA 19406

Mr. Ernst Volgenau, Director
Office of Inspection and Enforcement
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Ted Cintula (2 copies)
12105 MNBB, U. S. Nuclear Regulatory Commission
Washington, D. C. 20555
(To be opened by Addressee Only)

1587 052

7808160207

A008
S.1/1

TMI-I OPERATING SUMMARY

JULY 1978

The Unit operated at essentially 100% full power the entire month except for the following planned reductions.

On July 3rd and 4th, the Unit reduced power to 90% due to a reduced system load requirement. These reductions lasted approximately 4.5 hours and 2.75 hours respectively, after which the Unit escalated back to 100% full power.

On July 19, 1978, the Unit reduced power to 95% to perform Physics testing (Reactivity Coefficients). This planned reduction lasted 0.75 hours.

MAINTENANCE SUMMARY

The casing vent line on makeup pump (MU-P-1A) required repairs because of a fitting leak. MU-P-1A was taken out of service after the other make up pumps were aligned for normal operation. The following work was performed:

1. Vent line removed
2. Repair vent line
3. Installed vent line
4. MU-P-1A tested

After the MU-P-1A was tested satisfactorily, the pump was returned to service.

1589 053