

JUL 2 1974

DISTRIBUTION:
AEC PDR
Local PDR
Docket
LWR 2-3 Rdg
VAMoore
DEisenhut
RWKlecker
RMBernero
EIGoulbourne (2)
ACRS (16)
1 extra cpy

Docket No. 50-289

Metropolitan Edison Company
ATTN: Mr. Robert C. Arnold
Vice President
P. C. Box 542
Reading, Pennsylvania 19603

Gentlemen:

Amendments to the Commission's regulations (10 CFR 50.59) which relates to the manner in which proposed changes in the technical specifications for facility operating licenses are to be requested and acted upon, became effective on April 22, 1974. The purpose of this letter is to call this to your attention and point out that all requests for technical specification changes to facilities with operating licenses must be submitted in the form of an application for a license amendment in accordance with the applicable provisions of Parts 2 and 50 of 10 CFR Chapter I.

Note that Section 50.30(b) of 10 CFR Part 50 requires that applications be executed in three signed originals by the applicant or duly authorized officer thereof under oath or affirmation. In addition to the three signed originals, 37 conformed copies of all portions of those applications requesting technical specification changes for power and test facilities, and 19 conformed copies of all portions of those for research and critical facilities should be filed.

Sincerely,

Original Signed by

D. Eisenhut
Voss A. Moore, Assistant Director
for Light Water Reactors, Group 2
Directorate of Licensing

ccs: See next page

1587 160

APPL

OFFICE	LWR 2-3	LWR 2-3	L: LWR 2-3	L: AD LWRs 2	
SURNAME	EIGoulbourne	kmf RMBernero	ASchwencer	VAMoore	Rg
DATE	7/1/74	7/1/74	7/1/74	7/1/74	

7911040/13 P

ccs: GPU Service Corporation
Richard W. Heward, Project Manager
Thomas M. Crimmins, Jr., Safety
and Licensing Manager
260 Cherry Hill Road
Parsippany, New Jersey 07054

Pennsylvania Electric Company
Vice President, Technical
1001 Broad Street
Johnstown, Pennsylvania 15907

George F. Trowbridge, Esquire
Shaw, Pittman, Potts & Trowbridge
910 - 17th Street, N. W.
Washington, D. C. 20006

Mr. Weldon B. Arehart, Chairman
Board of Supervisors of Londonberry
Township
2148 Foxiana Road
Middletown, Pennsylvania 17057

Mr. Charles P. Hoy, Chairman
Board of County Commissioners of
Dauphin County
Dauphin County Courthouse
P. O. Box 1296
Harrisburg, Pennsylvania 17018

Miss Mary V. Southhard, Chairman
Citizens for a Safe Environment
P. O. Box 405
Harrisburg, Pennsylvania 17108

1587 161

OFFICE ➔					
SURNAME ➔					
DATE ➔					

Robert C. Arnold

- 2 -


JUN 6 1974

cc: George F. Trowbridge, Esquire
Shaw, Pittman, Potts & Trowbridge
910 17th Street, NW
Washington, D. C. 20006

1587 162

OFFICE ➤						
SURNAME ➤						
DATE ➤						

FDK



METROPOLITAN EDISON COMPANY A SUBSIDIARY OF GENERAL PUBLIC UTILITIES CORPORATION

1ST OFFICE BOX 542 READING, PENNSYLVANIA 19603

TELEPHONE 215 - 929-3601

MAY 17 1974

Dr. D. F. Knuth, Director
Directorate of Regulatory Operations
United States Atomic Energy Commission
Washington, D. C. 20545

Subject: Three Mile Island Nuclear Station Unit 1
Docket No. 50-289
License No. DPR-50
Inspection of Reactor Internals After Hot Functional Testing

Dear Dr. Knuth:

The inspections and investigations reported in Mr. J. G. Miller's letter of April 26, 1974, to Dr. D. F. Knuth have been completed.

A detailed inspection of the entire reactor internals package, reactor vessel, and closure head by Quality Control indicated that no damage was caused by the nut and that the nut was not part of the reactor components.

The reactor coolant system and associated systems were reviewed by GPU Service Corporation. It is concluded that the nut was of foreign origin and was not a part of these systems or the components of these systems (i.e., valves, pumps, motors).

An AEC-DRO Inspector examined the "Addendum to Inspection Record B-9, IFI-115", dated May 2, 1974, which documented the results of the reactor internals foreign material investigation and considers this item resolved per Inspection No. 50-289/74-22 dated May 8, 1974.

Very truly yours,

R. C. Arnold
Vice President-Generation

brh
CC: J. P. O'Reilly

DUPE 1587 163
7910260654