AEC DISTRIBUTION FOR PART 50 DOCKET MATERIAL
(TEMPORARY FORM)

CONTROL NO: 7658

FILE:

FROM:	DATE OF DOC	DATE REC'D	LTR	MEMO	RPT	OTHER
Metropolitan Edison Company Reading, Pennsylvania 19603 J. G. Miller	10-16-73	10-18-73	X			

TO:	ORIG	CC	OTHER	SENT AEC PDR	SENT LOCAL PDR
Mr. DeYoung	1 signed			X	X

CLASS	UNCLASS	PROP INFO	INPUT	NO CYS REC'D	DOCKET NO:
	XXX			1	50-289

DESCRIPTION:
Ltr re AEC/DRL ltr dtd 9-18-73....advising AEC of their intent to resize the engineered safeguard motor operated valve overload heaters to activate at 300 % of full load current.....

ENCLOSURES:

POOR ORIGINAL

Do Not Remove

PLANT NAME: Three Mile Island Unit # 1

FOR ACTION/INFORMATION 10-19-73 AB

BUTLER(L)	SCHWENCER(L)	ZIEMANN(L)	REGAN(E)
W/ Copies	W/2 Copies	W/ Copies	W/ Copies
CLARK(L)	STOLZ(L)	DICKER(E)	
W/ Copies	W/ Copies	W/ Copies	W/ Copies
GOLLER(L)	VASSALLO(L)	KNIGHTON(E)	
W/ Copies	W/ Copies	W/ Copies	W/ Copies
KNIEL(L)	SCHEMEL(L)	YOUNGBLOOD(E)	
W/ Copies	W/ Copies	W/ Copies	W/ Copies

INTERNAL DISTRIBUTION

REG FILE	TECH REVIEW	DENTON		A/T IND
AEC PDR	HENDRIE	GRIMES	LIC ASST	BRAITMAN
OGC, ROOM P-506A	SCHROEDER	GAMMILL	DIGGS (L)	SALTZMAN
MUNTZING/STAFF	MACCARY	KASTNER	GEARIN (L)	
CASE	KNIGHT	BALLARD	GOULBOURNE (L)	PLANS
GIAMBUSSO	PAWLICKI	SPANGLER	LEE (L)	MCDONALD
BOYD	SHAO		MAIGRET (L)	DUBE
MOORE (L)(BWR)	STELLO	ENVIRO	SERVICE (L)	
DEYOUNG(L)(PWR)	HOUSTON	MULLER	SHEPPARD (E)	INFO
SKOVHOLT (L)	NOVAK	DICKER	SMITH (L)	C. MILES
P. COLLINS	ROSS	KNIGHTON	TEETS (L)	
	IPPOLITO	YOUNGBLOOD	WADE (E)	
REG OPR	TEDESCO	REGAN	WILLIAMS (E)	
FILE & REGION(3)	LONG	PROJECT LDR	WILSON (L)	
MORRIS	LAINAS			
STEELE	BENAROYA	HARLESS		
	VOLLMER			

1584 311

EXTERNAL DISTRIBUTION

1 - LOCAL PDR Harrisburg, Pa.		
1 - DTIE(ABERNATHY)	(1)(2)(10)-NATIONAL LAB'S	1-PDR-SAN/LA/NY
1 - NSIC(BUCHANAN)	1-R.Schoonmaker,CG,GT,D-223	1-GERALD LELLOUCHE
1 - ASLB(YORE/SAYRE/	1-W. PENNINGTON, Rm E-201 GT	BROOKHAVEN NAT. LAB
WOODARD/"H" ST.	1-CONSULTANT'S	1-ACRED(WALTER KOESTER
16 - CYS ACRS HOLDING	NEWMARK/BLUME/AGBABIAN	RM-C-427-GT
	1-GERALD ULRIKSON...ORNL	1-RD..MULLER..F-309 GT

7911070 697 A

Regulatory File Cy

METROPOLITAN EDISON COMPANY

POST OFFICE BOX 542 READING, PENNSYLVANIA 19603 TELEPHONE 215 – 929-3601

October 16, 1973

Mr. R. C. DeYoung, Assistant Director
for Pressurized Water Reactors
Directorate of Licensing
Office of Regulation
U.S. Atomic Energy Commission
Washington, DC 20545

SUBJECT: THREE MILE ISLAND NUCLEAR STATION
DOCKET NO. 50-289
480 VOLT MOTOR CONTROL CENTER
THERMAL OVERLOAD HEATERS

REF: AEC/DRL Letter Dated 9/18/73

Dear Mr. DeYoung:

The referenced AEC/DRL letter directed Metropolitan Edison Company to use the criteria for selecting thermal overload heaters as 300% of the full load current for safety related motor operated valves.

As requested in the referenced letter, we are notifying you of our intended course of action. We are proceeding to resize the engineered safeguard motor operated valve overload heaters to activate at 300% of full load current for the operating time of the valve.

It is our intent to have completed this change by initial fuel load.

Very truly yours,

J. G. Miller
Vice President

asb

cc: Mr. H. M. Dieckamp
Mr. W. A. Verrochi