METROPOLITAN EDISON COMPANY

POST OFFICE BOX 542 READING, PENNSYLVANIA 19603

TELEPHONE 215 - 929-3601

Ro Bill to 12 1

September 10, 1973



Mr. James P. O'Reilly, Director Directorate of Regulatory Operations Region 1 United States Atomic Energy Commission 631 Park Avenue King of Prussia, Pa. 19406

> SUBJECT: THREE MILE ISLAND NUCLEAR STATION UNITS 1 & 2 DOCKET NO. 50-289 AND 50-320


Dear Mr. O'Reilly:

This letter is in response to the Commission's letter of July 18, 1973 which requested that we review the design of the control circuits for the Containment Ventilation System isolation valves installed at Three Mile Island Nuclear Station Units No. 1 and 2. This review has determined that no single failure of one containment isolation valve nor its control circuit would result in the simultaneous failure of the redundant isolation valve. We submit the following information in response to the July 18, 1973 letter.

The closure of the containment supply and exhaust purge valves is actuated from separate Engineered Safeguards actuation channels, from a separate control switch for each valve and from a radiation monitoring channel. Our review of the electrical drawings of Unit 1 established that all circuits are electrically isolated. Thus, in the event of a single failure, isolation of the containment ventilation system will be accomplished by the redundant valve.

The design of these circuits for Unit 2 has not been completed. As a result of the Commission's letter and the findings on Unit 1, explicit instructions are being forwarded to the designers insuring that electrical isolation and physical separation will be incorporated in the completed design.

1584 051



Mr. James P. O'Reilly, Director Directorate of Regulatory Operations

Therefore, the containment integrity will be maintained by the redundant value in the event of a single failure in either Unit 1 or Unit 2.

Very truly yours,

J. G. Miller Vice President

1

CC: Mr. W. A. Verrochi

kd

..

.