



UNITED STATES
ATOMIC ENERGY COMMISSION
DIRECTORATE OF REGULATORY OPERATIONS
REGION 1
970 BROAD STREET
NEWARK, NEW JERSEY 07102

July 31, 1972

J. B. Henderson, Chief, Reactor Construction Branch
Regulatory Operations, HQ

METROPOLITAN EDISON COMPANY
THREE MILE ISLAND UNITS 1 AND 2
RO REPORT NO. 50-289/72-11, 50-320/72-03

The subject inspection report is forwarded for information.

The inspector verified that no damage to safety related equipment on site was caused by the flood.

Slides were previously provided to RO:HQ of the flood crest in the plant area. A copy of these slides was also provided to the licensee.

Subsequent inspection verified minimal damage to installed and stored equipment on site.

Directorate of Licensing personnel have subsequently been at the site to review any required modifications in the design basis for flood protection.

for E. M. Howard
E. M. Howard, Chief
Reactor Construction Branch

Enclosure:
Subject Inspection Report

cc: R. Minogue, RS (3)
R. S. Boyd, RL (2)
R. C. DeYoung, RL (2)
D. J. Skovholt, RL (3)
H. R. Denton, RL (2)
P. A. Morris, RO
R. H. Engelken, RO
H. Thornburg, RO
J. G. Keppler, RO
RO Files
~~DR~~ Central Files

1566 226

7911110012

Q