

## ATOMIC ENERGY COMMISSION DIVISION OF COMPLIANCE REGION I

970 BROAD STREET

NEWARK. NEW JERSET 07102

201 645-3942

July 30, 1971

J. B. Henderson, Chief, Reactor Construction Branch, Division of Compliance, HQ

METROPOLITAN EDISON CCMPANY THREE MILE ISLAND UNITS 1 AND 2 DOCKET NOS. 50-289 and 50-320

The enclosed report of inspection of the Metropolitan Edison Company's Three Mile Island 1 and 2 construction site, performed by J. H. Tillou, A. V. J. Burzi, and D. M. Hunnicutt, on June 24-25, 1971, is forwarded for information.

This licensee's continuing efforts to reinforce and amplify the site QA/QC surveillance activities are reassuring, although the efforts have been somewhat less than an unqualified success.

We have concerns regarding the continuing series of concrete problems which indicate repeated failure of the site personnel to implement the details of concrete placement procedures.

The work stoppage by the operating engineers was settled on July 9, 1971, so activity on site should gradually accelerate back to normal.

E. M. Howard

Senior Reactor Inspector

Enclosure:

CO Report No. 71-03, by J. Tillou, A. V. J. Burzi & D. Hunnicutt, dated 7/29/71

cc: E. G. Case, DRS (3)

P. A. Morris, DRL

R. S. Boyd, DRL (2)

R. C. DeYoung, DRL (2)

D. J. Skovholt, DRL (3)

H. R. Denton, DRL (2)

A. Giambusso, CO

L. Kornblith, Jr., CO

R. H. Engelken, CO

Regional Directors, CO

DR Central Filest

1586 050

7911110/30



## U. S. ATOMIC ENERGY COMMISSION DIVISION OF COMPLIANCE

## REGION I

## INSPECTION REPORT

CO Report No.: 71-03		050 002 0
Subject: Metropolitan Edison Company	Docket No.(s):	050-00320 050-00289
Three Mile Island Units 1 and 2	License No.(s):	CPPR-40 & 66
Location: On Susquehanna River, South of	Category	_ A
Harrisburg, Pennsylvania		
Date of Inspection: June 24-25, 1971		
Date of Previous Inspection: April 5-8, 1971		
Type of Licensee: PWR, 2535 MWt (B&W)		
Type of Inspection: Routine, Announced		
Principal Inspector:  J. H. Tillou, Reactor Inspector		7-29-7/
Accompanying Inspectors: ON! Poursi		7-29-71
D. M. Hunnicutt, Sr. Reactor		Date
Other Accompanying Personnel: W. H. Baunack, Reactor	Inspector (Oper	ations)
Reviewed by fr. Boleshuau  E. M. Howard, Senior Reactor Inspector		7-29-71
/ E. M. Howard, Senior Reactor Inspector		Date
Proprietary Information: NONE		