

INTERIM REPORT

Accession No. 7911120141
Report No. EGG-SEMI-5025

Contract Program or Project Title: Semiscale Program

Subject of this Document: Test Prediction for Semiscale Mod-3 Test S-SB-2 - Small Break Test Series

Type of Document: Test Prediction


Author(s): B. W. Murri, et al

Date of Document: September 1979

Responsible NRC Individual and NRC Office or Division: W. D. Lanning, NRC-RSR

This document was prepared primarily for preliminary or internal use. It has not received full review and approval. Since there may be substantive changes, this document should not be considered final.

EG&G Idaho, Inc.
Idaho Falls, Idaho 83401


H. P. Pearson, Supervisor
Information Processing

Prepared for the
U.S. Nuclear Regulatory Commission
and the U.S. Department of Energy
Idaho Operations Office
Under contract No. EY-76-C-07-1570
NRC FIN No.

1215 004

A6038
INTERIM REPORT

7911120 146

NRC Research and Technical
Assistance Report

TEST PREDICTION FOR SEMISCALE MOD-3 TEST S-SB-2 -
SMALL BREAK TEST SERIES

B. W. Murri
D. M. Snider
S. E. Dingman
C. P. Fineman

POOR ORIGINAL

U.S. Department of Energy

Idaho Operations Office • Idaho National Engineering Laboratory



This is an informal report intended for use as a preliminary or working document

NRC Research and Technical
Assistance Report

1216 005

U. S. Nuclear Regulatory Commission



INTERIM REPORT

Accession No. _____

Report No. EGG-SEMI-5025

Contract Program or Project Title:

Semiscale Program

Subject of this Document:

Test Prediction for Semiscale Mod-3 Test S-SB-2 - Small Break Test Series

Type of Document:

Test Prediction

Author(s):

B. W. Murri, D. M. Snider, S. E. Dingman, C. P. Fineman

Date of Document:

September 1979

Responsible NRC Individual and NRC Office or Division:

W. D. Lanning, Reactor Safety Research

This document was prepared primarily for preliminary or internal use. It has not received full review and approval. Since there may be substantive changes, this document should not be considered final.

EG&G Idaho, Inc.
Idaho Falls, Idaho 83401

Prepared for the
U.S. Nuclear Regulatory Commission
Washington, D.C.
Under DOE Contract No. **DE-AC07-76ID01570**
NRC FIN No. A6038

NRC Research and Technical
INTERIM REPORT
Assistance Report

1216 006


TEST PREDICTION FOR
SEMISCALE MOD-3 TEST S-SB-2
SMALL BREAK TEST SERIES

by

B. W. Murri
D. M. Snider
S. E. Dingman
C. P. Fineman


SEMISCALE PROGRAM

Approved



D. J. Olson, Manager
Semiscale Program

Approved



G. W. Johnsen
Semiscale Experiment Specification
and Analysis Branch

1216 007

This RELAP4 model of the Semiscale Mod-3 system for small breaks analysis has been reviewed by the Pretest Prediction Consistency Review Committee.

Reviewers:

S. R. Behling
S. R. Behling
Code Development & Analysis Program

J. R. White for J. R. White
J. R. White
LOFT Program

D. J. Varacalle, Jr.
D. J. Varacalle
Thermal Fuels Behavior Program

C. D. Fletcher
C. D. Fletcher
Code Assessment and Applications Program

CONTENTS

SUMMARY-----	vi
I. INTRODUCTION-----	1
II. RELAP4 MODEL DESCRIPTION-----	10
III. SCALING CONSIDERATIONS-----	12
1. HEAT LOSSES-----	12
2. FLOW REGIMES-----	13
3. LOOP PUMPS-----	13
4. CRITICAL FLOW-----	15
5. STEAM GENERATOR-----	17
6. DIMENSIONALITY-----	18
7. GENERAL SCALING COMMENTS-----	18
IV. PREDICTION OF THE SEMISCALE MOD-3 SMALL BREAK TEST S-SB-2-----	19
1. DEPRESSURIZATION RATE-----	19
2. BREAK FLOW-----	23
3. CORE MIXTURE LEVEL-----	27
4. STEAM GENERATOR HEAT TRANSFER-----	32
5. CORE CLAD TEMPERATURES-----	32
6. CONCLUSION-----	35
V. REFERENCES-----	37
APPENDIX A-----	A-1
APPENDIX B-----	B-1

1216 009
1216 008

TABLES

I. Initial Conditions and Operational Requirements for Test S-SB-2-----	2
II. Power Decay for Test S-SB-2-----	8
III. Pump Speed for Test S-SB-2-----	9
IV. Calculated Sequence of Events for Test S-SB-2-----	20
A-I. RELAP4/MOD7 Model Control Volume Description for Test S-SB-2-----	A-4
A-II. RELAP4/MOD7 Model Junction Description for Test S-SB-2-----	A-6
A-III. RELAP4/MOD7 Input Options Used in Test S-SB-2-----	A-9
A-IV. RELAP4/MOD7 Listing for Test S-SB-2-----	A-10
B-I. RELAP4/MOD7 Model Control Volume Description for PWR-----	B-4
B-II. RELAP4/MOD7 Model Junction Description for PWR-----	B-5
B-III. Modeling Options for PWR Calculations-----	B-7

FIGURES

1. Axial power profile-----	5
2. HPIS flow rate-----	6
3. LPIS flow rate-----	7
4. RELAP4/MOD7 model for Test S-SB-2-----	11
5. Predicted flow regimes in Semiscale and PWR cold leg piping-----	14
6. Coolant volume inventory in Semiscale and PWR-----	16
7. Calculated pressure response in Test S-SB-2 and PWR-----	21
8. Calculated intact loop steam generator primary and secondary pressures-----	22
9. Calculated break flow for Test S-SB-2 and PWR-----	24
10. Calculated mixture level in the broken loop pump suction seal for Test S-SB-2 and PWR-----	25

FIGURES (contd)

11.	Calculated break flow and total HPIS flow for Test S-SB-2-----	26
12.	Calculated core and downcomer mixture levels in Test S-SB-2-----	28
13.	Calculated core total mass for Test S-SB-2-----	29
14.	Calculated core inlet flow rate for Test S-SB-2-----	30
15.	Calculated core mixture level for Test S-SB-2 and PWR-----	31
16.	Calculated steam generator total energy transfer for Test S-SB-2 and PWR-----	33
17.	Calculated core temperatures response for Test S-SB-2-----	34
A-1.	RELAP4/MOD7 model for Test S-SB-2-----	A-3
A-2.	RELAP4/MOD7 core model for Test S-SB-2-----	A-8
B-1.	RELAP4/MOD7 model for Westinghouse PWR-----	B-3

1216 011

SUMMARY

This document contains a pretest analysis of the Semiscale Mod-3 system thermal-hydraulic response for the first test in the small break test series (Test S-SB-2). This test series was designed to be compatible with small break loss-of-coolant experiments defined for the Loss-of-Fluid Test (LOFT) Program and computer code calculations performed by the Code Assessment and Applications Program to predict pressurized water reactor (PWR) system behavior during a small break loss-of-coolant accident (LOCA). Results of the Semiscale small break tests will be used to investigate scaling effects pertinent to LOFT and Semiscale and to assess analytical models used in the computer codes.

Test S-SB-2 is an integral small break loss-of-coolant test associated with the Semiscale small break test series. The primary objective of Test S-SB-2 is to provide information on the natural circulation phenomena and the potential for core uncovering which may result from the slow depressurization during a small break in the primary cold leg pipe near the vessel for the case where high pressure injection flow is not sufficient to makeup system mass discharged through the break.

The break configuration for Test S-SB-2 will represent a 2.5% communicative cold leg break with a total break area of 0.0613 cm^2 . The test will be initiated at a core power of 2.1 MW and will utilize a 25-rod electrically heated core consisting of 23 powered rods and 1 unpowered rod (one of the rod locations has been utilized for a liquid level probe). The radial power profile will be flat with a peak axial power density of 38.69 kW/m. The steam generator secondaries and the primary coolant pumps for both the intact and broken loops will be operated in a manner which simulates the expected performance in a PWR system. Emergency core coolant will be injected into both the intact and broken loop cold legs. Upper head injection will not be used in this experiment. Test S-SB-2 will be conducted from an initial pressure of 15.5 MPa with a cold leg fluid temperature of 550 K and a core differential temperature of 33 K.

The pretest analysis for Test S-SB-2 was performed using the RELAP4/MOD7 computer code to provide a prediction of the system thermal-hydraulic response during the test.

The pretest calculation was made from initiation of rupture to 856 s. The pump seals were calculated to blowout at 278 s, which resulted in a decrease in mass in the pump seals and cold leg. The reduction in mass in the cold leg led to a decrease in break flow (change from subcooled to two phase) and a reduction in core inlet flow. The core total liquid mass was calculated to decrease throughout the transient. However, the mixture level (which represents gas and liquid), remained high until 400 s, and then decreased rapidly. Core temperatures followed the saturation temperature until 605 s when there was a minor temperature excursion (780 K peak). With the start of accumulator injection at 838 s, the temperatures decreased to near saturation temperatures and remained cool. The results of the pretest calculation were compared to results of the audit calculation for a Westinghouse PWR cold-leg 2.1% break.

1216 013

I. INTRODUCTION

This report contains the pretest analysis for the Semiscale Mod-3 system thermal-hydraulic response for Test S-SB-2 which will be the first test in the Semiscale Mod-3 small break test series (Reference 1). Semiscale performs pretest analysis for the purpose of (1) obtaining insight into the expected behavior of the system during the test, (2) ensuring that initial conditions, operating procedures and instrumentation ranges are adequate to meet the test objectives, and (3) providing an indication of unexpected adverse conditions which could arise during the experiment. In making the analysis, engineering judgement was used in modeling the system while still adhering to the Pretest Prediction Consistency Committee guidelines. This report identifies the prerupture system conditions, presents the expected behavior of key variables, and provides a comparison of the Test S-SB-2 calculated results with results from the Code Assessment and Applications Program calculation for a Westinghouse pressurized water reactor (PWR) with a 2.1% cold-leg break (Reference 2). The PWR calculations was performed as a licensing audit calculation for the Nuclear Regulatory Commission (NRC) and as such, the modeling options chosen were standard for licensing calculations. On the other hand, the Semiscale calculation was run as a best-estimate calculation and the modeling options chosen were believed to give a best estimate of the system behavior. The RELAP4/MOD7 (Reference 3) model used to predict the system small break response for Test S-SB-2 is described briefly in Section II.1 with a more thorough description given in Appendix A. The RELAP4/MOD7 model used for the PWR calculation is described in Appendix B. Scaling considerations for comparing the two calculations are discussed in Section III.

The operating conditions for Test S-SB-2 are listed in Table I. The break configuration will represent a 2.5% communicative cold leg break with a total break area of 0.0613 cm^2 . The test will be conducted at an initial core power of 2.1 MW and an initial core mass flow rate of 11.7 kg/s. The heated core for this test will have

1216 014

TABLE I

INITIAL CONDITIONS AND OPERATIONAL REQUIREMENTS FOR TEST S-SB-2

Initial Conditions

Pressurizer Pressure	15.51 MPa
Hot Leg Fluid Temperature	583.3 K
Cold Leg Fluid Temperature	550.0 K
Core Inlet Flow Rate	11.7 kg/s
Total Core Power	2.1 MW
Radial Power Profile	F' c
Pressurizer Liquid	13.1 kg
Steam Generator Secondary Pressure	5.86 MPa
Steam Generator Feedwater Temperature	495 K
Steam Generator Secondary Water Level	
Intact Loop	2.95 m
Broken Loop	9.98 m

Configuration

Break Size	2.5%
Break Type	Communicative
Break Location	Cold Leg
Pressurizer Location	Intact Loop
Pressurizer Line Resistance (m ⁻⁴)	5.9x10 ⁸
Intact Loop ECC Injection	
Location (all systems)	Cold Leg
Broken Loop ECC Injection	
Location (all systems)	Cold Leg
Intact Loop Accumulator Line	
Resistance (m ⁻⁴)	8.59x10 ⁸
Broken Loop Accumulator Line	
Resistance (m ⁻⁴)	7.73x10 ⁹

ECC Injection


Intact Loop Accumulator	
Actuation Pressure	4.24 MPa
Liquid Volume	0.04480 m ³
Nitrogen Volume	0.02635 m ³
Temperature	300 K
Intact Loop HPIS	
Actuation Pressure	12.41 MPa
Delay	25 s
Injection Rate	see Fig. 2
Temperature	300
Intact Loop LPIS	
Actuation Pressure	0.883 MPa
Injection Rate	see Fig. 3
Temperature	300 K

TABLE I (contd)

Broken Loop Accumulator	
Actuation Pressure	4.24 MPa
Liquid Volume	0.01493 m ³
Nitrogen Volume	0.00878 m ³
Temperature	300 K
Broken Loop HPIS	
Actuation Pressure	12.41 MPa
Delay	25 s
Injection Rate	see Fig. 2
Temperature	300 K
Broken Loop LPIS	
Actuation Pressure	0.883 MPa
Injection Rate	see Fig. 3
Temperature	300 K
<u>Transient Conditions</u>	
SCRAM (power decay)	See Table II
Pressure Setpoint	12.58 MPa
Time Delay	3.4 s
Steam Generator Secondaries	
Steam Valve Relief Pressure	7.7 MPa
Steam Valve Isolation	12 s after scram
Main Feedwater Isolation	5 s after scram
Auxiliary Feedwater Initiation	60 s after scram
Auxiliary Feedwater Flow Rate	
Intact Loop	0.0296 kg/s
Broken Loop	0.0099 kg/s
Auxiliary Feedwater Temperature	300 K

1216 016

23 powered rods and 1 unpowered rod (one of the rod locations has been used for a liquid level probe). The radial power profile will be flat with a peak axial power density of 38.69 kW/m. All rods will have a chopped cosine axial power profile as shown in Figure 1. The core inlet fluid temperature will be 550 K and the core fluid temperature differential will be 33 K. The electrical power decay will follow the decay curve shown in Table II. The normalized pump speed for intact and broken loop pumps is given in Table III. Emergency core coolant (ECC) injection is to be made into both the intact loop and broken loop cold legs using accumulators and high pressure injection system (HPIS) and low pressure injection system (LPIS) pumps. The HPIS and LPIS flow rates as a function of pressure are shown in Figures 2 and 3, respectively. ECC water is to be ambient for this test. The pressure suppression system will be controlled to maintain a containment pressure of 241 kPa throughout the test.



INEL-A-6614

Fig. 1 Axial power profile.




Fig. 2 HPIS flow rate.




Fig. 3 LPIS flow rate.

1215 020

7

TABLE II
POWER DECAY FOR TEST S-SB-2

<u>Time after trip (s)</u>	<u>Normalized Power</u>	<u>Normalized Voltage</u>
0*	1.0	1.000
3	0.4	0.632
6	0.123	0.351
20	0.06	0.245
30	0.052	0.228
60	0.044	0.210
100	0.04	0.200
200	0.035	0.187
1000	0.023	0.152

* Time = 0 s is defined as 3.4 s after the pressurizer pressure reaches 12.58 MPa.

TABLE III
PUMP SPEED FOR TEST S-SB-2

<u>Time after trip (s)</u>	<u>Normalized Value</u>
0*	1.00
10	0.550
20	0.375
30	0.280
40	0.235
50	0.215
60	0.200
120	0.100
130	0.000

* Time = 0 s is defined as 3.4 s after the pressurizer pressure reaches 12.58 MPa.

1216 022

II. RELAP4 MODEL DESCRIPTION

The RELAP4/MOD7 (Update 92*) computer code was used to predict the system response during the blowdown, vessel refill, and core reflood of Test S-SB-2. The model nodalization representing the Semiscale system is shown in Figure 4. A more detailed description of the model and a listing** of the input for Test S-SB-2 is contained in Appendix A. The Henry-Fauske and homogeneous equilibrium (HEM) critical flow models were used for the subcooled and two phase break flow regimes, respectively. A break flow multiplier of 1.0 was used during both the subcooled regime and the saturated regime. Vertical slip was used in the model at all downcomer, core, and support and guide tube junctions. To be consistent with the use of slip in the core, the bubble rise model was not used in either the upper or lower plenums. The standard bubble rise model was used in the downcomer, core, upper head, pressurizer, pump suction, and steam generator secondaries. Heat conductors were included in the upper plenum to model the energy stored in the upper plenum and upper head structures, and heat conductors were used to model heat transfer from piping, downcomer wall and core barrel. Conductors were also used in the lower plenum to model energy stored in the unpowered rod sections. The upper plenum was nodalized into three control volumes in an attempt to simulate the mixing between the upper plenum fluid and fluid draining from the upper head through the guide and support tubes. All heat conductors which would be exposed to the environment were insulated on the outer surfaces and thus did not account for energy transfer from the system to the environment. The pressure suppression tank (Volume 6 in Figure 4) was represented as a time-dependent volume filled with saturated vapor at a constant pressure of 241 kPa. The pump power was tripped off at scram, and the intact and broken loop pumps followed the coastdown curve shown in Table III.

* RELAP/MOD7 historical code configuration control number is H007184B.

** Input to RELAP4/MOD7 historical code configuration control number is H009941B.




Fig. 4 RELAP4/MOD7 model for Test S-SB-2.

1215 024

III. SCALING CONSIDERATIONS

Due to inherent scaling compromises, the results obtained from tests in the Semiscale small break test series are not to be considered entirely representative of those expected in a PWR under similar conditions. Data from these tests will be used primarily to benchmark small break code capability and to evaluate scale effects by comparison to LOFT system results. Nevertheless, the value of Semiscale data is increased through an understanding of scaling limitations and their potential effect on results.

Several specific scaling concerns have been identified and categorized as either manageable or accountable. Those distortions considered manageable will require physical modification to the system to be effectively mitigated. Included in this category are excessive external heat loss and atypical steam generator configuration. Scaling distortions that are defined as accountable cannot be physically eliminated but may be assessed analytically. Scaling influences on flow regimes and critical flow are included in this category.

In the subsections that follow each of the identified scaling distortions is discussed and evaluated as to potential effect. It is important to recognize that an extensive technical evaluation of the impact of scaling on small break behavior in Semiscale has not yet been completed. Indeed, the data forthcoming from the small break tests series will be utilized as an integral part of that evaluation.

1. HEAT LOSSES

The heat losses from the piping, vessel and downcomer to the environment and heat loss to cooled instruments in the Semiscale Mod-3 system represent approximately 6% of initial core power. The heat loss should be on the order of 0.07% to be representative of that in a PWR. To compensate for the excess heat losses in Semiscale, the core power in Test S-SB-2 will be increased. Additionally, recent installation of a honeycomb downcomer insulator and improved insulation of the loop piping should reduce the heat loss.

1216 025

A long-term solution to the heat loss problem includes the installation of strip heaters and high quality external insulation. In the pretest calculation heat structures were modeled with an insulated outer surface, and thus heat loss between the system and environment was not accounted for. An analysis is currently underway to quantify the effect on system response caused by piping heat loss and increased core power to offset it. It is recognized that the increase in core power has the potential to distort core coolant void distribution and uncovered core temperature response.

2. FLOW REGIMES

Scaling influences can induce flow regime differences between Semiscale and a PWR during a small break LOCA. The flow regime differences can in turn affect the wetted surface areas, pressure drops, and critical break flow characteristics. Since the RELAP4 calculations for both Semiscale and a PWR assume homogeneous flow, the effects of scale on flow regime characteristics cannot be evaluated with the code. The potential difference in flow regime behavior between Semiscale and a PWR during a small break LOCA has been investigated analytically using the Dukler-Taitel method (Reference 4) in conjunction with the results of the PWR audit calculation. A sample result is shown in Figure 5 which compares the predicted flow regime in the broken loop cold leg pipe (between the break and the pump) in Semiscale and the PWR. Good agreement is obtained when mass flow rates in Semiscale are assumed to scale properly.*

3. LOOP PUMPS

The head performance of the small-scale Semiscale pumps is expected to degrade more rapidly than in PWR pumps as coolant void fraction increases. However, for Test S-SB-2, the Semiscale primary

1216 026

* Comparison of LOFT and Semiscale mass flow rates indicate this to be a valid premise.

PREDICTED FLOW REGIMES IN SEMISCALE AND PWR COLD
LEG PIPING DUKLER-TAITEL METHOD - PWR 4 IN. BREAK
AUDIT CALCULATION MASS FLUXES USED




Fig. 5 Predicted flow regimes in Semiscale and PWR cold leg piping.

coolant pumps are tripped at scram and will coastdown before significant voiding occurs. Consequently, pump performance is not considered a scaling distortion for this test.

4. CRITICAL FLOW

The critical flow characteristics of the Mod-3 system can be affected by piping flow regimes, system coolant distribution, and the small size of the break orifice. The piping flow regimes and the relative coolant distribution can affect the timing and duration of the transition from single-phase to two-phase flow at the break, and as a result, the system depressurization. The small break size may be influenced by boundary layer effects (vena contracta) and by bubble sizes which could be comparable to the orifice diameter.

Flow regime agreement between Semiscale and a PWR in the vicinity of the break may potentially be quite good, as evidenced by the comparison shown in Figure 5. Break uncover time occurs as the pump seals blow out, and in either system, the breaking of the water seals is influenced by the mass discharge rate from the system and the relative amount of coolant in the upper parts of the system which can drain into the pump suction pipes. Figure 6 compares coolant volume inventory (as a percent of total volume) as a function of elevation in Semiscale and a PWR. Because the Semiscale system is, relatively speaking, shorter than a PWR, distortions in coolant inventory to elevation relationship exist in the upper and lower portions of the system. However, in the vicinity of the cold leg centerline the coolant inventory agreement is quite good, with the Semiscale system containing approximately 10% more coolant than the PWR at this location. Thus Semiscale and PWR have close to the same potential for draining water into the pump suction pipes, and both maintain the pump seals for about the same duration. It can be concluded that if the break discharge is scaled properly, then, seal blowout and break uncover time in Semiscale should be comparable to that in a PWR. This conclusion is born out by the RELAP₅ analysis as discussed later in this text.




Fig. 6 Coolant volume inventory in Semiscale and PWR.

With regard to break orifice size, results from the Three Mile Island accident simulations in Semiscale (Reference 5) indicate that critical flow atypicality is not evidenced in orifices as small as 0.091 cm in diameter. Moreover, an independent calibration of the break orifice utilized for Test S-SB-2 is to be conducted to better characterize its critical flow behavior.

5. STEAM GENERATOR

The Semiscale steam generators may produce atypical system response because of disproportionately large secondary side volumes and an elevation mismatch between the intact and broken loop steam generators. The broken loop steam generator secondary is approximately five times larger than if it were properly scaled to a PWR and the intact loop steam generator is 30% larger. These distortions may result in atypical heat transfer from primary to secondary which is an important means of heat rejection during a small break. Current plans call for the replacement of the intact loop steam generator (Type I, scaled to LOFT) with a Type II steam generator (similar to what is now in the broken loop). This will eliminate the elevation mismatch problem. Furthermore, design modifications are currently being explored to minimize the secondary volume distortions. However, neither the replacement of the intact loop steam generator nor volume modifications will occur prior to completion of the current small break test series.

Elevation differences between the intact and broken loop steam generators may affect fallback and flow separation in Semiscale relative to a PWR. During natural circulation the differences in elevation may also affect the magnitudes and relative flow distributions between the intact and broken loops. The differences in elevation, however, can be partially compensated for by adjusting loop resistance. The broken loop resistance in Semiscale is to be adjusted to account for the differences in steam generator elevations. A posttest calculation may be required if the differences in loop resistances between the pretest calculation and the actual test are found to influence results significantly.

1216 030

A qualitative indication of steam generator design effects is afforded by a comparison of the pretest prediction and PWR audit calculation results. This comparison (discussed in Section IV.4) indicates that the scaling distortions did not result in appreciable differences in primary-to-secondary heat transfer, on a scaled basis.

6. DIMENSIONALITY

Since Semiscale is essentially a one-dimensional facility, multi-dimensional coolant behavior that may occur in a PWR during a small break LOCA may not be well represented. In general, it is felt that multi-dimensional fluid behavior in a PWR would be restricted primarily to the core region, in terms of radial flow components induced by radial power variations. The quantitative affect on PWR core thermal-hydraulic behavior caused by potential multi-dimensional flow patterns is unknown. Moreover, one-dimensional codes such as RELAP4 are unable to address the question of multi-dimensionality in Semiscale versus a PWR.

7. GENERAL SCALING COMMENTS

The Semiscale core geometry, core elevation, and pump loop seal elevations are matched directly with those from a Westinghouse PWR. Therefore, the timing and magnitude of important phenomena relating to pump seal blowout and core uncovering should be similar to the expected behavior in a PWR (assuming system depressurization and primary side heat transfer are matched correctly).

In-core heat transfer and cladding temperature response above the core liquid level will be affected by electric rod thermal properties and fixed axial power profile representation in Semiscale, as opposed to a PWR core utilizing fuel rods arranged to produce a peaked axial profile.

IV. PREDICTED SYSTEM BEHAVIOR

Presented in this section is a discussion of the system behavior from the pretest calculations for Test S-SB-2. The results of the pretest calculation are demonstrated through the use of several calculated system variables, including system depressurization, flow rates, mixture levels, densities, heat transfer rates, and temperatures. To provide additional system analysis, a few key parameters describing system behavior are compared to those obtained from the PWR audit calculation.

A sequence of events in their order of occurrence in the pretest calculation is listed in Table IV.

1. DEPRESSURIZATION RATE


Directly following initiation of the simulated pipe rupture, the system pressure was calculated to decrease from 15.5 to 7.4 MPa during the first 30 s of the transient, as shown in Figure 7. This depressurization period corresponded to the time required for the system to depressurize to the saturation pressure associated with the core fluid temperature. Stabilization of the system pressure occurred at about 7.4 MPa when the system pressure and steam generator secondary pressure (Figure 8) equalized. At 340 s the fluid exiting the break changed from subcooled to two-phase, resulting in a decrease in mass flow but an increased enthalpy discharge at the break location and thus, increased system depressurization rate. At 838 s, the accumulators began emptying into the system which led to an increased depressurization rate. The increased depressurization rate resulted from complete mixing of subcooled and saturated water at the accumulator injection points. This complete mixing is an inherent limitation in the code and is not expected to occur in the actual test.

The Semiscale system depressurization behavior was very similar to that which occurred in the PWR calculation (Figure 7); however, the pressure for Test S-SB-2 was consistently lower than that for the

TABLE IV

CALCULATED SEQUENCE OF EVENTS FOR TEST S-SB-2

<u>Time (s)</u>	<u>Event</u>
0.0	Break nozzle opens, subcooled blowdown commences.
12.9	Scram signal received, steam generator discharge valves begin to close (pressurizer pressure falls to 12.58 MPa).
16.3	Reactor scram, pump power tripped off.
17.4	Steam generator discharge valves fully closed.
21.3	Main feedwater starts to ramp off.
25.8	Main feedwater completely off.
31.6	Pressurizer valve closes (pressurizer mixture level falls to 3.05 cm).
41.3	HPIS initiated.
62.0	Intact loop steam generator relief valve opens.
76.3	Steam generator auxiliary feedwater comes on.
838.0	Intact loop and broken loop accumulator flow initiated.



PRETEST CALCULATION FOR TEST S-SB-2

Fig. 7 Calculated pressure response in Test S-SB-2 and PWR.

1216 034




Fig. 8 Calculated intact loop steam generator primary and secondary pressures.

PWR. This led to earlier occurrence of events (trips based on pressure) in the S-SB-2 calculation than were calculated to happen in the PWR. The lower pressure attained in the pretest calculation can be attributed to a great extent on a larger subcooled break flow rate allowed by a larger break size (2.5% for Semiscale compared to 2.1% for the PWR).

2. BREAK FLOW

The calculated break flow for Test S-SB-2 is shown in Figure 9 as compared with the volume-scaled PWR calculated break flow. Subcooled flow at the break was calculated to last until about 340 s after rupture in both calculations, at which time the pump seals were blown out (as seen by the drop in mixture level at the broken loop pump suction in Figure 10). Loss of water in the pump seals brought about a rapid decrease in mass upstream from the break, which in turn led to a transition from subcooled to two phase break flow. Throughout the transient, the calculated break flow was higher than the HPIS (Figure 11), allowing the system to depressurize.

The Semiscale calculated break flow rate was higher than the volume-scaled PWR flow rate during the subcooled period and lower than the PWR flow rate during the two phase period. The higher flow rate in the subcooled period was a result of a larger break area (scaled) in Semiscale than in the PWR (2.5% for Semiscale compared to 2.1% for the PWR). In the experiment, the small size of the break orifice (relative to the boundary layer) may lead to a flow rate less than that calculated in the prediction. In the two phase break period, two different break flow models were employed for the Semiscale and PWR calculations. In the Semiscale calculation, the HEM flow table was used while in the PWR calculation, the Moody flow table was used. The Moody critical flow table generally gives break flow rates larger than HEM and thus the larger PWR (scaled) flow rate would be expected.




Fig. 9 Calculated break flow for Test S-SB-2 and PWR.





Fig. 10 Calculated mixture level in the broken loop pump suction seal for Test S0SB-2 and PWR.

8200151



PRETEST CALCULATION FOR TEST S-SB-2

Fig. 11 Calculated break flow and total HPIS flow for Test S-SB-2.

1215 039

3. CORE MIXTURE LEVEL

The calculated mixture level for the Semiscale core is shown in Figure 12. This level represents a combined gas and liquid mixture, and although at times the mixture level was near the top of the core, the total liquid mass decreased until initiation of accumulator injection (Figure 13).

The mixture level is one of the more important parameters and its behavior addresses directly one purpose of the experiment, which is to determine if core uncovering will occur. From examining Figure 12, it is observed that the calculated mixture level decreased (for an extended time) at about 400 s after rupture (core uncovering) and then began oscillating until the accumulators came on. The drop in core mixture level from 400 s to 600 s led to a mild core temperature excursion which lasted until accumulator injection began. The oscillations beginning at 600 s are of a manometer type as suggested by the level in the core being 180° out of phase with the downcomer level as shown in Figure 12. However, as seen from the core inlet flow (Figure 14) there was no net mass transfer between downcomer and core. The driving force for the oscillations was partially due to core heat transfer. As the core mixture level dropped, core heat transfer decreased and reduced steam generation. The reduction in steam generation reduced the pressure above the core, and the downcomer head of water forced a greater amount of water into the core. This influx of coolant in turn increased the core heat transfer rate and steam generation which in turn increased the pressure and reduced the core inlet flow. The oscillations were terminated when accumulator ECC water was injected into the system.

The calculated mixture level in the Semiscale core was much different than that calculated for the PWR (Figure 15) even though the behavior of other parameters around the system was quite similar. In the PWR calculation, the core remained full until about 810 s after rupture. The PWR core remained partially uncovered until initiation of accumulator injection at 1007 s. The two calculations used




Fig. 12 Calculated core and downcomer mixture levels in Test S-SB-2.




Fig. 13 Calculated core total mass for Test S-SB-2.




Fig. 14 Calculated core inlet flow rate for Test S-SB-2.




Fig. 15 Calculated core mixture level for Test S-SB-2 and PWR.

different modeling in the core region (See Appendix A and Appendix B), and this modeling difference may be the source of differences between the two calculations. Posttest examination of calculated versus measured mixture level will provide a judgement of the merit of the modeling used in Semiscale. The effect of differences in RELAP4 modeling between Semiscale and a Westinghouse PWR will be addressed once experimental data has been obtained.

4. STEAM GENERATOR HEAT TRANSFER

The steam generator total heat transfer rates for the pretest calculation are compared to the volume-scaled steam generator total heat transfer rates calculated for the PWR in Figure 16. One scaling concern for steam generators is that the excessive size of the Semiscale secondary volumes could result in atypical heat transfer to the secondaries. In this calculation, scaling of the secondary volumes did not represent a major problem, as the total heat transfer rates for the Semiscale steam generators compared quite well to the PWR steam generator total heat transfer rates. A second scaling concern is that the use of two different size steam generators may lead to abnormal behavior between the intact and broken loop. The second concern does not appear to pose a major problem since not only does the total steam generator energy compare well but so does the energy transfer from the individual steam generators.

5. CORE CLAD TEMPERATURES

The peak cladding temperatures calculated for the Semiscale core (Figure 17) followed the saturation temperature until about 500 s, when core uncover reached the top of heat conductor 49 (refer to Figure 4). The cladding temperature peaked at 780 K before the core began refilling at about 605 s. The peak cladding temperature for the Semiscale core compares well with the PWR core peak cladding temperature up to 500 s. This would be expected since the system depressurization rates compare well and the core cladding temperatures follow the saturation temperatures, as long as the mixture level is




Fig. 16 Calculated steam generator total energy transfer for Test S-SB-2 and PWR.

1216 046




Fig. 17 Calculated core temperatures response for Test S-SB-2.

above the heated core. The peak cladding temperature for the PWR core rose to a maximum of 670 K after the core had partially uncovered at about 1000 s. Accumulator flow was initiated at 1007 s in the PWR calculation, and the surface temperatures decreased to near the saturation temperature.

6. CONCLUSION

Substantial core uncovering is calculated to occur in Test S-SB-2, as shown in Figure 12. As a result of core uncovering, the peak cladding temperature reached a maximum of 780 K before the core was quenched by accumulator flow at 838 s.

Two significant factors bear on the degree of confidence placed on the validity of this pretest prediction. First, it is recognized that the calculation does not embody all of the features that are potentially necessary to describe the thermal-hydraulic phenomena expected. For example, the RELAP4 code is unable to predict flow regime definition beyond homogeneous or separated condition (and even this is restricted to selected model nodes). Also, the RELAP4 model used did not account for the external system heat loss expected in the test, nor the increased core power to be employed to offset this heat loss.

Secondly, experience with the RELAP4 code has shown that results can be very sensitive to model input (i.e., nodalization, code options). This is particularly true of the prediction of core uncovering, which ultimately determines the severity of the transient. In addition to the importance of correctly predicting mass and energy inventory in the system, reliance must be placed upon a model for level swell behavior. An insufficient basis presently exists for evaluating the various bubble rise options available in the RELAP4 code and selecting the optimum approach.

1216 048

In conclusion, it must be stressed that the expectation of good agreement between the pretest prediction and test data for Test S-SB-2 is significantly lower than has been the case for large break

experiments of the past. The refinement of models and identification of deficiencies can only be made possible by the experience gained through posttest analysis as the small break test series proceeds.

1512 049

1216 049

V. REFERENCES

1. Semiscale Program, Appendix SB to the Semiscale Experimental Operating Specification - Mod-3 Small Break Test Series, SEMI-TR-011, EG&G Idaho, Inc. (August 1979).
2. C. A. Dobbe, C. D. Fletcher, and E. E. Ross, Audit Calculations for Westinghouse PWR Small Cold-Leg Breaks, CAAP-TR-054, EG&G Idaho, Inc. (August 1979).
3. RELAP4/MOD7 User's Manual, CDAP-TR-78-036 (August 1978).
4. Y. Taitel and A. E. Dukler, "A Model for Predicting Flow Regime Transitions in Horizontal and Near Horizontal Gas-Liquid Flow," AIChE Journal (Vol. 22, No. 1), (January 1976).
5. T. K. Larson, G. G. Loomis, and R. W. Shumway, Semiscale Simulations of the Three Mile Island Transient - A Summary Report, SEMI-TR-010, EG&G Idaho, Inc. (July 1979).

1216 050

APPENDIX A

RELAP4 MODEL FOR TEST S-SB-2

1215 051

APPENDIX A

RELAP4 MODEL FOR TEST S-SB-2

The nodalization diagram for the RELAP4 model used for the Test S-SB-2 prediction is shown in Figure A-1. The model includes 38 control volumes and 54 junctions. Two control volumes are used to represent the lower plenum, one volume to represent the core mixer box, one volume to represent the core, and three volumes to represent the upper plenum. The inlet annulus, downcomer, guide tube, support tubes and the upper head are each represented by one control volume. Table A-I provides physical descriptions of the control volumes used in the model. Table A-II describes the junctions used in the model which connect the control volumes, as well as those which join fill volumes to control volumes. Fill junctions are used to represent the high pressure injection system (HPIS), the low pressure injection system (LPIS), and the intact and broken loop steam generator secondary water supply.

A total of 50 heat slabs are used to represent heat conducting solids in contact with the coolant in the core, downcomer, steam generators, vessel, and piping. Heat conductors in the core are capable of modeling both high and low power rods although for Test S-SB-2 all rods had equal power. The high power rods are represented by 10 axial heat slabs, and the low power rods are represented by 5 axial heat slabs. The core heat conductor and fluid volume nodalization are shown in Figure A-2.

The more significant code analytical options used in this calculation, including heat transfer correlations, vertical slip, and bubble rise model, are listed in Table A-III. The RELAP4 input listing for Test S-SB-2 is given in Table A-IV.




Fig. A-1. RELAP4/MOD7 model for Test S-SB-2.

1216 053

TABLE A-I

RELAP4/MOD7 MODEL CONTROL VOLUME DESCRIPTION FOR TEST S-SB-2

<u>Control Volume</u>	<u>Description</u>
1	Core
2	Bottom of the upper plenum
3	Mid-volume of the upper plenum
4	Top volume of the upper plenum
5	Upper head
6	Pressure suppression vessel
7	Accumulator - intact loop
8	Accumulator - broken loop
9	Pressurizer
10	Intact loop hot leg
11	Intact loop steam generator inlet plenum
12, 13, 14	Intact loop steam generator tube bundle
15	Intact loop steam generator outlet plenum
16	Intact loop pump suction - downflow
17	Intact loop pump suction - upflow
18	Intact loop pump
19	Intact loop cold leg
20	Broken loop steam generator secondary
21	Broken loop hot leg
22	Broken loop steam generator inlet plenum
23, 24, 25	Broken loop steam generator tube bundle
26	Broken loop steam generator outlet plenum
27	Broken loop pump suction - downflow
28	Broken loop pump suction - upflow
29	Broken loop pump
30	Broken loop pump discharge
31	Break assembly
32	Broken loop cold leg
33	Support tubes
34	Inlet annulus and downcomer
35	Lower plenum

1216 054

TABLE A-I (contd)

<u>Control Volume</u>	<u>Description</u>
36	Core mixer box
37	Guide tube
38	Intact loop steam generator secondary

1216 055

TABLE A-II

RELAP4/MOD7 MODEL JUNCTION DESCRIPTION FOR TEST S-SB-2

<u>Junction</u>	<u>Description</u>
1	Core mixer box, core
2	Intact loop accumulator, intact loop cold leg
3	Broken loop accumulator, broken loop cold leg
4	Pressurizer, intact loop hot leg
5	Core, bottom of upper plenum
6	Bottom of upper plenum, mid-volume of upper plenum
7	Mid-volume of upper plenum, top volume of upper plenum
8	Top volume of upper plenum, intact loop hot leg
9	Intact loop hot leg, intact loop steam generator inlet plenum
10	Intact loop steam generator inlet plenum, intact loop steam generator tube bundle
11, 12	Intact loop steam generator tube bundle junctions
13	Intact loop steam generator tube bundle, intact loop steam generator outlet plenum
14	Intact loop steam generator outlet plenum, intact loop pump suction - downflow
15	Intact loop pump suction - downflow, intact loop pump suction - upflow
16	Intact loop pump suction - upflow, intact loop pump
17	Intact loop pump, intact loop cold leg
18	Intact loop cold leg, inlet annulus and downcomer
19	Broken loop cold leg, inlet annulus and downcomer
20	Top volume of upper plenum, broken loop hot leg
21	Broken loop hot leg, broken loop steam generator inlet plenum
22	Broken loop steam generator inlet plenum, broken loop steam generator tube bundle
23, 24	Broken loop steam generator tube bundle junctions
25	Broken loop steam generator tube bundle, broken loop steam generator outlet plenum

TABLE A-II(contd)

<u>Junction</u>	<u>Description</u>
26	Broken loop steam generator outlet plenum, broken loop pump suction - downflow
27	Broken loop pump suction - downflow, broken loop pump suction - upflow
28	Broken loop pump suction-upflow, broken loop pump
29	Broken loop pump, broken loop pump discharge
30	Broken loop discharge, break assembly
31	Upper head, support tubes
32	Upper head, guide tubes
33	Support tubes, bottom of upper plenum
34	Guide tube, bottom of upper plenum
35	Lower plenum, core mixer box
36	Inlet annulus and downcomer, lower plenum
37, 38	Guide tube, mid-volume of upper plenum
39, 40	" " " " " " "
41	Pressure suppression vessel, break assembly
42	Break assembly, broken loop cold leg
43	Intact loop steam generator feedwater
44	Intact loop steam generator discharge
45	Intact loop steam generator relief valve
46	Broken loop steam generator feedwater
47	Broken loop steam generator discharge
48	Broken loop steam generator relief valve
49	Broken loop LPIS
50	Broken loop HPIS
51	Intact loop LPIS
52	Intact loop HPIS
53	Intact loop steam generator auxiliary feedwater
54	Intact loop steam generator auxiliary feedwater





Fig. A-2. RELAP4/MOD7 core model for Test S-SB-2.

TABLE A-III

RELAP4/MOD7 INPUT OPTIONS FOR TEST S-SB-2

1. MVMIX=0 (compressible flow with momentum flux) is used at all junctions except the following: MVMIX=-2 for junctions associated with the steam generator secondary relief and discharge valves, and MVMIX=3 for junctions associated with the accumulators, pressurizer, guide and support tubes, main and auxiliary feedwater, and high and low pressure injection systems.
 2. Vertical slip is used at all vertical junctions in the reactor vessel, except between the core mixer box and core, and at all vertical junctions between the steam generator tube bundles and the downflow pump suction.
 3. The standard bubble rise model (velocity 0.91 m/s and gradient of 0.8) is used in the pump suction, steam generator secondaries, pressurizer, downcomer, core, and upper head. A bubble rise model allowing complete separation of phases within a control volume is used in the accumulators.
 4. Critical flow is modeled using the Henry-Fauske/HEM option. A flow rate multiplier of 1.0 is applied to HEM, as well as to subcooled Henry Fauske.
 5. Core heat transfer is calculated by using (1) HTS2 heat transfer surface, (2) implicit wall temperature solution on the right side of all conductors, (3) modified Tong-Young transition boiling correlation, and (4) Condie-Bengston III (HTS2) and Condie-Bengston IV (HTS3) film boiling correlation.
 6. The enthalpy transport model is used to initialize the calculation, but is not used during the transient.
 7. The new slip velocity model developed for RELAP4/MOD7 is used to provide a flow regime dependent correlation, which results in a more accurate value for interphase slip velocities.
 8. The RELAP4/MOD7 self-initialization routine is used to effect an initial system pressure balance and energy balance.
 9. Steam generator secondaries utilize the natural convection option for heat transfer.
-

TABLE IV

RELAP4/MOD7 LISTING FOR TEST S-SB-2

CCCCCCCC11111111112222222222333333333333444444444455555555556666666666777777777788
 123456789C123456789C123456789C123456789C123456789C123456789C123456789C123456789C123456789C

-RUN S-SB-2

- 1) RELAP4/MOD7 MODEL
- 2) ONE VOLUME CORE
- 3) 2.5 PERCENT BREAK (AREA=6.175E-5 FT2)

** PROBLEM DIMENSION DATA **

010001 -2 0 5 1E 38 5 1 54 2 6 2 12 50 14 7 15 0 0

** PROBLEM CONSTANT DATA **

010002 2.1 1.

** WATER PACKING AND MIXTURE LEVEL SMOOTHING DATA **

030003 50 0 0 .COOL

030004 50 0.

** UNCOUPLE H.T. TIME STEPS **

030006 0. - .1 0

** TIME STEP DATA **

030010 2 2 1C 1 0 0 .01 .00001 2. 3900.

030020 2 2 1C 1 0 0 .09 .0001 10.

030030 2 2 1C 1 0 0 .09 .0001 35.

030040 3 3 1C 1 0 0 .06 .0000 50.

030050 2 2 1C 1 0 0 .01 .00001 9000.

** TRIP CONTROL DATA **

040010 1 1 0 0 5000. 0. *END OF PROBLEM

040020 2 2 0 0 0 0. 3.4 *OPEN BREAK NOZZLE

040030 3 3 9 9 1825. 0. *SCRAM & PUMP COASTDOWN

040040 4 4 38 38 1065. 0. *INTACT LOOP SG RELIEF VALVE

040050 5 5 20 20 1065. 0. *BROKEN LOOP SG RELIEF VALVE

040060 6 6 9 9 0 0.1 *CLOSE PRESSURIZER VALVE

040070 7 7 5 5 0 0.01 *INTACT LOOP ACCUMULATOR

040080 8 8 5 5 0 0.01 *BROKEN LOOP ACCUMULATOR

040090 9 9 9 9 1825. 28.4 *INTACT LOOP HPIS

040100 10 10 9 9 1825. 28.4 *BROKEN LOOP HPIS

040110 11 11 0 0 5000. 0. *INTACT LOOP LPIS

040120 12 12 0 0 5000. 0. *BROKEN LOOP LPIS

040130 13 13 9 9 1825. 0. *S.G. DISCHARGE

040140 14 14 9 9 1825. 63.4 *I.L. S.G. AUX. F.W.

040150 15 15 9 9 1825. 63.4 *B.L. S.G. AUX. F.W.

040160 16 16 30 30 15. 1. *TURN ON NONEQUILIB. MODEL IN BL

040170 17 17 30 30 15. 1. *TURN ON NONEQUILIB. MODEL IN IL & VESSEL

040180 18 18 9 9 1825. 8.4 *S.G. FEEDWATER

** CONTROL VOLUME DATA **

000CCCCC011111111112222222222333333333333444444444455555555556666666666777777777788
 123456789C123456789C123456789C123456789C123456789C123456789C123456789C123456789C123456789C

TABLE A-IV (contd)

050011	5	C	2265.0046	578.5	-1.	.368328	12.	12.	0.	.030694	.0332	-16.26166	0	17
050021	C	C	2255.9356	610.	-1.	.05175	1.	.0009	1.	.0009	.05171	.05544	-4.2617	0
050031	C	C	2252.064	610.	-1.	.090244	2.	.17744	2.	.17744	.041445	.09894	-3.2608	0
050032	17													
050041	0	C	2250.610.	-1.	.276993	5.5417	5.5417	0.	.049983	.153691	-1.08336	0	17	
050051	5	C	2250.	544.	-1.	.4716	8.7235	8.7235	0.	.05406	.176869	5.1615	0	
050061	5	C	2249.3	-1.	.11007	.936	50.	5.45	0	.79	3.4	-8.4	0	
050071	1	C	615.80.	0.	.2.506	2.506	1.575	0	1.	.12838	0.	0.	0	
050081	1	C	615.80.	0.	.837	.837	.527	0	1.	.12838	0.	0.	0	
050091	5	C	2247.655	-1.	.978	4.53	3.042	0.	.2553	.5701	.6	0	0	
050101	C	C	2247.655	-1.	.610.	.355	.21867	.21867	0.	.03755	.21867	.599	0	
050111	0	C	2232.5242	610.	-1.	.366	2.38567	2.38567	0.	.15342	.44197	.81767	0	
050121	0	C	2230.561	593.47	-1.	.26833	5.6162	5.6162	0.	.0476	.0335	3.20334	0	
050131	0	C	2227.7369	565.61	-1.	.26833	2.86422	2.86422	0.	.0476	.0335	8.81954	0	
050141	0	C	2227.6365	549.62	-1.	.26833	5.6162	5.6162	0.	.0476	.0335	3.20334	0	
050151	0	C	2226.1488	544.	-1.	.34	1.995	1.995	0.	.17043	.46583	1.20833	0	
050161	2	C	2214.1687	544.	-1.	.407241	10.30833	10.30833	0.	.03755	.21867	-9.1	0	
050171	2	C	2213.7505	544.	-1.	.430467	8.35508	8.35508	0.	.03755	.21867	-9.1	0	
050181	0	C	2246.7864	544.	-1.	.144	1.03117	1.03117	0.	.03491	.21083	-.92183	0	
050191	0	C	2281.2049	544.	-1.	.304916	.21867	.21867	0.	.03755	.21867	-.10933	0	
050201	4	C	0.525.26	.072	3.46	41.	32.743	0.	.0855	.25	8.40883	0		
050211	0	C	2247.6025	610.	-1.	.079153	.1115	.1115	0.	.009764	.1115	.65258	0	
050221	0	C	2244.7785	610.	-1.	.101793	5.89475	5.89475	0.	.017266	.1483	.764083	0	
050231	0	C	2233.7763	589.48	-1.	.164643	25.	25.	0.	.0065857	.06475	6.658833	0	
050241	0	C	2219.7806	566.14	-1.	.09491	6.75	8.75	0.	.005423	.06475	31.65883	0	
050251	0	C	2216.6247	551.79	-1.	.164643	25.	25.	0.	.0065857	.06475	6.658833	0	
050261	0	C	2215.3569	544.	-1.	.096644	5.588	5.588	0.	.017295	.14839	1.323333	0	
050271	2	C	2216.0868	544.	-1.	.106591	10.42333	10.42333	0.	.009764	.1115	-9.1	0	
050281	2	C	2215.0709	544.	-1.	.084115	6.24583	8.24583	0.	.009764	.1115	-9.1	0	
050291	0	C	2300.988	544.	-1.	.02934	.8963	.8963	0.	.032735	.204156	-.85417	0	
050301	0	C	2281.6807	544.	-1.	.019236	.1115	.1115	0.	.009764	.1115	-.05575	0	
050311	0	C	2261.2619	544.	-1.	.019086	.1115	.1115	0.	.009764	.1115	-.05575	0	
050321	0	C	2280.605	544.	-1.	.036843	.1115	.1115	0.	.009764	.1115	-.05575	0	
050331	0	C	2251.0243	610.	-1.	.13591	8.8596	8.8596	0.	.001534	1.892	-3.2608	0	
050341	5	C	2280.4049	544.	-1.	.722327	18.9075	18.9075	0.	.0342	.1388	-17.9075	0	
050342	17													
050351	0	C	2278.4465	544.	-1.	.3853	.9696	.9896	0.	.3893	.293	-18.8971	0	
050361	0	C	2276.4035	530.	-1.	.080457	1.64584	1.64584	0.	.049209	.0859	-17.9075	0	
050362	17													
050371	0	C	2250.1776	610.	-1.	.05296	14.3028	14.3028	0.	.003703	.27452	-3.2608	0	
050381	3	C	0.525.26	.0176	7.	15.52	9.678	0.	.04	.042	2.495	0		
* BUBBLE-RISE MODEL DATA *														
060013	C	-2.												
060021	C	3.												
060031	C	.2747	24.34											
060041	C	.2766	3.79											
060051	C	.8	-1.											
* TIME-DEPENDENT VOLUME DATA FOR PSS TANK *														
070100	4													
070101	330.	43.5	0.	0.	5.45									

0000000000	1111111111	2222222222	3333333333	4444444444	5555555555	6666666666	7777777777	8888888888	9999999999
1234567890	1234567890	1234567890	1234567890	1234567890	1234567890	1234567890	1234567890	1234567890	1234567890

1215 061

POOR ORIGINAL

TABLE A-IV (contd)

CCCCCCCC011111111112222222222233333333333444444444445555555555566666666666777777777778
 12345678901234567890123456789012345678901234567890123456789012345678901234567890

070102	1130	.	14.5	0.	0.	5.45
C7C1C3	2000	.	14.5	C.	C.	5.45
** JLNCTICN DATA **						
CEC0111	36	1	C	C		25.79
CEC021	7	14	C	C		0.
CEC031	6	30	C	C		0.
CEC041	9	10	C	C		0.
CEC051	1	2	C	C		25.79
CEC061	2	3	C	C		25.79
CEC071	3	4	C	C		25.79
CEC081	4	10	C	C		19.335
CEC091	10	11	C	C		19.335
CEC101	11	12	C	C		19.335
CEC111	12	13	C	C		19.335
CEC121	13	14	C	C		19.335
CEC131	14	15	C	C		19.335
CEC141	15	16	C	C		19.335
CEC151	16	17	C	C		19.335
CEC161	17	18	C	C	0	19.335
CEC171	18	19	C	C	0	19.335
CEC181	19	20	C	C	0	19.335
CEC191	20	21	C	C	0	6.45
CEC201	21	22	C	C	0	6.45
CEC211	22	23	C	C	0	6.45
CEC221	23	24	C	C	0	6.45
CEC231	24	25	C	C	0	6.45
CEC241	25	26	C	C	0	6.45
CEC251	26	27	C	C	0	6.45
CEC261	27	28	C	C	0	6.45
CEC271	28	29	C	C	0	6.45
CEC281	29	30	C	C	0	6.45
CEC291	30	31	C	C	0	6.45
CEC301	31	32	C	C	0	0.
CEC311	32	33	C	C	0	0.
CEC321	33	34	C	C	0	0.
CEC331	34	35	C	C	0	0.
CEC341	35	36	C	C	0	25.79
CEC351	36	37	C	C	0	25.79
CEC361	37	38	C	C	0	0.
CEC371	38	39	C	C	0	0.
CEC381	39	40	C	C	0	0.
CEC391	40	41	C	C	0	0.
CEC401	41	42	C	C	0	0.
CEC411	42	43	C	C	0	0.
CEC421	43	44	C	C	0	6.45
CEC431	44	45	C	C	0	-1.894
CEC441	45	46	C	C	0	-1.894
CEC451	46	47	C	C	0	0.
CEC461	47	48	C	C	0	0.631
CEC471	48	49	C	C	0	-0.631

CCCCCCCC011111111112222222222233333333333444444444445555555555566666666666777777777778
 12345678901234567890123456789012345678901234567890123456789012345678901234567890

1216 062
 POOR ORIGINAL

TABLE A-IV (contd)

000000000111111111122222222223333333333344444444445555555555666666666677777777778
 12345678901234567890123456789012345678901234567890123456789012345678901234567890

080442 .007 15.4 1. 3350. 3350. 1 5 0 -2 .0472 0. 0 0 0. 0
 080452 .021 15.4 0. .752 .39 0 5 2 -2 .0472 0. 0 0 0. 0
 080462 .004 10. 0. .752 .39 1 5 2 3 .0797 0. 0 0 0. 0
 080472 .007 48. 1. 3350. 3350. 1 5 2 3 .0797 0. 0 0 0. 0
 080482 .007 48. 0. .752 .39 0 5 2 -2 .0472 0. 0 0 0. 0
 080492 .004 99 0. 0. .752 .39 1 5 2 3 .0797 0. 0 0 0. 0
 080502 .004 99 0. 0. .752 .39 1 5 2 3 .0797 0. 0 0 0. 0
 080512 .004 99 0. 0. .752 .39 1 5 2 3 .0797 0. 0 0 0. 0
 080522 .004 99 0. 0. .752 .39 1 5 2 3 .0797 0. 0 0 0. 0
 080532 .012 2.5 0. .752 .39 1 5 2 3 .155 0. 0 0 0. 0
 080542 .004 10. 0. .752 .39 1 5 2 3 .0797 0. 0 0 0. 0

** STAGNATION OPTION **

082000 0
 ** HENRY-FALSKE-HEM CRITICAL FLOW MODEL **

082003 1. 1. 1. .02
 ** INTACT LOOP PUMP DATA **
 090011 11 2 1 0 3500. 0.8022 267.2 440.
 090012 101. 38.3 62.3 0. 0. 8.72
 ** BROKEN LOOP PUMP DATA **
 090021 22 2 1 0 15250.0 1.1022 51.3 261.
 090022 2.20 .22 62.3 C. 0.
 ** PUMP HEAD MULTIPLIER CURVE **
 091001 -11 0.0 0.0 0.1 0.0 0.15 0.05 0.24 0.8
 091002 0.3 0.96 0.4 0.98 0.6 0.97 0.8 0.9
 091003 0.9 0.8 0.96 0.5 1.0 0.0
 ** PUMP TORQUE MULTIPLIER CURVE **
 092001 -9 0.0 -0.17 0.0001 -0.17 0.006 0.0 0.1 0.0
 092002 0.15 0.15 0.24 0.56 0.8 0.56 0.96 0.45
 092003 1.0 0.0

** PUMP SPEED VS TIME DATA (INTACT LOOP PUMP) **

098011 3 10 0. 2807.70 10. 1544.24 20. 1052.89
 098012 30. 786.16 40. 659.81 50. 603.66 60. 561.54
 098013 120. 280.77 130. 0.0 9000. 0.0

** PUMP SPEED VS TIME DATA (BROKEN LOOP PUMP) **

098021 3 10 0. 16808.55 10. 9244.70 20. 6303.21
 098022 30. 4706.39 40. 3950.01 50. 3613.84 60. 3361.71
 098023 120. 1680.86 130. 0.0 9000. 0.0

** PUMP CURVE INPUT INDICATOR **

100000 16 16 0 16
 ** SINGLE-PHASE PUMP HEAD HOMOLOGOUS CURVE (INTACT LOOP) **

101011 1 1 -2 0.0 1.2 1.0 1.0 0.5 0.0
 101021 1 2 -5 0.0 -0.35 0.3 -0.2 0.5 0.0
 101031 1 3 -5 0.0 0.545 1.0 1.0 -0.6 1.375
 101041 1 4 -6 -0.4 1.375 0.0 1.2 -0.6 0.95
 101051 1 5 -3 -0.4 0.83 -0.8 1.15 -0.6 0.725
 101061 1 6 -5 0.0 0.975 0.5 1.35 1.0 1.95
 101071 1 6 -5 0.0 0.725 0.2 0.725 0.4 0.8
 101082 0.0 1.023 1.0 1.95

000000000111111111122222222223333333333344444444445555555555666666666677777777778
 12345678901234567890123456789012345678901234567890123456789012345678901234567890

POOR ORIGINAL

TABLE A-IV (contd)

0000000001111111111222222222233333333333344444444445555555555666666666677777777778
 12345678901234567890123456789012345678901234567890123456789012345678901234567890

101071	7	-3	-1.0	0.175	-C.50	0.65	0.0	0.975	
1C1C81	1	8	-5	-1.0	0.175	-0.75	-0.15	-0.55	-0.3
1C1C82				-0.275	-0.4	C.0	-0.35		
** SINGLE-PHASE PUMP TORQUE HOMOLOGOUS CURVE (INTACT LOOP) **									
1C1C91	2	1	-6	C.0	0.54	C.2	0.59	0.4	0.65
1C1C92				0.6	0.77	C.8	0.95	0.9	0.98
1C1C93				0.95	0.96	1.0	0.87		
1C11C1	2	2	-8	C.0	-0.15	C.2	0.02	0.4	0.22
1011C2				0.6	0.46	C.8	0.71	0.9	0.81
1C11C3				0.95	0.65	1.0	0.67		
1C1111	2	3	-6	-1.0	0.62	-0.8	0.63	-0.6	0.53
1C1112				-0.4	0.46	-C.2	0.49	-0.0	0.54
1C11121	2	4	-6	-1.0	0.62	-0.8	0.53	-0.6	0.46
1C11122				-0.4	0.42	-C.2	0.39	-0.0	0.36
1C11131	2	5	-7	C.0	-C.63	C.2	-0.51	0.4	-0.16
1C11132				0.6	-C.29	C.8	-0.20	0.9	-0.16
1011133				1.0	-0.13				
1C11141	2	6	-6	0.0	0.36	0.2	0.32	0.4	0.27
1C11142				0.6	0.18	0.8	0.05	1.0	-0.13
1C11151	2	7	-6	-1.0	-1.44	-C.8	-1.25	-0.6	-1.08
1C11152				-0.4	-0.92	-C.2	-0.77	0.0	-0.63
1C11161	2	8	-6	-1.0	-1.44	-C.8	-1.12	-0.6	-0.79
1C11162				-0.4	-0.52	-C.2	-0.31	0.0	-0.15
** SINGLE-PHASE PUMP HEAD HOMOLOGOUS CURVE (BROKEN LOOP) **									
1C2C11	1	1	-5	C.0	1.782	C.297	1.906	0.555	1.625
1C2C12				0.892	1.187	1.0	1.0		
1C2C21	1	2	-4	0.0	-1.636	C.682	C.0	0.75	0.296
1C2C22				1.0	1.0				
1C2C31	1	3	-5	-1.0	1.5	-C.8	1.275	-0.6	1.375
1C2C32				-C.4	1.375	C.0	1.2		
1C2C41	1	4	-6	-1.0	1.5	-C.8	1.15	-0.6	0.95
1C2C42				-0.4	0.83	-C.2	0.775	0.0	0.725
1C2C51	1	5	-3	0.0	0.975	C.5	1.35	1.0	1.95
1C2C61	1	6	-5	0.0	0.725	C.2	0.225	0.4	0.6
1C2C62				0.6	1.025	1.0	1.95		
1C2C71	1	7	-3	-1.0	0.175	-C.50	0.65	C.0	0.975
1C2C81	1	8	-5	-1.0	0.175	-C.75	-0.15	-0.55	-0.3
1C2C82				-0.275	-0.4	C.0	-0.35		
** SINGLE-PHASE PUMP TORQUE HOMOLOGOUS CURVE (BROKEN LOOP) **									
1C2C91	2	1	-6	C.0	0.54	C.2	0.59	0.4	0.65
1C2C92				0.6	0.77	C.8	0.95	0.9	0.98
1C2C93				0.95	0.96	1.0	0.87		
1C21C1	2	2	-8	C.0	-0.15	C.2	0.02	0.4	0.22
1C21C2				0.6	0.46	C.8	0.71	0.9	0.81
1C21C3				0.95	0.65	1.0	0.67		
1C2111	2	3	-6	-1.0	0.62	-0.8	0.66	-0.6	0.53
1C2112				-0.4	0.46	-C.2	0.49	-0.0	0.54
1C2121	2	4	-6	-1.0	0.62	-0.8	0.53	-0.6	0.46
1C2122				-0.4	0.42	-C.2	0.39	-0.0	0.36
1C2131	2	5	-7	0.0	-C.63	C.2	-0.51	0.4	-0.16

0000000001111111111222222222233333333333344444444445555555555666666666677777777778
 1234567890123456789012345678901234567890123456789012345678901234567890

1216 065
 POOR ORIGINAL

TABLE A-IV (contd)

CCCCCCCCO11111111112222222222333333333344444444445555555555666666666677777777778
 1234567890123456789012345678901234567890123456789012345678901234567890

150441 30 C 14 C 1 0 0 .650067 C. .019536 .1115 0. .1115 C. 1.97 0. 0. .1115
 150451 32 C 14 0 1 C C 1.321752 0. .C3742 .1115 0. .1115 C. 3.77333 0. 0. .1115
 ** S.G. SECONDARY NATURAL CONVECTION CARDS **

150134
 150144
 150154
 150164
 150174
 150184
 150194
 150204
 ** CCRF FEAT SLAB DATA CARD **
 16001C 2 6 1C 0. .C2935 C. 0.
 16002C 2 6 1C C. .C2902 C. 0.
 16003C 2 6 1C C. .C3978 C. 0.
 16004C 2 6 1C C. .04696 C. 0.
 16005C 2 6 1C C. .C5054 C. 0.
 16006C 2 6 1C C. .C5054 C. 0.
 16007C 2 6 1C C. .C4696 C. 0.
 16008C 2 6 1C C. .C3978 C. 0.
 16009C 2 6 1C C. .C2902 C. 0.
 16010C 2 6 1C C. .C2935 C. 0.
 160460 2 6 1C C. .C9080 C. 0.
 16047C 2 6 1C C. .13493 C. 0.
 16048C 2 6 1C C. .15724 C. 0.
 16049C 2 6 1C C. .13493 C. 0.
 16050C 2 6 1C C. .C9080 C. 0.

** FEAT SLAB GEOMETRY CARD **
 ** CORE REGION, GEOM=1, MTRL=3,4,3,1,1 **
 170101 2 5 3 1 0. .C02917 0.
 170102 C 4 4 .C06458 1.
 170103 C 3 4 .C05125 0.
 170104 C 1 4 .C01 0.
 170105 C 4 4 .C02083 0.
 ** INTACT LOOP SG TUBES, GEOM=2, MTRL=5 **
 170201 2 1 5 4 .C01675 .C04083 0.
 ** BROKEN LOOP SG TUBES, GEOM=3, MTRL=5 **
 170301 2 1 5 4 .C032375 .004083 0.
 ** BROKEN LOOP SG, GEOM=4, MTRL=1 **
 170401 2 1 1 5 .C032375 .1667 C.
 ** LOWER PLENUM WALLS, GEOM=5, MTRL=1,2,1 **
 170501 2 3 1 2 .C06254 .C0833 0.
 170502 C 2 1 3 .C0417 C.
 170503 C 1 1 3 .16667 C.
 ** COKE KCU EXTENSIONS, GEOM=6, MTRL=7,3,1,1 **
 170601 2 4 7 1 C. .C104167 0.
 170602 C 3 1 .C04083 C.
 170603 C 1 1 .C01 C.
 170604 C 1 1 .C02083 C.
 ** MIXER BOX, GEOM=7, MTRL=1,2,1 **

*BROM NITRIDE
 *CONSTANTAN
 *BROM NITRIDE
 *316 STAINLESS STEEL
 *316 STAINLESS STEEL
 *INCONEL 600
 *INCONEL 600
 *316 STAINLESS STEEL
 *316 STAINLESS STEEL
 *AVERAGE 2-PHASE
 *316 STAINLESS STEEL
 *COPPER (CA 102)
 *BROM NITRIDE
 *316 STAINLESS STEEL
 *316 STAINLESS STEEL

0000000001111111111222222222333333333344444444445555555555666666666677777777778
 1234567890123456789012345678901234567890123456789012345678901234567890

POOR ORIGINAL

TABLE A-IV (contd)

C00000001111111111222222222222333333333333444444444444555555555555666666666666777777777778		123456789012345678901234567890123456789012345678901234567890					
180506		1100.	13.6	\$	INCCNEL	600	
180601	-E	250.	22.875	\$	GRAFOIL		
180602		500.	22.458	\$	GRAFOIL		
180603		750.	22.083	\$	GRAFOIL		
180604		1000.	21.633	\$	GRAFOIL		
180605		1250.	21.142	\$	GRAFOIL		
180606		1500.	20.683	\$	GRAFOIL		
180607		2000.	20.167	\$	GRAFOIL		
180608		3000.	19.750	\$	GRAFOIL		
180701	-4	32.	22.400	\$	COPPER	CA 102	
180702		212.	22.180	\$	COPPER	CA 102	
180703		572.	22.120	\$	COPPER	CA 102	
180704		932.	22.070	\$	COPPER	CA 102	
** VOLUMETRIC HEAT CAPACITY DATA							
190101	-4	400.	61.3	\$	316L	STAINL	SS
190102		600.	64.6	\$	316L	STAINL	SS
190103		800.	67.1	\$	316L	STAINL	SS
190104		1000.	69.35	\$	316L	STAINL	SS
190201	-2	212.	1.00	\$	AVERA	GE	PHAS
190202		572.	64.5	\$	AVERA	GE	PHAS
190301	-7	400.	46.3	\$	BORCN	NITR	IDE
190302		800.	54.6	\$	BORCN	NITR	IDE
190303		1200.	58.3	\$	BORCN	NITR	IDE
190304		1600.	60.5	\$	BORCN	NITR	IDE
190305		2000.	61.4	\$	BORCN	NITR	IDE
190306		2400.	62.5	\$	BORCN	NITR	IDE
190307		3400.	62.5	\$	BORCN	NITR	IDE
190401	-7	212.	56.	\$	CONST	ANTAN	
190402		572.	61.	\$	CONST	ANTAN	
190403		932.	67.	\$	CONST	ANTAN	
190404		1472.	73.	\$	CONST	ANTAN	
190405		2152.	78.	\$	CONST	ANTAN	
190406		2552.	84.	\$	CONST	ANTAN	
190407		3000.	90.	\$	CONST	ANTAN	
190501	-2	100.	57.225	\$	INCCNEL	600	
190502		1000.	57.225	\$	INCCNEL	600	
190601	-5	80.4	11.900	\$	GRAFOIL		
190602		170.4	14.700	\$	GRAFOIL		
190603		260.4	17.150	\$	GRAFOIL		
190604		350.4	19.600	\$	GRAFOIL		
190605		440.4	21.250	\$	GRAFOIL		
190606		530.4	22.400	\$	GRAFOIL		
190607		620.4	23.800	\$	GRAFOIL		
190608		710.4	25.200	\$	GRAFOIL		
190609		800.4	26.320	\$	GRAFOIL		
190701	-2	100.	51.336	\$	COPPER	CA 102	
190702		600.	51.336	\$	COPPER	CA 102	

* CHANGES FOR MOD-1 1.0 L. PUMP SUCTION PIPE

C00000001111111111222222222222333333333333444444444444555555555555666666666666777777777778
 12345678901234567890123456789012345678901234567890123456789012345678901234567890

~~1215 073~~
 POOR ORIGINAL

TABLE A-IV (contd)

00000000011111111112222222222333333333344444444455555555566666666677777777778
 12345678901234567890123456789012345678901234567890123456789012345678901234567890

* 50161 2 C 2213.2370 544. -1. .1915 4.8678 4.8678 0 .C3755 .21867 -3.457 0
 * 50171 2 C 2212.8198 544. -1. .2140 5.6990 5.6990 C .C3755 .21867 -3.457 0
 * 80151 16 17 C C 16.11 .C3755 -3.348 C. 1.209 1.209 1 5 2 0 0. C. 0 0 0. 0

* TEMPERATURE BALANCE
 * CORE SECONDARY VOLUMES
 220200 36 2

* I.L. S.G.
 220100 11 12 13 14 38 15 43 44

* B.L. S.G.
 220110 22 23 24 25 20 26 46 47

* CORE FLOW PATH
 220210 1

* S.G. - CORE
 220261 15 16 17 18 19 34 35 36 32 31 30 29 28 27 26

* CORE - S.G.
 220281 2 3 4 10 11 21 22

* I.L. PUMP - S.G.
 220300 16 17 18 15

* B.L. PUMP - S.G.
 220301 29 28 27 26

* PRESSURE BALANCE
 * PARALLEL FLOW PATHS
 22031X NONE

* DEAD END FLOW PATHS
 220320 4
 220321 33
 220322 34
 220323 32

* MAIN FLOW LOOP
 220400 4 10 11 12 13 14 15 16 17 18
 220401 4 3 2 1 36 35 34 19 18

* NON MAIN FLOW LOOP
 220402 4 21 22 23 24 25 26 27 28 29
 220403 34 32 31 30 29

* NEGATIVE RESIDUAL TURNOFF
 220408 1

00000000011111111112222222222333333333344444444455555555566666666677777777778
 12345678901234567890123456789012345678901234567890123456789012345678901234567890

POOR ORIGINAL

APPENDIX B
RELAP4 MODEL FOR AUDIT CALCULATION

077

APPENDIX B

RELAP4 MODEL FOR AUDIT CALCULATION

The nodalization diagram for the RELAP4/MOD7 model used for the Westinghouse PWR 2.1% cold-leg break calculation is shown in Figure B-1. The model includes 40 control volumes and 47 junctions. One control volume is used to represent the lower plenum, one volume to represent the core mixer box, three volumes to represent the core, and one volume to represent the upper plenum. Table B-I provides physical descriptions of the control volumes used in the model. Table B-II describes the junctions used in the model which connect the control volumes. Fill junctions are used to represent the intact and broken loop injection systems and steam generator secondary water supplies.

A total of 21 heat slabs are used to represent heat conducting solids in contact with the coolant in the core, steam generators, and reactor vessel. The fuel rods are represented by 6 axial heat slabs of equal length.

Table B-III lists the more significant code analytical options used in this calculation, such as heat transfer correlations, vertical slip, and bubble rise model.

B-3




Fig. B-1. RELAP4/MOD7 mode: for Westinghouse PWR.

1215 076
POOR ORIGINAL

TABLE B-I

RELAP4/MOD7 MODEL CONTROL VOLUME DESCRIPTION FOR PWR

<u>Control Volume</u>	<u>Description</u>
1	Intact loop hot leg
2	Intact loop steam generator inlet plenum
3, 4, 5, 6	Intact loop steam generator tube bundle
7	Intact loop steam generator outlet plenum
8	Intact loop pump suction - downflow
9	Intact loop pump suction - upflow
10	Intact loop pump
11, 12	Intact loop cold leg
13	Broken loop hot leg
14	Broken loop steam generator inlet plenum
15, 16, 17, 18	Broken loop steam generator tube bundle
19	Broken loop steam generator outlet plenum
20	Broken loop pump suction - downflow
21	Broken loop pump suction - upflow
22	Broken loop pump
23	Broken loop pump discharge and break assembly
24	Broken loop cold leg
25	Intact loop steam generator secondary
26	Broken loop steam generator secondary
27	Pressurizer
28	Pressure suppression vessel
29	Intact loop accumulator
30	Broken loop accumulator
31, 32, 33	Core
34	Inlet annulus
35	Downcomer
36	Lower plenum
37	Core mixer box
38	Upper plenum
39	Upper head
40	Core baffle region

1216 077

TABLE B-II

RELAP4/MOD7 MODEL JUNCTION DESCRIPTION FOR PWR

<u>Junction</u>	<u>Description</u>
1	Intact loop hot leg, intact loop steam generator inlet plenum
2	Intact loop steam generator inlet plenum, intact loop steam generator tube bundle
3, 4, 5	Intact loop steam generator tube bundle junctions
6	Intact loop steam generator tube bundle, intact loop steam generator outlet plenum
7	Intact loop steam generator outlet plenum, intact loop pump suction - downflow
8	Intact loop pump suction - downflow, intact loop pump suction - upflow
9	Intact loop pump suction - upflow, intact loop pump
10	Intact loop pump, intact loop cold leg
11	Intact loop cold leg junction
12	Broken loop hot leg, broken loop steam generator inlet plenum
13	Broken loop steam generator inlet plenum, broken loop steam generator tube bundle
14, 15, 16	Broken loop steam generator tube bundle junctions
17	Broken loop steam generator tube bundle, broken loop steam generator outlet plenum
18	Broken loop steam generator outlet plenum, broken loop pump suction - downflow
19	Broken loop pump suction - downflow, broken loop pump suction - upflow
20	Broken loop pump suction-upflow, broken loop pump
21	Broken loop pump, broken loop pump discharge and break assembly
22	Broken loop discharge and break assembly, broken loop cold leg

1216 078

TABLE B-II (contd)

<u>Junction</u>	<u>Description</u>
23	Broken loop pump discharge and break assembly, pressure suppression vessel
24	Intact loop accumulator, intact loop cold leg
25	Broken loop accumulator, broken loop pump discharge and break assembly
26	Pressurizer, intact loop hot leg
27	Intact loop cold leg, inlet annulus
28	Broken loop cold leg, inlet annulus
29	Inlet annulus, downcomer
30	Core mixer box, core
31, 32	Core junctions
33	Core, upper plenum
34	Downcomer, lower plenum
35	Inlet annulus, core baffle region
36	Core baffle region, core mixer box
37	Lower plenum, core mixer box
38	Upper head, upper plenum
39	Inlet annulus, upper head
40	Upper plenum, broken loop hot leg
41	Upper plenum, intact loop hot leg
42	Intact loop steam generator main and auxiliary feedwater
43	Intact loop steam generator discharge
44	Intact loop steam generator relief valve
45	Broken loop steam generator main and auxiliary feedwater
46	Broken loop steam generator discharge
47	Broken loop steam generator relief valve

TABLE B-III

MODELING OPTIONS FOR PWR CALCULATIONS

1. MVMIX = 0 (compressible flow with momentum flux) is used at all junctions, except that MVMIX = 3 (incompressible flow with no momentum flux) is used at junctions between the vessel and hot or cold legs, pressurizer and accumulator junctions, core bypass paths and all fill junctions.
2. Vertical slip is used at all vertical junctions in the model except in the steam generator tubes.
3. Wilson hubble rise is used in all vessel volumes (except bypass volume), pressurizer, and pump suction volumes. (Bubble gradient = 0.8). Complete phase separation is modeled in the accumulator. A constant bubble rise velocity and hubble gradient are used in the steam generator secondaries. The values are code calculated to achieve an initial energy balance.
4. Critical flow is modeled using the Henry-Fauske/Moody option. A multiplier of 1.0 is applied to both Henry-Fauske (subcooled) and Moody (saturated).
5. Core heat transfer is calculated with the default and/or recommended options for the RELAP4/MOD6 Update 4 code. These are (1) use of HTS² heat transfer surface, (2) CHF calculated with recommended CHF correlations, (3) Transition boiling calculated with modified Tong-Young correlation, and (4) film boiling calculated with the Condie-Bengston III film boiling correlation. The recommended CHF correlations are the W-3 correlation for the subcooled regime, Hsu and Beckner's modified W-3 correlation for saturated high flow and Smith and Griffith's modified Zuber for saturated low flow regime.

1216 080

TABLE B-III (contd)

6. The enthalpy transport model is used to initialize the calculation but is not used during the transient.
 7. The new slip velocity model developed for RELAP4/MOD7 is utilized. The new model employs a flow regime dependent correlation which results in a more accurate calculation, of interphase slip velocities.
 8. The RELAP4/MOD7 self-initialization routine is used to effect initial system pressure and energy balances.
 9. Steam generator secondaries utilize the natural convection option for heat transfer.
-