

J. T. Collins, Chief, Effluent Treatment Systems Branch, DSE  
Thru: L. G. Hulman, Chief, Hydrology-Meteorology Branch, DSE

ACCEPTANCE REVIEW OF 10 CFR PART 50, APPENDIX I SUBMITTAL

PLANT NAME: Three Mile Island 1 & 2  
DOCKET NUMBER: 50-289, 50-320

We have reviewed the information submitted on the subject plant to comply with the provisions of Appendix I to 10 CFR Part 50. No information was provided concerning liquid pathways. The average blowdown rate is about 40 cfs and may be sufficient for use with our previously agreed to "first-cut" guidelines. However, if additional dilution factors and travel times are required, please let us know as soon as possible so that our analyses can be initiated without undue delay. There should be sufficient information in the SAR and ER to determine more refined dilution factors and travel times, however, depending on the degree of analysis required, more information may be needed.

Distribution:

Docket File (50-289, 50-320)

NRR Rdg

HMB Rdg

DSE Rdg

William S. Bivins, Leader  
Hydrology-Meteorology Branch  
Division of Site Safety and  
Environmental Analysis

cc: R. Ballard  
W. Kreger  
T. Johnson  
R. Gotchy

POOR ORIGINAL

1585 356

7911 120 535 P

OFFICE	DSE:HMB	DSE:HMB	DSE:HMB			
SURNAME	TJohnson:sb	WBivins	LGHulman			
DATE	7/9/76	7/9/76	7/ 76			