

TENNESSEE VALLEY AUTHORITY

CHATTANOOGA, TENNESSEE 37401

716 Edney Building

November 7, 1979

Mr. James P. O'Reilly, Director
U.S. Nuclear Regulatory Commission
Office of Inspection and Enforcement
Region II
101 Marietta Street, Suite 3100
Atlanta, Georgia 30303

Dear Mr. O'Reilly:

TENNESSEE VALLEY AUTHORITY - BROWNS FERRY NUCLEAR PLANT UNIT 1 - DOCKET
NO. 50-259 - FACILITY OPERATING LICENSE DPR-33 - REPORTABLE OCCURRENCE
REPORT BFRO-50-259/7927

The enclosed report provides details concerning Surveillance Instruction
4.5.E.1.d which was being run when high-pressure coolant injection
system turbine tripped due to a failed rupture disc in the turbine
exhaust line with the unit in steady-state power of 98 percent. This
report is submitted in accordance with Browns Ferry unit 1 Technical
Specification 6.7.2.b.2.

Very truly yours,

TENNESSEE VALLEY AUTHORITY

J. K. Calhoun
Director of Nuclear Power

Enclosure (3)

cc (Enclosure):

Director (3)
Office of Management Information and Program Control
U.S. Nuclear Regulatory Commission
Washington, DC 20555

Director (40)
Office of Inspection and Enforcement
U.S. Nuclear Regulatory Commission
Washington, DC 20555

R. F. Sullivan, NRC Inspector, Browns Ferry

1320 069

7911130257