



Federal Energy Regulatory Commission
 Nuclear Regulatory Commission
 Washington, D.C. 20541

October 24, 1979
 CPY-455-79



Mr. R. H. Engelken, Director
 Nuclear Regulatory Commission, Region V
 1990 North California Blvd.
 Walnut Creek, California 94596

Dear Sir:

In accordance with the Trojan Plant Operating License, Appendix B, US NRC Technical Specifications, Paragraph 2.2.4, attached is a report concerning a situation where the plant effluent pH was above the limit of 9.0 for approximately three minutes on Thursday, October 18, 1979.

Sincerely,

C. P. Yundt
 General Manager

CPY/JCP:ga

Attachment

c: LER Distribution List

*CO3
 5/11*

1320 075

7911130 260

P

7/3/80