

FEB 20 1974

Docket Nos. 50-289/320

V. A. Moore, Assistant Director for LWR's Group 2, L

RESPONSE TO TECHNICAL ASSISTANCE REQUEST, THREE MILE ISLAND NUCLEAR STATION, UNITS 1 & 2, REVIEW OF INDUSTRIAL SECURITY PLAN (ORB-1-70)(TAR-769)

Licensee: Metropolitan Edison Co.  
Licensing Stage: Post-OL  
Cognizant Project Branch and LPM: LWR 2-3, R. Bernero  
Technical Review Branch Involved: L:OSB  
Requested Completion Date: 3/1/74  
Review Status: Additional Information Requested

We have reviewed the security plan for the Three Mile Island station submitted by the licensee as Revision 3 dated 2/12/73, and Revision 4 dated 1/7/74. The attached report identifies specific omissions or subject areas which appear to be unacceptable departures from our position as stated in Regulatory Guide 1.17 of June 1973. The licensee should submit a revision to the security plan which will correct the deficiencies and conform to the Regulatory Guide. The enclosure is labeled Official Use Only, as a result of the review of a document considered by the licensee as subject to Section 2.790 of 10CFR2.

151

Victor Stello, Jr., Assistant Director  
for Reactor Safety  
Directorate of Licensing

Enclosure:  
As stated

cc:  
S. Hanauer  
J. Hendrie  
A. Giambusso  
W. McDonald  
A. Schwencer  
R. Bernero  
R. W. Houston  
C. R. Van Niel  
S. Varga

DISTRIBUTION:  
Docket  
L Rg. File  
OSB Rdg. File  
Elva Leins  
VStello

POOR ORIGINAL

1596 341

7911180520 F

OFFICE	L:OSB	L:OSB	KXABXSR	L:AD/RS		
SURNAME	CRVanNiel:1d	RWHouston		VStello		
DATE	2/19/74	2/19/74		2/22/74		

Three Mile Island Nuclear Station

Docket Nos. 50-289/320

Industrial Security Plan

1. The Plan does not indicate that the security force is armed. It is our position that the security force be armed.
2. Section 3.2 states that a surveillance system alarm will annunciate in the control room only if the retransmit switch is placed in the remote position. This does not appear to satisfy our position as stated in Regulatory Guide 1.17 at Section 1b, that all security alarms annunciate in two continuously manned stations.
3. The alarms on the exterior plant doors should be self-checking and tamper indicating. Indicate the location of the exterior doors on Figure 1.
4. The perimeter of the owner controlled area should be marked by signs as specified in ANSI N18.17 at Section 3.2.
5. Specify that visitors will be required to register the specific information listed in ANSI N18.17 at Section 3.3.2.1.
6. Describe the method for review, approval, and revision of the security plan and procedures as specified in ANSI N18.17 in Sections 4.1 and 4.2.
7. Do the employee screening practices listed in Section 7 also apply to the members of the security force? If not, provide such information.
8. It is our position that drills and tests be conducted to prove the effectiveness of the security measures. Include a section on this subject in the Plan.

1596 342