NRC FORM 366
(7-77)

U.S. NUCLEAR REGULATORY COMMISSION

LICENSEE EVENT REPORT

CONTROL BLOCK: (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 | I L Z I S 2 (7) | 0 0 - 0 0 0 0 0 - 0 0 (3) | 4 1 1 1 1 (4) | (5)
LICENSEE CODE (14) LICENSE NUMBER (25) LICENSE TYPE (30) CAT (58)

CON'T
01 | REPORT SOURCE M (6) | 0 5 0 0 0 3 0 4 (7) | 1 0 1 8 7 9 (8) | 1 1 0 1 7 9 (9)
(60) (61) DOCKET NUMBER (68) (69) EVENT DATE (74) (75) REPORT DATE (80)

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 Indications of cracking on Unit 1 steam generator feedwater nozzles
03 were identified on 10/16/79. Unit 2 was shutdown on 10/27/79.
04 Indications of cracking on Unit 2 feedwater nozzles were identified
05 on 10/29/79. The health and safety of the public has not been
06 affected.
07
08

09 SYSTEM CODE H H (11) | CAUSE CODE X (12) | CAUSE SUBCODE Z (13) | COMPONENT CODE P I P E X X (14) | COMP. SUBCODE Z (15) | VALVE SUBCODE Z (16)

(17) LER/RO REPORT NUMBER: EVENT YEAR 7 9 | — | SEQUENTIAL REPORT NO. 0 5 0 | / | OCCURRENCE CODE 0 1 | REPORT TYPE T | — | REVISION NO. 0

ACTION TAKEN X (18) | FUTURE ACTION Z (19) | EFFECT ON PLANT B (20) | SHUTDOWN METHOD N (21) | HOURS 1 2 0 0 (22) | ATTACHMENT SUBMITTED N (23) | NPRD-4 FORM SUB. N (24) | PRIME COMP. SUPPLIER N (25) | COMPONENT MANUFACTURER N 1 2 0 (26)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 An updated LER will be submitted 30 days following the completion
11 of the examinations and will contain the licensees resolution.
12
13
14

15 FACILITY STATUS E (28) | % POWER 0 5 0 (29) | OTHER STATUS (30) NA | METHOD OF DISCOVERY C (31) | DISCOVERY DESCRIPTION (32) Examinations per bulletin 79-13

16 ACTIVITY RELEASED Z (33) | CONTENT OF RELEASE Z (34) | AMOUNT OF ACTIVITY (35) NA | LOCATION OF RELEASE (36) NA

17 PERSONNEL EXPOSURES NUMBER 0 0 0 (37) | TYPE Z (38) | DESCRIPTION (39) NA

18 PERSONNEL INJURIES NUMBER 0 0 0 (40) | DESCRIPTION (41) NA

19 LOSS OF OR DAMAGE TO FACILITY TYPE Z (42) | DESCRIPTION (43) NA

20 PUBLICITY ISSUED N (44) | DESCRIPTION (45) NA

NRC USE ONLY

POOR ORIGINAL

1355 060

7911190 445

R. E. Shannon 312-746-2084