POOR ORIGINAL

NRC FORM 366 (7-77)

U. S. NUCLEAR REGULATORY COMMISSION

LICENSEE EVENT REPORT

EXHIBIT A

CONTROL BLOCK: (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 CARSS1 (2) 00-000-00 (3) 4111 1 (4) (5)
LICENSEE CODE — LICENSE NUMBER — LICENSE TYPE — CAT

CON'T 01 REPORT SOURCE L (6) 05000312 (7) 10 08 79 (8) 11 08 79 (9)
DOCKET NUMBER — EVENT DATE — REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 While performing the requirements of I&E Bulletin 79-14, the District
03 contracted the A/E to assist in review and analysis. On 10-8-79 and
04 10-16-79, the A/E informed the District that the as-built configuration of
05 Line 48222-18", when seismically reanalyzed, resulted in probable support
06 pipe overstresses.
07
08

09 SYSTEM CODE CJ (11) CAUSE CODE B (12) CAUSE SUBCODE A (13) COMPONENT CODE SUPORT (14) COMP. SUBCODE B (15) VALVE SUBCODE Z (16)

(17) LER RO REPORT NUMBER: EVENT YEAR 79 — SEQUENTIAL REPORT NO. 014 — OCCURRENCE CODE 01 — REPORT TYPE L — REVISION NO. 0

ACTION TAKEN F (18) FUTURE ACTION Z (19) EFFECT ON PLANT A (20) SHUTDOWN METHOD A (21) HOURS (22) 078 ATTACHMENT SUBMITTED V (23) NPRD-4 FORM SUB N (24) PRIME COMP SUPPLIER A (25) COMPONENT MANUFACTURER B130 (26)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 Design documentation and construction drawings were not in complete
11 conformance with the original seismic analyses. Two new supports were
12 installed and two support modifications were completed to correct the
13 discrepancy.
14

15 FACILITY STATUS E (28) % POWER 100 (29) OTHER STATUS (30) N/A METHOD OF DISCOVERY D (31) DISCOVERY DESCRIPTION (32) Notification from A/E

16 ACTIVITY RELEASED Z (33) CONTENT OF RELEASE Z (34) AMOUNT OF ACTIVITY (35) N/A LOCATION OF RELEASE (36) N/A

17 PERSONNEL EXPOSURES NUMBER 000 (37) TYPE Z (38) DESCRIPTION (39) N/A

18 PERSONNEL INJURIES NUMBER 000 (40) DESCRIPTION (41) N/A

19 LOSS OF OR DAMAGE TO FACILITY TYPE Z (42) DESCRIPTION (43) N/A

20 PUBLICITY ISSUED Y (44) DESCRIPTION (45) Local newspapers and wire service on 10/10.

NRC USE ONLY

NAME OF PREPARER R. W. Colombo PHONE: 916-452-3211

7911200 399