

Docket No. 50-498/79-14
50-499/79-14

Appendix B

NOTICE OF DEVIATION

Based on the results of the NRC investigation conducted on September 4-7, and 11-14, 1979, it appears that certain of your activities related to South Texas Project, Unit 1 deviate from commitments made in your Preliminary Safety Analysis Report (PSAR) as indicated below:

Appendix A of the PSAR commits to Regulatory Guide 1.88 which endorses ANSI N45.2.9-1974, "Requirements for Collection, Storage and Maintenance of Quality Assurance Records for Nuclear Power Plants."

Paragraph 3.2.6 of ANSI N45.2.9 requires that corrections or supplements to QA records shall include the date and identification of the person making such corrections or supplements.

Contrary to the above:

An Examination Check form documenting QC inspection of concrete placements CS1-12A and CS1-13A, dated November 9, 1978, contained a supplemental entry which did not include the date of entry or identification of the person making the supplemental entry.

This is a deviation.

. 1392 296

7911260

010