

YANKEE ATOMIC ELECTRIC COMPANY



Rowe, Massachusetts 01367

November 19, 1979

Mr. B. H. Grier, Director
U.S. Nuclear Regulatory Commission
Office of Inspection and Enforcement
Region I
631 Park Avenue
King of Prussia, Pennsylvania 19406

Subject: Reportable Occurrence 50-29/79-25/03L
Main Coolant Pressure Channel Setpoint Drift

Mr. Grier:

In accordance with Technical Specifications, Section 6.9.4.a, the attached Licensee Event Report is hereby submitted.

Very truly yours,

Herbert A. Autio
Plant Superintendent

LDF/amt

Enclosure:

- cc: [30] Director, Office of Inspection and Enforcement
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555
- [3] Director, Office of Management Information & Program Control
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555
- [14] NSARC Chairman
- [1] Manager of Operation Quality Assurance
Yankee Atomic Electric Company

1390 244

7911260 292

5