

APPENDIX A

NOTICE OF DEVIATION

South Carolina Electric and Gas Company  
V. C. Summer Nuclear Station, Unit 1

License No. CPPR-94

Based on the results of the NRC inspection conducted on August 13 - September 14, 1979, certain of your activities appear to deviate from your commitments to the Commission as indicated below.

Section 14.1.1.1 of the FSAR states that Phase II Preoperational Test Procedures will be approved by the Plant Manager.

Contrary to the above, the following Phase II Preoperational Test Procedures were approved by the Startup Supervisor instead of the Plant Manager:

SI-6	SI Flow Balancing Test
CS-2	Charging Pump Flow Test
RH-1	RHR Pump Flow Test
CS-1	VCT Auto Makeup and Level Control

1399 346

7911270 044