

TERA



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

OCT 15 1979

MEMORANDUM FOR: Donald Hassell, OCM  
George Eysymontt, OCM  
John Stephens, OCM  
Tom Gibbon, OCM  
Vickie Harding, OCM

FROM: Marvin R. Peterson, Acting Assistant Director  
Export/Import and International Safeguards  
Office of International Programs

SUBJECT: HEU EXPORTS TO EURATOM

Attached for your information is a copy of a July 25 letter with enclosures from EURATOM's local office to DOE.

This letter was sent to IP by the EURATOM office on October 10 and addresses the technical justifications for several pending EURATOM HEU exports. These cases, many of which require Presidential approval, are still undergoing Executive Branch review.

Marvin R. Peterson, Acting Assistant Director  
Export/Import and International Safeguards  
Office of International Programs

Attachment:  
July 25 ltr w/enclosures  
from EURATOM's local  
office to DOE

1396 113

- cc w/encl.
- R. Burnett, NMSS
- J. Becker, OELD
- J. Devine, OPE
- C. Stoiber, OGC
- J. Shea, IP
- K. Moore, IP
- T. Rehm, EDO
- K. Cohen, IP

DELEGATION OF THE COMMISSION OF THE EUROPEAN COMMUNITIES

EURATOM SUPPLY AGENCY

July 25, 1979

RECEIVED  
J.S. HFC

1979 OCT 10 PM 2 32

Dr. A. Travelli  
Associate Director  
Reactor Physics Department  
Safety Test Facility  
Argonne National Laboratory  
Argonne, Illinois 60439

EXPORT/IMPORT  
AND  
INTERNAT'L SFGROS

Dear Dr. Travelli:

Subject: Supply of HEU to European Communities' customers

Enclosed please find a letter which the Euratom supply Agency addressed to you on July 18, 1979. As you will see, the Supply Agency in this letter (namely in the 3rd paragraph of the first page and in the "summary" on page 5) is referring to the possibility "that you might have to reject some applications (of HEU export license) on the ground of insufficient technical justification".

We would like to indicate that the Supply Agency is of course completely aware of the fact that your laboratory is only in charge of making technical assessments of pending export license applications and of the data provided by the reactor operators and that it is up to the Executive Branch, based upon your technical assessment, to recommend NRC to withhold a certain application.

Please understand Supply Agency letter in this sense.

Sincerely,

*Michael Goppel*

M. Goppel

MG/JM/ajs

Enclosure: Supply Agency letter no. 43757 of 18 July 1979  
(6 pages + enclosure)

1396 114

43707  
18. VII. 1979

Argonne National Laboratory  
Applied Physics Division/RERTR Program  
Attn. A. Travelli  
9700 South Cass Avenue  
Argonne (Illinois) 60439  
U.S.A.

Subject: Supply of highly enriched uranium (HEU) to European  
Community customers

Gentlemen:

Please recall the discussions Euratom Supply Agency representatives and/or its customers had with your services at several occasions during the last months, since the U.S. adopted a new policy for HEU supplies as of late 1977 and since the Nuclear Non-Proliferation Act (NNPA) became law in March 1978.

These developments have been communicated by us to our customers; please find enclosed for your information and file copy of our corresponding circular letter AA/44/78 - 41660 of July 13, 1978.

When again discussing HEU supply problems late May 1979 in Washington and with you - via phone contacts of our Washington Delegation - we learned that in several cases of applications to export HEU pending with NRC and actually under Executive Branch review, you indicated that you might have to reject some applications on the grounds of insufficient technical justification, i.e. because of a too large HEU inventory and the potential for conversion into high(er) density fuel with "mildly (20 to 45% U-235) enriched" uranium (HEU). Such reasoning might apply for instance in the cases of

- |    |           |   |
|----|-----------|---|
| 1) | XSNM-1391 | 113 kgs of HEU for CEN's BR-2 (AG/1418) |
| 2) | XSNM-1425 | 35 kgs of HEU for GKSS' FRG-1 and -2    |
| 3) | XSNM-1428 | 3.8 kgs of HEU for CSGAE's ASTRA        |
| 4) | XSNM-1429 | 21.5 kgs of HEU for KfA's FRJ-2         |

and particularly for

- |    |           |   |
|----|-----------|---|
| 5) | XSNM-1236 | 5.7 kgs of HEU for PTB's FMRB (AG/1276) |
| 6) | XSNM-1444 | 14 kgs of HEU for Garching's FRM        |
| 7) | XSNM-1459 | 6.8 kgs of HEU for HMI's BER-II         |

Whereas the first abovementioned case (BR-2) has already been argued at your offices May 24, 1979, and you received additional data (our letter 43485 of June 1, 1979), we have now discussed the supplies for FMRB, FRM and BER-II (cases 5 thru 7 above) with our customers and the convertor/fuel manufacturer Nukem.

As a result of these discussions we want to submit the following reasoning:

A) Timing

According to our experience of the last two years it can easily take up to 18 months or more from the date of an application for a license to export HEU out of the US until such license is issued. Recent examples (last HEU export license issuance by NRC):

<u>kgs HEU</u>	<u>for</u>	<u>license N°</u> <u>XSNM-</u>	<u>date of</u> <u>application</u>	<u>date of</u> <u>issuance</u>	<u>our</u> <u>reference</u>
19.8	HFR Petten	1212	Oct 13, 1977	April 11, 1979	AG/1282
23	ILL's HFR	1232	Nov 23, 1977	Apr. 10, 79	/1400
20	HFR Petten	1238	Dec 1, 1977	" 11, 79	1402
22	KfA's FRJ-1	1241	Dec 8, 1977	" 19, 79	1309
22	Swedish R-2	1247	Dec 29, 1977	" 11, 79	1296
17	" "	1248	Dec 29, 1977	" 11, 79	1401

where the requests were deposited before or very shortly after the cut-off date of December 1, 1977 for more elaborate 'technical and economic justification' and anyhow before the NNPA became law. Even if we hope that the still rather lengthy NRC plus Executive Branch review and authorisation procedure should only become faster and more reliable experiences of the past are not encouraging to that effect and we have to take into account that our more recent applications are subject to still more thorough US administration scrutiny as required under the NNPA.

Further it has to be taken into account that only after license issuance we can proceed with the procurement of the HEU either

- a) by concluding a Short Term Fixed Commitment enriching services contract with DOE (a subsequent arrangement as per Sec. 303 of the NNPA, the time requirements for which we had not yet to test because we did not use this procurement method up to now)
- b) by concluding a contract to purchase separative work units in excess under an existing DOE toll enriching agreement, or
- c) by concluding a straight purchase contract for HEU.

This of course takes some time: apart from the preparation and execution of the necessary contractual arrangements 180 days lead time or more pass for a and b above between order and product delivery if DOE does not waive its right for such term by delivering HEU from stock 90 days after feed has been transferred as it fortunately did/does. Thus, at least four months elapse after license issuance until product delivery, which brings the total to (18+4=) 22 months.

1396 116

As you are aware transport of significant HEU quantities from the US to Europe must be subject to stringent physical protection measures. In consequence and as incited by US authorities, military air transport has been used in the recent past. For such transport there are no regular schedules, thus it can easily take 1 to 2 months bringing the total delay to  $(22 + 2 =) 24$  months.

Finally, time to convert the hexafluoride and to fabricate the fuel, dependent on the contingencies at the manufacturer's plant as well as on the regularity of supply flow, can be estimated to be about 8 months. In consequence, at least  $(24+8=)$  32 months can slip by between applying for an export license with NRC and receiving reload fuel. You will understand that our customers want a three years inventory or even a bit more to continuously operate their facility, particularly since above lead times have always been increasing since the NRC took office in January 1975.

B) Inventories

1) PTB's FMRB (XSNM-1236 of Dec. 1, 1977) - AG/1276

FMRB's actual inventory of 13 fresh 11-plate fuel elements\* will keep the reactor in operation - assuming economical fuel utilization - until mid 1982 (annual consumption 3 to 4 elements, next reloading autumn 1979), since only up to 35% burn-up can be achieved in this reactor.

In addition, a power increase from 1 to 3 MW is anticipated in order to cope with accumulating requests for higher neutron flux densities (shorter irradiation times). New 23-plate fuel will then become necessary and consumption will triple. The request for supply of new fuel was initiated early in view of past lead time experience and of the envisaged power increase: should a license to operate the reactor at 3 MW be issued earlier than expected new fuel would be needed sooner

2) Garching's FRM (XSNM-1444 of January 24, 1979)

FRM will need a fresh fuel reload at the end of 1982. The export license was applied for early because of the existing lead time experience (see above under A), but further since Savannah River (SR00) is to reprocess 16 irradiated Munich fuel elements with subsequent separative work and natural uranium component credit for reenrichment.

3) HMI's BER-II (XSNM-1459 of February 14, 1979)

BER-II also has a fresh fuel inventory to assure reactor operation at its actual 5 MW until the end of 1982. As for FRM above the license has already been applied for not only taking into account the long lead times but also since re-enrichment of feed resulting from SR00 reprocessing of 26 irradiated Berlin fuel elements is anticipated.

1396 117

\* An additional information request from DOS concerning check 1396

Further, BER-II intends to double its power to 10 MW for reasons similar to those given for FMRB (see 1 above). It is hoped to receive the corresponding permit around the end of 1981, in which case the actual fuel inventory would not last thru 1982.

C) Introduction of new MEU fuel

1) General

Please recall the draft of the Final Report of INFCE Working Group 8 (INFCE/WG8/14 of May 31, 1979) and in particular Chapter 6 "Summary and Findings" of Subgroup C - Research Reactors Final Reports as established under US Cochairmanship. Criteria for utilizing lower enriched fuel in existing research reactor are enumerated under point (3), these are reiterated by our customers. There is further under point (10) said: "... in some countries it may take five years or more after the decision of modification before the reactor is operating on the lower enriched fuel cycle ...", and under point (12): "... introduction of these fuels has to be considered as a long term objective ....".

More specifically you might want to recall that the Government of the Federal Republic of Germany - as announced during INFCE - has launched a 5 1/2 years R & D program on high density fuel, in which KfK, KfA, GKSS, Interatom, Nukem collaborate and German licensing authorities participate, which, at a cost of about 20 million DM (+ 11 million US \$) is intended to examine the use of U Alx, changes of fuel configuration (thicker plates), and sophisticated fuels on uranium silicide or nitride base.

You will further recall European collaboration in the IAEA/ Vienna Advisory Group preparing a 'Program on Research Reactor Core Conversion to Use Less Enriched Uranium instead of HEU' and its actual efforts to develop a 'Guide Book' to help research reactor operators in not highly industrialized nations to cope with the problems of uranium supply reduction.

You are finally aware (and this appears to be the most time consuming factor when addressing the problems of putting MEU into use) that no operation license for any new fuel will be issued until such has been thoroughly examined. Such tests (irradiation of small platelets in a special rig and interpretation of results) might easily take two years; thereupon operators need to test prototype elements and only after that a full core conversion can be planned in detail and executed. It is estimated that a full core conversion with U Alx fuel of 45 instead of 93% uranium - 235 might occur 5 to 6 years from now; use of other configurations (thicker plates) or exotic fuel (U<sub>3</sub>Si) at enrichments below 45% could request still more time, except where reactors are available which are not subject to normal licensing procedures.

We will not discuss here but wonder about reprocessing possibilities for new fuel.

2) Remarks from customers

Apart from the ironic sidelight that possible improvements of fuel are not used to increase flux densities thus facilitating research work but to reduce enrichment, reactor operators cannot do much at present: they might request an authorisation to operate their facility at a lower enrichment but will not receive the corresponding license until competent authorities have been satisfied concerning the safe operation (conditio sine qua non) of the installation, i.e. when R & D has resulted in satisfactory and complete results.

As to the use of MEU and apart from safety/licensing considerations, the operators' opinion can be summarised as follows:

- a) the neutron yield of the installation (at the irradiation positions) must not decrease, at least not significantly, i.e.
- b) disadvantages must be tolerable (e.g. < 5%) and that is true also for
- c) economic penalties, which are to be minimized, in particular since most operators depend on public budgets.

D) Summary


From the above explanations we hope that you are able to conclude that HEU supplies as requested must not be rejected because of insufficient technical justification: taking into account the present lead times inventories are not too large and the potential for (full core) conversion to MEU use even if principally existing can only be employed after completion of the corresponding R & D and acceptance of the results by licensing authorities. It is almost impossible to estimate the delays involved, since there are as well political considerations (public acceptance of nuclear energy, discussions of INFCE results after spring 1980), to be taken into account which we deliberately bypassed in this letter; more than 5 to 6 years from now appears to us a conservative evaluation.

Of course, all considerations above are also valid for requests (1 and 2 to 4 mentioned initially: (BR-2) GKSS' FRG-1 and -2, OSGAE's ASTRA, KFA's BR-2) as well as others from Community customers pending with US authorities, except that actual inventory data might be slightly different. But

such data should be known to you from the check lists/questionnaires submitted. We do not believe excess inventories to exist at research facilities or fuel manufacturers, therefore we believe also these other requests to be 'technically and economically justified'.

If you need any further information on above or other HEU requests, please do not hesitate to contact us.

Sincerely yours,

  
J.B. MENNICKEN  
Director General

Enclosure:

1396 120



Brussels  
JJ/ml 13. VII. 1978

Circular letter to customers of highly  
enriched uranium (HEU) of US origin

Subject: New US criteria and justification for approving exports  
(and retransfers) of HEU

This is to recall and complete earlier informations on above  
matter.

As you are aware, US AEC, then ERDA, now Department of Energy  
(DOE) was/is the only practical source of significant amounts of HEU  
for Community customers. Supply is governed by the actual EUR/US  
Additional Agreement for Cooperation of June 11, 1960, as amended, and  
in particular its Art. I Bis A:

"The enriched uranium supplied under this Agreement may con-  
tain up to twenty percent (20%) in the isotope U-235. A  
portion of the isotope U-235 so supplied may be made available  
as material containing more than twenty percent (20%) in the  
isotope U-235 when the use of such material is technically or  
economically justified".

Whereas US supply of HEU proceeded rather smoothly until 1975 and  
justification of need was furnished by fuel inventory data compiled in  
a one page check list and by an uncomplicated end use statement, world-  
wide and particularly US concern on proliferation risks associated with  
HEU supplies retarded export licensing as of that time; the then installed  
Nuclear Regulatory Commission (NRC) developed new and slower procedures to  
assess problems involved with export licensing (see our circular letters 34013  
and AA/46/75 - 35341 of April 15 and October 30, 1975 as well as AA/42/76 -  
37610 of September 24, 1976 to toll enriching customers (and members of our  
Advisory Committee)).

By Executive Order 11902 of February 2, 1976, President Ford introduced  
an U.S. Executive Branch review of export license applications prior to NRC  
action (circular letter AA/6/76 - 36123 of February 18 1976 to transporters  
of nuclear material) and retransfers of nuclear material became subject to  
similar scrutiny (circular letter AA/40/76 - 37591 of September 24, 1976).

The new US policy was further explained in an October 28, 1976,  
Presidential statement on Nuclear Export and Non-Proliferation Policy  
(circular letter AA/53/76 - 37902 of November 4, 1976); consequent delays  
were recognised by US authorities (circular letter AA/3/77 - 38500 of  
February 3, 1977 to toll enriching customers). Some exports were

1396 121

..//..

additionally detained since 1976 and in 1977 by interventions from (US) environmental organisations (see correspondence with the many customers concerned).

In context with pending applications for licenses to export HEU for use in Community facilities, US authorities in September and December 1977 made up (bilaterally) more detailed inquiries on data such as fuel inventories/core loading/operation mode and corresponding fuel consumption of such facilities. They finally published their new criteria November 20, 1977, inclusive a new check list of information required (circular letter AA/36/77 - 40295 of December 2, 1977).

Customers' reaction to this new US policy was requested (circular letter AA/10/78 - 40607 of January 31, 1978) and a meeting organised (circular letters AA/19/78 - 40894 and AA/27/78 - 41050 of March 10, 1978 and April 12, 1978). Annexed to the last referenced circular letter was an US letter of March 29, 1978, explaining further the new policy, and a revised copy of the new HEU Check List. Our latest circular letter on this matter so far (AA/36/78 - 41448 of June 16, 1978) answered some of the questions discussed at our April 10, 1978, meeting and gave further detailed information.

In the meantime, other information with impact on HEU exports (and retransfers) became available and has to be taken into account also, such as

- NRC's rules on export and import of nuclear facilities and materials (circular letters AA/18 and 35/78 - 40811 and 41397 of February 27 and June 8, 1978 and the
- Nuclear Non-Proliferation Act (NNPA) of 1978 and the procedures established by the US Executive Branch pursuant to it (circular letters AA/38 and 43/78 - 41543 and 41624 of June 28 and July 7, 1978 - see the first one for lead times in comparison with point 5, (1) - (7) of AA/36/78 cited above).

Finally, the Euratom Supply Agency had late June 1978 discussions with US authorities on the implementation of the new policies.

During these discussions it was confirmed that the new policy is employed for all applications filed since December 1977 and that therefore data as per the new check list (see AA/27/78 above) are requested.

In this context we learned that, even if sufficient information on fuel inventories is available in most pending cases, it is not yet fully conclusive - in particular sometimes reactor core data are missing - to allow specialists from Argonne National Laboratory (ANL) to evaluate the feasibility of going to lower U-235 assays in the respective facilities.


ANL staff recommended either and preferably to answer questions as per point C 5 and E of the new check list or to furnish as complete as possible data under points A, B, C, and D of the check list.

Since the check list questions are kept rather general in order to cover all aspects, ANL staff refers to a recently published questionnaire, established by the American Nuclear Society in view of editing a new directory of US research, training and test reactors, and recommends interested parties to employ it when addressing the problem of answering most check list (A, B, C, D) questions.

Please find enclosed one copy of that questionnaire.

The Euratom Supply Agency would appreciate to further receive possible comments from customers on the abovementioned issues. We shall keep you informed of any new developments.

Applications at present pending for licenses to export HEU from the US are probably best handled individually and depending on the date of the original request (before or after November/December 1977).

  
J.B. MERRICKEN  
Director General

Enclosure: Questionnaire form

1396 123

QUESTIONNAIRE FORM

RESEARCH, TRAINING AND TEST REACTOR DIRECTORY

Instructions:

1. Insert the best available information adjacent to each item.
2. Leave unknowns blank.
3. Insert not applicable in not applicable sections.
4. Insert metric units if known. Otherwise, use your most frequently used units.
5. Please enclose a reproducible copy of a reactor diagram if you have one available.

1396 124

RESEARCH, TRAINING, AND TEST REACTOR DIRECTORY

1. GENERAL

1.1 Reactor Name (Acronym)

1.2 License Number

1.3 NRC Docket Number

1.4 Reactor Address

1.5 Reactor Telephone

1.6 Reactor Owner

1.7 Reactor Operator

1.8 Reactor Administrators

1.9 Reactor Facility Staff

a. Scientific/Technical

b. Operations

c. Support

d. Normal Number of Personnel in  
Reactor Containment/Confinement

1.10 Reactor Architect/Engineer

1.11 Reactor Constructor

1.12 Organization/Country Supplying  
Nuclear Technology

1.13 Reactor Setting

1.14 Reactor Operating Status

a. Initial Criticality Date

- b. Full Power Date
- c. Operating Cycle
  
- d. Full Power Hours/Year
- e. Pulses/Year, Average Energy
- 1.15 Reactor Facility Cost
- 1.16 Annual Operating Budget

---

---

---

---

---

---

---

---

2. REACTOR

2.1 Reactor Type

---

---

---

---

2.2 Reactor Vessel

- a. Configuration
- b. Overall Dimensions
  
- c. Material
- d. Normal Operating Pressure
- e. Normal Operating Temperature

---

---

---

---

---

---

---

---

2.3 Core

- a. Volume
- b. Overall Dimensions
  
- c. Lattice Configuration
- d. Number of Elements
  - 1. Standard
  - 2. Control
- e. Maximum Number of Grid Locations That can be used for Fuel
- f. Normal Core <sup>235</sup>U Content
- g. Subdivided Core
  - 1. Number of Subdivisions
  - 2. Subdivision Differentiating Characteristics

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

3. Number of Elements per  
Subdivision

- 2.4 Containment
  - a. Type
  - b. Volume
  - c. Material
- 2.5 Moderator
- 2.6 Blanket Gas
- 2.7 Reflectors
- 2.8 Thermal Shield
- 9 Biological Shield
  - a. External Radiation Levels
- 2.10 Power Level
  - a. Normal Steady State
  - b. Pulsing
- 2.11 Normal Average Thermal Power Density
  - a. Volumetric (2.10.a/2.3.a)
  - b. Linear (2.10.a/(Number of Plates/  
Pins x Plate/Pin Length))
- 12 Normal Specific Power (2.10.a/2.3.f)
- 2.13 Reactor Control
  - a. Safety Rods
    - 1. Number
    - 2. Shape and Dimensions
    - 3. Material and Loading
    - 4. Normal Withdrawal/Insertion  
Speed
    - 5. Scram Insertion Speed
    - 6. Total Reactivity

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

7. Average Reactivity  
Addition Rate

8. Scram Mechanism

b. Regulating Rods

1. Number

2. Shape and Dimensions

3. Material and Loading

4. Normal Withdrawal/Insertion  
Speed

5. Total Reactivity

6. Average Reactivity  
Addition Rate

c. Chemical Shim Control

1. Chemical

2. Loading

3. Control Mechanism

4. Total Reactivity

d. Burnable Poison

1. Isotopes Utilized

2. Location

3. Loading

4. Total Reactivity

3. FUEL

3.1 Standard Fuel Element

a. Configuration

b. Element Dimensions

c. Overall Plate/Pin Dimensions



d. Number of Plates/Pins per Element

e. Distance Between Plate/Pin  
Centerlines

f. Active Portion of Fuel Plate/Pin

1. Dimensions

2. Composition

3.  $^{235}\text{U}$  Enrichment

4. Fissile Material Density

g. Reflector Portion of Fuel Plate/Pin

1. Composition

2. Dimensions

h. Clad

1. Composition

2. Thickness

i. Structural Material

3.2 Control Rod Fuel Element

a. Specify Differences from Standard  
Fuel Elements

3.3 Fuel Cycle

a. Criteria for Refueling

b. Frequency of Refueling

c. Normal Element Lifetime

d. Burnup

1. Average  $^{235}\text{U}$  Burnup

2. Peak  $^{235}\text{U}$  Burnup

3. Maximum Allowed  $^{235}\text{U}$  Burnup

e. Number of Elements Replaced During  
Typical Refueling

f. Spent Fuel

1. Minimum Cooling Time

2. Maximum Amount in Storage

1396 129

g. Disposition of Spent Fuel

---

h. Spent Fuel Shipping Cask

---

i. Spent Fuel Handling

---

---

---

---

j. Fuel Failure Detection

---

---

---

---

---

3.4 Fuel Inventory

a. Current Fissile Material Inventory Status

1. New Fuel In-Process

---

2. New Fuel On Hand

---

3. Fuel In-Core

---

4. Spent Fuel In Storage

---

5. Spent Fuel Being Reprocessed

---

6. Non-Fuel Special Nuclear Material

---

b. Fissile Material Inventory Needed to Assure Continuity of Operations

1. New Fuel In-Process

---

2. New Fuel On Hand

---

3. Fuel In-Core

---

3.5 Fuel Source

a. Fuel Fabricator

---

---

b. Fuel Supplier

---

---

c. Fissile Material Origin

d. Enrichment Supplier

---

e. Method of Fabrication

---

---

---

f.. Fuel Element Cost

---

4. HEAT TRANSFER DATA

4.1 Fuel Element Heat Transfer Area  
(No. of Plates/Pins x Active Plate/  
Pin Surface in Contact with Coolant)

---

---

4.2 Fuel Element Flow Area

---

4.3 Fuel Element Wetted Perimeter

---

4.4 Fuel Meat Thermal Resistivity

---

4.5 Clad-Coolant Heat Transfer Coefficient  
(at Hot Spot)

---

4.6 Heat Flux at Plate Surface

a. Normal Average Heat Flux

---

b. Peak Heat Flux

1. Without Hot Chanr . Factors

---

2. With Hot Channel Factors

---

c. Axial Peaking Factor in Hot  
Channel (from Axial Fission Rate  
Distribution)

1. Without Hot Channel Factors

---

2. With Hot Channel Factors

---

d. Hot Spot Location

---

4.7 Peak Operating Fuel Plate/Pin  
Temperature

a. At Plate/Pin Surface

1. Without Hot Channel Factors

---

2. With Hot Channel Factors

---

b. Inside Fuel Meat

1. Without Hot Channel Factors

---

2. With Hot Channel Factors

---

4.8 Primary Coolant

---

4.9 Coolant Flow

a. Flow Direction

---

b. Flow Induced by

---

c. Normal flow Rate

---

- d. Maximum Flow rate
- e. Mean Core Flow Velocity
- f. Normal Core Inlet Temperature
- g. Normal Core Temperature Rise ( $\Delta T$ )
- h. Peak Coolant Temperature Rise ( $\Delta T$ ) at Hot Spot
  - 1. Without Hot Channel Factors
  - 2. With hot Channel factors
- i. Coolant Pressure at Core Outlet (Absolute)
- j. Coolant Pressure at Hot Spot (Absolute)
  - 1. Without Hot Channel Factors
  - 2. With Hot Channel Factors
- 4.10 Hot Channel Factors (Including Only effects Other than Nuclear Peaking; Specify Breakdowns)
  - a. For Coolant Temperature Rise
  - b. For Film Temperature Rise
  - c. Others
- 4.11 Core Heat Dissipation System
- 4.12 Shutdown Heat Removal System
  - a. Worst Case Elapsed Time from Shutdown to Coolant Independence Without Fuel Distortion
- 4.13 Emergency Core Cooling System

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

5. NUCLEAR DATA

5.1 Fuel Loading

- a. Minimum Critical Mass
- b. Normal Core Loading  
(Beginning of Cycle at Rated Power)
- c. Maximum  $k_{\text{excess}}$  Components
  - 1. Temperature
  - 2. Equilibrium Xenon
  - 3. Equilibrium Samarium
  - 4. Xenon Override
  - 5. Burnup (Including Burnable  
Poison)
  - 6. Experimental Sample
  - 7. Others
  - 8. Total
- d. Shutdown Margin

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

5.2 Reactivity Coefficients

- a. Temperature
  - 1. Moderator
  - 2. Doppler
  - 3. Fuel Expansion
  - 4. Burnable Poisons
- b. Void

---

---

---

---

---

---

---

---

5.3 Neutron Flux Densities

- a. Steady State Average Thermal
- b. Steady State Peak Thermal
- c. Steady State Average Fast
- d. Steady State Peak Fast
- e. Peak Pulsing Power
- f. Pulse Integrated Power

---

---

---

---

---

---

---

---

5.4 Pulsing Characteristics

- a. Pulse Period

---

---

1396 133

- b. Full Width at Half Maximum
- c. Maximum Frequency of Pulses

---



---

5.5 Fission Density

- a. Normal Average
- b. Peak
- c. Axial Peak/Average Ratio for Typical Element

---



---



---

5.6 Maximum Fission Product Inventory

---

6. OPERATING EXPERIENCE

6.1 Forced Outages per 100 Full Power Operating Hours Since Criticality

- a. Equipment Malfunction
- b. Personnel Error
- c. Total

---



---



---

7. SAFEGUARDS

7.1 Agency Responsible for Regulatory Jurisdiction

---

8. PAST MODIFICATIONS AND FUTURE PLANS

8.1 Past Major Modifications

- a. Power Increase
- b. Fuel Conversion
- c. Other
- d. Date

---



---



---



---

8.2 Future Major Modifications

- a. Power Increase
- b. Fuel Conversion
- c. Decommissioning
- d. Other
- e. Date

---



---



---



---

8.3 Future Reactors

- a. Type
- b. Date

---



---

Irradiation Facilities	Description	Dimensions	Neutron Flux (n/cm <sup>2</sup> /sec)		Gamma Flux (Rad/hr)
			Thermal	Fast	
Beamports					
Convertor Blocks					
Irradiation Racks					
Pneumatic Tubes					
Neutron Source					
Reactor Core					
Reactor Pool					
Thermal Column					

1396 135

POOR ORIGINAL

9.1 REACTOR, LABORATORY, AND EXPERIMENTAL FACILITIES

Cont.d)

Laboratory Facilities	Description
Accelerator	
Critical Assemblies	
Gamma Sources	
t Cells	
Neutron Activation Analysis	
Neutron Generator	
Neutron Radiograph	
Neutron Spectrometer	
Radioisotope Laboratories	



10. RESEARCH AND TECHNICAL PROGRAM AND REACTOR UTILIZATION SUMMARY

10.1 Research, Technical, and Training Program

(This section contains 24 horizontal lines for handwritten text.)

10.2 Principal Isotopes Produced

(This section contains 7 horizontal lines for handwritten text.)

11. COMPUTER CODES UTILIZED IN DESIGN

11.1 Neutronics

---

---

11.2 Structural Design

a. Reactor Vessel

---

---

b. Fuel

---

---

c. Containment

---

---

11.3 Heat Transfer

---

---

12 DECOMMISSIONED FACILITY DATA

12.1 Facility Structural Condition

---

---

12.2 Maintenance and Surveillance Program

---

---

12.3 Types and Quantity of Contamination Present

---

---

12.4 Types and Quantity of Stored Wastes Present

---

---

12.5 Facility Radionuclide Inventory

12.6 Planned Interim Disposition of Facility

---

---

12.7 Planned Ultimate Disposition of Facility

12.8 Estimate Volume of Radioactive Waste Generated by Decommissioning

13. FACILITY DESIGN AND OPERATION REFERENCE DOCUMENTS

---

---

---

---

---