POOR ORIGINAL

NRC FORM 366 (7-77)

U.S. NUCLEAR REGULATORY COMMISSION

LICENSEE EVENT REPORT

EXHIBIT A

CONTROL BLOCK: [| | | | |] (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 | C A R S S 1 (2) LICENSEE CODE | 0 0 - 0 0 0 0 0 - 0 0 (3) LICENSE NUMBER | 4 1 1 1 1 (4) LICENSE TYPE | (5) CAT

CON'T 0 1 | REPORT SOURCE L (6) | 0 5 0 0 0 3 1 2 (7) DOCKET NUMBER | 1 1 0 1 7 9 (8) EVENT DATE | 1 1 1 5 7 9 (9) REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 While analyzing the onsite power distribution system per the 8-8-79 letter

0 3 from W. Gammill (NRC-Washington), a potential discrepancy was identified.

0 4 The potential discrepancy identified concerned the adequacy of the On Site

0 5 Distribution System in the event of a degraded voltage condition on the grid

0 6

0 7

0 8

0 9	SYSTEM CODE	CAUSE CODE	CAUSE SUBCODE	COMPONENT CODE	COMP. SUBCODE	VALVE SUBCODE
	E B (11)	X (12)	Z (13)	Z Z Z Z Z Z (14)	Z (15)	Z (16)

(17) LER/RO REPORT NUMBER

EVENT YEAR		SEQUENTIAL REPORT NO.		OCCURRENCE CODE	REPORT TYPE		REVISION NO.
7 9	—	0 1 3	/	0 1	T	—	0

ACTION TAKEN	FUTURE ACTION	EFFECT ON PLANT	SHUTDOWN METHOD	HOURS (22)	ATTACHMENT SUBMITTED	NPRD-4 FORM SUB.	PRIME COMP. SUPPLIER	COMPONENT MANUFACTURER
F (18)	F (19)	Z (20)	Z (21)	0 0 0 0	Y (23)	N (24)	Z (25)	Z 9 9 9 (26)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 Actual recorded degraded voltage condition on the grid is lower than origi-

1 1 nally anticipated. Resetting the UV relay to guarantee transfer of the ESF

1 2 buses whenever the 4160V supplies reach 0.9 of 4160V and the resetting OV

1 3 relays at 110% of 4160V will assure that the onsite electrical distribution

1 4 system meets all design criteria. This will be done during 11-17-79 outage.

1 5	FACILITY STATUS	% POWER	OTHER STATUS (30)	METHOD OF DISCOVERY	DISCOVERY DESCRIPTION (32)
	E (28)	1 0 0 (29)	N/A	C (31)	Special Testing

1 6	ACTIVITY RELEASED OF RELEASE	CONTENT	AMOUNT OF ACTIVITY (35)	LOCATION OF RELEASE (36)
	Z (33)	Z (34)	N/A	N/A

PERSONNEL EXPOSURES

1 7	NUMBER	TYPE	DESCRIPTION (39)
	0 0 0 (37)	Z (38)	N/A

PERSONNEL INJURIES

1 8	NUMBER	DESCRIPTION (41)
	0 0 0 (40)	N/A

LOSS OF OR DAMAGE TO FACILITY (43)

1 9	TYPE	DESCRIPTION
	Z (42)	N/A

1399 112

PUBLICITY

2 0	ISSUED	DESCRIPTION (45)	NRC USE ONLY
	N (44)	N/A	

NAME OF PREPARER R. W. Colombo PHONE: 916-452-3211

7911270326