

Accession Unit
(ORIG)

P-050

NUCLEAR REGULATORY COMMISSION

ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

IN THE MATTER OF:

235th GENERAL MEETING

POOR ORIGINAL

Place - Washington, D. C.

Date - Friday, 9 November 1979

Pages 311 - 68

Telephone
(202) 347-3700

ACE - FEDERAL REPORTERS, INC.

Official Reporters

444 North Capitol Street
Washington, D.C. 20001

7911290

NATIONWIDE COVERAGE - DAILY

436

1429.001

PT 9.7

JOCFR

CR8176

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

PUBLIC NOTICE BY THE
UNITED STATES NUCLEAR REGULATORY COMMISSION'S
ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

Friday, 9 November 1979

The contents of this stereographic transcript of the proceedings of the United States Nuclear Regulatory Commission's Advisory Committee on Reactor Safeguards (ACRS), as reported herein, is an uncorrected record of the discussions recorded at the meeting held on the above date.

No member of the ACRS Staff and no participant at this meeting accepts any responsibility for errors or inaccuracies of statement or data contained in this transcript.

1429 002

1 UNITED STATES OF AMERICA
2 NUCLEAR REGULATORY COMMISSION
3 ADVISORY COMMITTEE ON REACTOR SAFEGUARDS
4

5 235 GENERAL MEETING
6

7 Room 1046
8 1717 H Street, N.W.
9 Washington, D. C.

Friday, November 9, 1979

10 The 235th General Meeting of the Advisory Committee on
11 Reactor Safeguards was reconvened, pursuant to adjournment, at
12 8:30 a.m.

13 PRESENT:

14 DR. MAX W. CARBON, Chairman
15 DR. MILTON S. PLESSET, Vice Chairman
16 MR. MYER BENDER, Member
17 MR. JESSE EBERSOLE, Member
18 MR. HAROLD ETHERINGTON, Member
19 PROF. WILLIAM KERR, Member
20 DR. STEPHEN LAWROSKI, Member
21 MR. HAROLD LEWIS, Member
22 DR. J. CARSON MARK, Member
23 MR. WILLIAM M. MATHIS, Member
24 DR. DADE W. MOELLER, Member
25 DR. DAVID OKRENT, Member
MR. JEREMIAH J. RAY, Member
DR. PAUL G. SHEWMON, Member
DR. CHESTER P. SIESS, Member

1429 003

P R O C E E D I N G S

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

DR. CARBON: This is the second day of the 235th meeting. Speak up. Let's start the meeting without further ado.

DR. OKRENT: Mr. Chairman, may I raise a question on schedule before we get further into the agenda?

DR. CARBON: Yes.

DR. OKRENT: If I recall correctly, the current plan is we meet until Saturday, noon?

DR. CARBON: Until Saturday, noon, yes.

DR. OKRENT: Much as I look forward to getting an early plane back, it is not clear to me that we shouldn't take advantage of the available time, for example, either to see whether we have any recommendations that we want to complete this meeting, or to take a first hard look at what the Kemeny report means from our point of view, or something. It strikes me that during these rather fast-moving days and weeks, we perhaps should give thought to whether we want to use that time.

DR. CARBON: Your point is well taken. Ray told me later yesterday that there is a request on its way to us asking for our views on how the Kemeny report affects us. Those recommendations that it makes with respect to ACRS, at least. So, we definitely will have procedures subcommittee the day before the December meeting to consider that. That

76 01 02

pv MM

1 does not cover everything that you speak of. I want to try
2 to maximize the time today that we can devote to Mike's
3 report and put just as much time as possible on it and defer
4 other things until tomorrow and maybe cancel something this
5 afternoon, although I am not sure anything can be done there
6 or not.

7 Would you have specific thoughts on things we
8 might well work on tomorrow afternoon? For example,
9 discussion of the Kemeny report?

10 DR. OKRENT: Well, that could be a topic. It
11 wouldn't even, I suppose, be improper to start thinking in a
12 preliminary way about how one would best organize what the
13 NRC expects to be trying to do during the coming months and
14 what seemed to be important to be done for operating
15 reactors on a short or a long basis.

16 Again, Lewis yesterday indicated that if we have
17 any I guess what you would call administrative kinds of
18 recommendations as distinct from what I will call
19 nuts-and-bolts recommendations, this is an important month
20 for such recommendations. I don't know if we have any, but
21 if we don't talk about them, then I am sure we won't have
22 any.

23 DR. CARBON: Anyone else have comments to make on
24 the subject at the moment?

25 DR. SIESS: I have a comment: that I have already

1429 005

76 01 03

pv MM

1 changed my reservations, and other people may have also. I
2 may be able to change them back, but somebody has got to
3 decide real quick.

4 DR. CARBON: Okay. Let's go on with the agenda
5 for the morning.

6 DR. SIESS: If we're going to decide about
7 tomorrow, I would like to know whether to change from 1:00
8 o'clock to 5:00 o'clock.

9 DR. CARBON: I had in mind trying to do something
10 later this morning, but maybe we might as well do it right
11 now.

12 DR. SIESS: I don't care. I have got a
13 reservation now --

14 DR. CARBON: Let's just stay on it and do it right
15 now.

16 DR. SIESS: You might ask how many people can now
17 stay beyond.

18 DR. CARBON: I changed mine, but I can change them
19 right back again. How many people could stay until, say,
20 4:30 or 4:00 o'clock?

21 DR. MARK: Only if reservations are available.

22 (Show of hands.)

23 DR. CARBON: Two, three -- possibly seven.

24 PROF. KERR: We could start with 2:00 o'clock, but
25 I am not sure that two hours would be enough.

1429 006

76 01 04

pv MM

1 DR. CARBON: Well, let me ask. 2:00?

2 (Show of hands.)

3 DR. CARBON: Well, with your approval, I propose
4 right now, then, that we just stay until 4:00 o'clock
5 tomorrow afternoon, as many people as can. If somebody has
6 to drop out at 2:00 o'clock, so be it, and we'll work on
7 until 4:00, those of us who can stay. So be it. Let's do
8 it.

9 Let's go on, then, with our agenda. Mr. Check.

10 MR. CHECK: I am Paul Check, of the reactor safety
11 branch, division of operating reactors.

12 The committee has invited us to discuss system
13 interactions resulting from steam line breaks outside
14 containment. Actually, the subject is broader than that. I
15 believe you are referring to the events preceding and
16 surrounding a letter from Harold Denton to the industry,
17 dated approximately the 17th of December, in which he asks
18 for the opinion of each licensee regarding certain concerns
19 expressed in the licensee event report submitted to us by
20 Public Service Electric & Gas Company, New Jersey.

21 Let me begin, then, by saying that what I hope to
22 do today is describe something of the history of this issue,
23 to discuss where we are today, and make a few comments about
24 the future

25 (Slide.)

1429 007

76 01 05

pv MM

1 I guess, first of all, I should describe the issue
2 itself. Prior to the first entry here in this chronology,
3 actually, I guess, in late August of this year, Westinghouse
4 sent letters to its customers alerting them to potential
5 spurious control system operations which might result from
6 adverse environment which attends postulated high-energy
7 line break. These could be steam line breaks, it could be
8 feedwater line breaks, it could be primary system breaks.

9 Westinghouse informed its customers that such
10 spurious operation might impact protection functions in such
11 a way that the consequences of the high-energy line break
12 could be more limiting than those presented in the plant
13 SAR. In that letter to its customers, it invited customers
14 to a meeting, an owners group meeting, in Pittsburgh, on the
15 sixth of September. That meeting was held. I wasn't
16 there. I don't know the tenor of the meeting. But as I
17 said earlier, Public Service Electric & Gas Company of New
18 Jersey, the owner-operator of Salem Unit 1, felt as a result
19 of what it had learned that it should notify the Nuclear
20 Regulatory Commission, which it did on September 9.

21 Shortly thereafter, the office of inspection and
22 enforcement issued an information notice to all licensees.
23 And about the same time, Harold Denton wrote a letter to all
24 licensees asking them to respond to this issue. Briefly,
25 the NRC was concerned -- I am quoting now from Denton's

1429 008

pv MM

1 letter -- "was concerned that similar potential may exist at
2 other operating light water reactor facilities, including
3 yours, for an unreviewed safety matter relating to the
4 effects of the environment on control systems resulting from
5 high-energy line breaks inside or outside containment and
6 the result of these effects on the required safety systems."

7 In his letter he requested that all licensees
8 respond within 20 days, presenting evidence which would
9 enable the staff to determine whether or not licensees
10 should be modified, suspended, or revoked.

11 In the week following that letter there was a
12 series of meetings, one with each of the owners groups that
13 had been established since Three Mile Island to discuss the
14 matter. The following week, the assignment was given to me
15 to prepare for the receipt of the licensee submittals that
16 would be coming in another two or three weeks. As part of
17 this we began to explore whether in fact there was a basis
18 for continued operation of plants.

19 So, although the chronology suggests that we
20 didn't come to such a determination until after licensee
21 submittals were in, in fact in a very short time we did make
22 a determination regarding the basis for continued
23 operations. And that is contained in a document that
24 Eisenhut sent to Denton on the 15th of October.

25 (Slide.)

1429 009

76 01 07

pv MM

1 Briefly, what we said was the basis of what we
2 knew at the time, while we had a safety concern we could not
3 find a particular safety problem. What I mean is: no event
4 had been identified which led to an unacceptable
5 consequence. We observed also that there were considerable
6 margins in the safety analyses for most high-energy line
7 breaks and that these margins were probably sufficient to
8 absorb our present uncertainties about the effects of what
9 we were calling "consequential control system failures."

10 We observed that there were unresolved safety
11 issues of a similar kind in existence, and that plants
12 continued to operate in the face of these. And we
13 contrasted this concern with some issues which had led
14 recently to shutdown orders. And fourthly, we observed that
15 the ability of the operator to cope with the high-energy
16 line break we did not feel would be substantially degraded
17 by the addition of this so-called "consequential control
18 system failure."

19 MR. EBERSOLE: Is your topic pertinent to boilers
20 as well as PWRs?

21 MR. CHECK: Yes. All licensees received this
22 letter.

23 DR. SHEWMON: And all line breaks are
24 instantaneous and complete. Right?

25 MR. CHECK: Yes.

1429 010

176 01 08

pv MM

1 MR. EBERSOLE: I want to ask you a question
2 concerning a generation of boiling water reactors that has a
3 break in a 10-inch HPSI line immediate adjacent to the
4 outboard isolation valve. This break, should it occur at
5 that point, will strip that valve of any functional
6 capability to close. The valves, I believe, at least
7 designs, are nominally standing open up to the stop valve at
8 the turbine. The inboard isolation, which is an AC-driven
9 valve, can be a fresh random failure.

10 The end result of this particular incident is that
11 continuous discharge of 10-inch, initially 1100 psi steam
12 into the environment which contains the shutdown equipment
13 as well as the operators. How does the operator cope with
14 that?

15 MR. CHECK: Mr. Ebersole, I should have said at
16 the outset that we are not prepared to discuss in technical
17 detail particular event scenarios. I do not know whether
18 that one was identified in the GE responses. They have a
19 rather extensive matrix. We will show you something of what
20 they have provided to us.

21 MR. EBERSOLE: I would like that one to stay on
22 top of the list.

23 MR. CHECK: This issue is not closed.

24 MR. EBERSOLE: This issue is 10 years old.

25 MR. CHECK: Obviously, this issue isn't closed.

1429 011

76 01 09

pv MM

1 DR. RAY: A point, please. If that's
2 characteristic of BWRs in service, Jesse, I would think it
3 should be given priority of consideration on the part of
4 this task force.

5 MR. EBERSOLE: I agree with you.

6 MR. CHECK: If you will bear with me, gentlemen,
7 we will describe for you something of the plan that we have
8 for dealing with this.

9 (Slide.)

10 I don't mean to mislead you regarding the detail
11 into which the NRC has gone up to this point in dealing with
12 this specific issue. There is a presumption of innocence
13 until guilt is shown. If we find a problem, then we deal
14 directly with it. But we have been notified by the industry
15 of potential unreviewed safety questions, and we are going
16 as quickly and as systematically as time permits through a
17 large body of information in order to make some
18 assessments, general and specific, on continued operation.

19 You may, in fact, have a very interesting scenario
20 and one that ought to be recommended for study. But I think
21 if you will bear with me, we will talk a little bit more
22 about pulling together a lot of disparate elements of a
23 large task.

24

25

1429 012

pv MM

1 MR. CHECK: Okay, then, the licensee submittals
2 came in. And perhaps not too surprisingly, they generally
3 speak confidently about the issue. We have screened these.
4 We are preparing a status report presenting our interim
5 findings on our evaluation, and I will touch on those in
6 just a moment.

7 But I wanted to mention that, in connection with
8 this, the industry had begun for the first time -- I think
9 for the first time -- to act in concert to try to bring as
10 many people, as many interests, together in a common effort
11 -- something that we, of course, have encouraged. And as a
12 result, an NSAC report memorandum was written and sponsored
13 by the Atomic Industrial Forum. It was sent in. That
14 report was referenced by a number of utilities. That
15 report, for those of you who haven't seen it, deals
16 principally with a probabilistic analysis of the
17 Westinghouse scenarios and also discusses the likelihood of
18 high-energy line breaks.

19 (Slide.)

20 As I said, we are preparing a status report which
21 we hope to complete shortly. We have screened all the
22 licensee submittals. I should note that there is a general
23 acknowledgement in the responses from the industry that the
24 issue deserves longer-term considerations; this deserves
25 further study. Our initial findings are -- continue to be

1429 013

pv MM

1 that we have not identified any safety problem.

2 We distinguish safety problems from safety
3 concerns. Safety concerns involve mostly uncertainty, in
4 our minds, which derives from a lack of information. There
5 are assertions made in the responses with very little
6 supporting hard information, not enough information which
7 would allow us to conclude independently as they have.
8 That's what I mean by "concern" as opposed to safety problem
9 where something would be identified as deficient.

10 We say our concerns reside in the question of the
11 breadth and the depth of the systems interactions reviews
12 that they've performed. In the question of the
13 environmental qualification of the equipment and in this
14 matter that you bring up, Mr. Ebersole, the ability of the
15 operator to actually function as he is presumed to.

16 DR. RAY: Your concern with the adequacy of the
17 breadth and depth of the systems reviews, is that in
18 response to this request or in a general routine reviews and
19 in the course of evolution of the plant?

20 MR. CHECK: No. My comments are directed to the
21 response that came from Harold Denton's letter, yes.

22 DR. OKRENT: I have a question. First, could you
23 repeat the scenario, just so we have it in front of us
24 again?

25 MR. EBERSOLE: Yes. Some of the designs — these

pv MM 1 are boilers -- contain the concept of having full pressure
2 steam against the intake stop valve of the HPSI turbine
3 right up to the stop valve. This necessitates that the two
4 oscillation valves which feed this turbine are wide open.
5 Typically, the inboard valve is an AC valve, so it can
6 better resist the environment of the containment. It stands
7 open. The outboard is a DC-driven valve for diversity.
8 They both stand open.

9 If I postulate a main steam line failure, which is
10 a 10-inch steam line in this case, in the region adjacent to
11 the outboard valve, I no longer have the privilege of saying
12 I have two random failures available to me before the
13 function fails, because the outboard valve becomes involved
14 as a direct result of the initial event. It is stripped of
15 its functional capability.

16 The first random failure could be the inboard
17 valve, which is protected because it's inside containment.
18 If that failure occurs, the end result is the BWR feeds the
19 steam not into the outer environment as it would in the case
20 of the main steam lines, but to the inner environment
21 wherein are located all of the shutdown heat removal
22 equipment and the operators. It may feed into an
23 environment of three units.

24 The situation is: you have a long-term continuous
25 discharge of 10-inch steam into that building which houses

1429 015

pv MM

1 all of the mitigating systems. Besides the roof coming off,
2 I suspect that the equipment will indeed not run very well
3 or very long at all. From temperature, humidity, water, a
4 variety of reasons.

5 That is a standing condition. It was deplored in
6 1968 by TVA, to GE and to the regulatory commission.
7 Nothing was ever done about it except that TVA provided a
8 straight piece of pipe inboard in this main steam line for
9 someday when better judgment would put a valve in that
10 place. I think that time is due.

11 DR. OKRENT: How would you examine such a question
12 and arrive at a decision whether or not it was important
13 enough to backfit? It's not a straightforward situation.
14 It involves a break and then a single failure. I am curious
15 to know how you would proceed.

16 MR. CHECK: I suspect, Dr. Okrent, I would do what
17 you are trying to do now. You would want to find out what
18 the staff had been doing on this issue. There have got to
19 be countervailing arguments. We have heard something here.
20 I suspect Dr. Ebersole — Mr. Ebersole knows something of
21 the response to the concern that TVA expressed.

22 MR. EBERSOLE: As I recall, the decision was the
23 probability of the break in the pipe at that particular
24 distance from the outboard oscillation valve was
25 sufficiently low to claim purely random failure of the

1429 016

pv MM

1 outboard valve.

2 MR. CHECK: It sounds like a policy decision.

3 MR. EBERSOLE: Indeed, it is.

4 DR. SHEWMON: It was not a pipe break; it's a
5 failure of the valve casing.

6 MR. EBERSOLE: No, it's a pipe break. Anywhere
7 within, say, 10 to 15 feet of the valve, including the
8 casing.

9 DR. SHEWMON: But you strip the valve of its --

10 MR. EBERSOLE: Of its delicate trim, that's
11 called, that makes it go. You know, all valves have a
12 relatively delicate accessory system which tells the valve
13 what to do -- the motors or whatever they may be.

14 DR. SHEWMON: You have had two simultaneous
15 failures --

16 MR. EBERSOLE: I have not. I have had one failure
17 followed by causally occurred failure, then a random
18 failure.

19 DR. PLESSET: Jesse, what was this thing that TVA
20 did? Was that considered a fix?

21 MR. EBERSOLE: No, that was a waiting game.

22 DR. PLESSET: Oh.

23 MR. ETHERINGTON: These pipe lines are carbon
24 seal; aren't they? So we have a reliable material.

25 MR. EBERSOLE: Yes, you do, indeed. That's true.

1429 017

pv MM 1 Some possible fixes -- and I am not sure; you may introduce
2 these, if you wish -- would be to change the whole logic and
3 have these valves normally closed. That was never
4 developed. Another one would be to have the valves
5 cracked. The main reason they were kept open was to keep
6 the line hot and available for instant start of HPSI. And
7 there are several solutions, but the most solid one, of
8 course, is the third valve inboard of the containment.

9 PROF. KERR: Mr. Chairman, clearly, Mr. Ebersole
10 has identified a problem which he considers important. Can
11 we agree that we can send some sort of note to staff asking
12 that this be examined? I doubt if Mr. Check and we can
13 solve the problem.

14 DR. CARBON: No, that's right. Fine.

15 MR. EBERSOLE: It's just an example of an old
16 issue which maybe had a new light on it.

17 MR. CHECK: It may very well. And again, I ask
18 you to reserve until I get down to the premises. Okay?

19 DR. CARBON: Fine.

20 MR. CHECK: We'll be talking something about the
21 future. I think a more systematic study than has been done
22 in the past is in the offing, and issues such as those
23 should be addressed.

24 DR. CARBON: Are you near winding up?

25 MR. CHECK: Yes, I hope so.

1429 018

02 07

(Slide.)

That brings us just about to the present.

We have drafted a status report with our initial findings and told you about those, and we expect that within the next couple of weeks that we will be writing back to all licensees stating our finding, perhaps encouraging some to follow up in a way that they have in fact suggested -- minor plant modifications or procedural modifications -- and urging active participation in an NRC-industry plan to deal with this issue.

And that brings me to where we go from here. I have the impression that some of you had heard from Roger Mattson about his final report in Lessons Learned. I want to read from it, recommendation No. 9:

"The owners of operating plants and all plants under construction should be required to evaluate the interaction of nonsafety and safety-grade systems during normal operation, transients, and design basis accidents, to assure that any interaction will not result in exceeding the acceptance criteria for any design basis event.

"The event should be system tic, include all nonsafety components, equipment, systems, and structures. Under all conditions of normal operation, anticipated operational occurrences and design basis accidents initiated both within the plant, such as pipe breaks, and from outside

1429 019

pv MM 1 the plant, such as earthquakes and other natural phenomena,
2 and off-site hazards.

3 "The interactions and effects should consider
4 various failure modes, including spurious operation, failure
5 to operate upon demand, and any unusual or erratic operation
6 that might result from exposure to the abnormal process or
7 environmental conditions accompanying the event under
8 study. As a necessary part of this evaluation, proper
9 qualification of safety systems, including mechanical
10 components, should be verified."

11 I think that is an excellent charter for the kind
12 of study that would address issues as you bring up,
13 Mr. Ebersole.

14 (Slide.)

15 This slide shows a number of existing review
16 efforts or programs that could be considered elements of the
17 kind of omnibus task that is being recommended by the
18 Lessons Learned Task Force. It remains for the NRC to
19 implement such a task.

20 PROF. KERR: Mr. Check, what is meant by consequential
21 system?

22 MR. CHECK: That's what we are calling this.
23 High energy line break creating an environment which in consequence
24 results in a spurious control system.

25

1429 020

pv MM

PROF. KERR: Thank you.

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14
- 15
- 16
- 17
- 18
- 19
- 20
- 21
- 22
- 23
- 24
- 25

1429 021

c2

gshBW

1 MR. CHECK: I'm sure that we could come up with a
2 better title.

3 PROF. KERR: I didn't mean to criticize the
4 title. I just wanted to understand it.

5 MR. CHECK: I'm not nuts about it.

6 The last item on the chronology was the industry meeting.

7 We met with the industry yesterday, representatives of
8 the industry yesterday to explore a new way to accomplish a
9 task such as this.

10 (Slide.)

11 This is all so new, it hasn't even been typed. We
12 proposed for consideration a scheme for involving the
13 industry early in the planning and design and the resolution
14 of this issue.

15 The central feature of this scheme is a steering
16 committee of mid to senior level NRC and industry
17 representatives which develops the task action plan and
18 establishes the schedule and thereafter, oversees
19 performance.

20 Other responsibilities would include developing review or
21 problem-solving methodology and developing acceptance
22 criteria.

23 The NRC hopes to gain by this an equivalent or superior
24 safety product at less cost to the taxpayer. Industry, I
25 think, should profit by helping to confine regulatory

1429 022

gshBW 1 requests and requirements to true safety matters.

2 That's all I have to say, Mr. Chairman.

3 DR. CARBON: Fine.

4 MR. EBERSOLE: One quick question. I notice in
5 this flood of literature we get, there's occasional
6 reference to the potential in this aspect of
7 overpressurizing the PWR containments as a result, for
8 instance, of continual run on the main feedwater after
9 a main feedline break.

10 I really would like to suggest that you look at these large
11 potential result-type accidents as a first-stage look due to
12 the gross consequence of this.

13 My impression is that there may be a growing concern
14 about containment inadequacy against some of the system
15 failures.

16 DR. CARBON: Any other questions? Harold?

17 MR. ETHERINGTON: Is there any concern about jet
18 action, or is it just the atmosphere?

19 MR. CHECK: It's all environmental effects,
20 including jet impingement on wires or other components.

21 MR. ETHERINGTON: And do you expect the controlled
22 instrumentation to retain its integrity until it's performed
23 its function and then you don't care beyond that?

24 Is that right?

25 MR. CHECK: Well, if it must perform in a good

1429 023

gshBW 1 way --

2 MR. ETHERINGTON: A good way, of course.

3 MR. CHECK: Then, of course, there would have to
4 be appropriate environmental qualification of the
5 equipment. Some of the assumption, in our judgment thus far,
6 has been that things don't fail catastrophically. We have
7 been looking at this perhaps more mechanistically than we
8 would if we were doing an FSAR design review.

9 We're dealing with the world as we find it and we are
10 trying to give it the benefit of reality.

11 MR. RAY: Is it possible that you might schedule
12 some tests of those components of control and see what it
13 takes to destroy them, make them inoperative?

14 MR. CHECK: Yes, that's certainly the kind of
15 thing that may happen.

16 DR. CARBON: Fine. Thank you, Mr. Check.

17 Let's then move on to Mike's report.

18 MR. BENDER: Let's pick up on 6. This first
19 section deals with design basis accidents. At one time, I
20 thought it should have been -- we might talk about societal
21 risks, too, but I think I am going to read what it says
22 about design basis accidents and suggest that that be what
23 the subject matter ought to be in this particular section.

24 The NRC adopted the regulatory safety requirements of the
25 AEC as a starting point for its administration. Design

1429 024

gshBW 1 basis accidents are the foundation for these regulatory
2 requirements.

3 The accident conditions assumed for containment purposes
4 include the release of very large amounts of fission
5 products and gaseous and particulate forms, whose escape
6 from the contained plant volume must be controlled.

7 The radionuclide release is derived from core melting
8 experiments. But containment design is based on the
9 assumption that core cooling is maintained, and thus, that
10 no fuel melting will occur.

11 The reactor safety studies, WASH-1400, shows that the
12 probabilities of accidents involving core melting without
13 adequate core cooling were high enough to deserve attention.

14 Prior to the reactor safety study, the ACRS had for many
15 years urged the nuclear industry to look beyond the design
16 basis accident for circumstances that might warrant
17 mitigation treatment by design.

18 More recently, the floating nuclear plant had been
19 required in response to environmental impact evaluations to
20 provide features permitting the consequences of a core melt.

21 The foregoing suggests a need to re-examine the design
22 basis accident used for safety evaluation purposes. The NRC
23 evaluates the consequences of design basis accidents under
24 conditions where engineered safety features are provided to
25 cope with the accidents.

1429 025

gshBW 1 The approach has been described as defense in-depth. It
2 presumes that the plants are well engineered, that some
3 things will go wrong in spite of good engineering, but
4 normal engineering practice for nuclear power plants would
5 provide for such normal contingencies.

6 For very unusual events, there is a second line of
7 protection — engineered safety features intended to keep
8 unusual accidents within public safety consequence limits.

9 The severity of the accident under which engineered
10 safeguards must function is arbitrarily established by the
11 design basis.

12 The severity of the design basis accident is one of the
13 crucial technological issues. Should core melt be assumed
14 and if so, how completely? If not, is the core damage
15 experienced at TMI 2 the appropriate basis for establishing
16 containment leak tightness?

17 Did the escape of hydrogen from the TMI 2 reactor vessel
18 as a result of zirconium-water reactions indicate that
19 hydrogen combustion effects had been underestimated? Were
20 assumptions concerning containment integrity as a design
21 basis well founded?

22 The technical basis for the accident assumptions involve
23 the most complicated logic intended to bound the potential
24 accident circumstances. The logic does not always involve
25 totally consistent assumptions.

1429 026

gshBW

1 The one possibility for establishing severity levels was
2 to use the probabilistic accident consequence analysis
3 approach as was done in the reactor safety study.
4 Quantitative safety goals would be needed to use this
5 approach and they would have to account for very low
6 probability events where actual statistical experience is
7 weak.

8 The method would have to include consideration of both
9 consequence uncertainty and engineering reliability
10 questions involving applications where little experience
11 exists.

12 In spite of these limitations, this approach appears to
13 have the best opportunity for displaying the appropriateness
14 of the NRC's regulatory requirements to the knowledgeable
15 public.

16 The risks associated with these goals would be compared
17 with other known societal risks. Recognizing, however, that
18 probabilistic methodology is slow to evolve and will include
19 much subjective judgment, it appears necessary for the
20 immediate future to continue the current policy of
21 specifying arbitrary accidents as a basis for regulation.

22 The NRC clearly has an obligation to assign requirements
23 in accord with its views of public risk. It should be able
24 to show the public and the regulated industry how these
25 requirements are established and clarify the reasons for

1429 027

gshBW 1 inconsistencies when they appear.

2 A more conservative position assigned to one particular
3 installation or one area as opposed to all the rest makes
4 all the others suspect.

5 A major contribution to public acceptance of the
6 regulatory process would be to clarify how the constantly
7 changing regulatory position, whether more or less
8 conservative, are founded and how they compare with other
9 societal risks.

10 PROF. KERR: Is there any significance of
11 clarifying?

12 MR. BENDER: I guess the thought I had in mind was
13 that we've got some design basis accidents and nowhere have
14 I been able to find anything that says why those were
15 selected.

16 PROF. KERR: Well, clarify the reasons for having
17 chosen a particular design basis accident.

18 MR. BENDER: Yes.

19 PROF. KERR: Okay.

20 MR. BENDER: Fine. And maybe that ought to be
21 developed more clearly. This thing says, look at the design
22 basis accidents again and even though we could use
23 probabilistic analysis, it's going to take a while to get
24 there.

25 DR. OKRENT: A couple of quasi-editorial kinds of

gshBW

1 things.

2 On page 6-2, where you talk about prior to the
3 application study, ACRS since 1966 has urged the AEC, the
4 NRC, and the nuclear industry. That's when it all began.

5 And if you wanted to, you could say that the floating
6 nuclear plant thing is in response to ACRS concerns. But
7 that's not a very major point.

8 And on page 6-4, when you talk about, at the end of the
9 first paragraph, you say, in spite of the limitations, the
10 approach appears to have the best opportunity for displaying
11 the appropriateness. I would say for examining the
12 appropriateness.

13 MR. BENDER: Okay.

14 DR. OKRENT: I would like to come to a substantive
15 point. What isn't in here is whether the design basis
16 accidents should be changed.

17 It is sort of hinted at a little bit and sort of hinted
18 about a little bit in the next section.

19 I was wondering what your intent was, your thoughts, or
20 however you want to put it?

21 MR. BENDER: I guess Max had a fairly strong
22 recommendation on this. My thought was that we probably
23 need to make some judgment about whether it should be. But
24 what it should be changed to was hard to say.

25 And the thought I was trying to convey was that the first

1429 029

gshBW

1 thing to do was to try to figure out whether it should be
2 changed and if so, to what extent. But not to say right now
3 that it must be changed because I really don't know whether
4 it should be changed or not.

5 That's my personal judgment.

6 Right now it's an accident that involves a substantial
7 release of radionuclides. As a matter of fact, it really is
8 just about the TMI 2 accident right now.

9 That's about what the design basis is. And whether you
10 ought to have something that goes beyond that or not, I
11 don't know. For the purpose of designing
12 containment and engineered safety features, what would be
13 accomplished by going beyond that, I'm not sure about.

14 I don't know what we mean when we say we would go beyond
15 it.

16 That's what I'm talking about.

17 MR. RAY: Is there a staff effort underway
18 examining whether or not they should be changed?

19 MR. BENDER: I think they're thinking about it,
20 but I think they're in the same dilemma I am.

21 DR. OKRENT: The title of this section --

22 MR. BENDER: The title is bad.

23 DR. OKRENT: Yes. Because in fact, you don't
24 really --

25 MR. BENDER: I was going to do something else,

1429 030

gshBW 1 Dave, when I started out and I threw a lot of it away. I
2 just wanted to make it design basis accidents.

3 MR. RAY: Is it possible that you wouldn't have to
4 have a decision incorporated in this memorandum as to
5 whether or not it should be changed but simply indicate that
6 a study must be undertaken in this area?

7 MR. BENDER: I think that this is the point that
8 Dave is getting at. How should we go about saying that,
9 though? I wouldn't argue that it may need to be changed. I
10 just don't know how to say that we really want a change or
11 how you can decide.

12 PROF. KERR: Well, a position in that direction
13 would be to say that since a particular set of design basis
14 accidents now used have been used for at least a decade, I
15 guess, that one should re-examine to see if the experience
16 since the early adoption would still indicate that those are
17 appropriate.

18 MR. BENDER: Well, we could take that tac.

19 PROF. KERR: That is a very mild beginning. Maybe
20 not going far enough.

21 DR. OKRENT: I would say it was all right for two
22 years ago.

23 PROF. KERR: Well, unless we know or unless we can
24 conclude that some reasonable amount of discussion, to what
25 design basis accident one should shift, it seems to me what

gshBN 1 we'd have to say is that we have some misgivings about the
2 present set and we think that the question ought to be
3 looked at carefully.

4 MR. EBERSOLE: May I suggest a sentence to be put
5 in here along this line?

6 Design basis consequences, and even risk consequences,
7 can be obtained without the necessity of having spontaneous
8 quench failures. I think that's important. That's what
9 happened in TMI.

10 MR. BENDER: That's one kind of design basis
11 accident.

12 MR. EBERSOLE: But it's not considered that. It's
13 not a design basis accident now.

14 DR. MOELLER: It seems to me that we also should
15 take into the equation or insert the fact that a facility
16 designed to handle a given design basis accident won't
17 necessarily not handle one of a different size, an accident
18 of a different size.

19 Am I making myself clear?

20 DR. SHEWMON: If I understand your double
21 negative, you're saying that you think the design basis
22 accident provides a good umbrella?

23 DR. MOELLER: Yes, it provides some umbrella. I
24 don't know if it's good.

25 MR. EBERSOLE: But it beclouds —

1429 032

gshBW

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14
- 15
- 16
- 17
- 18
- 19
- 20
- 21
- 22
- 23
- 24
- 25

DR. MOELLER: Whether it's adequate, I don't know. But it certainly provides an umbrella. We should keep that in mind.

MR. EBERSOLE: What it doesn't do, however, is reveal the causal potential for having the design basis accident. It relegates it to the concept of spontaneous pipe failure, which is low, the probability.

It doesn't need to be that.

2.3

1429 033

gsh/MMM 1 MR. BENDER: I think that's only one thing covered in
2 design basis accidents, spontaneous pipe failure. It's one of
3 the mechanisms used to determine accident consequences.

4 I think others are inferred by the design basis accident.

5 PROF. KERR: It seems to me, Jess, the present design
6 philosophy assumes the probability of spontaneous pipe failure is
7 one. And given that probability one has to be able to live with it.

8 So it doesn't assume that the probability is low.

9 MR. EBERSOLE: That's true.

10 DR. CARBON: I want to clarify a point. I did not
11 make a recommendation to change from the DBA. I urge
12 studies, but not changing the DBA.

13 MR. BENDER: I apologize for the
14 misinterpretation.

15 DR. CARBON: Okay.

16 DR. OKRENT: I am not at the moment trying to
17 propose a committee recommendation or an individual position
18 that sort of goes to the end or that we know what to do.

19 But I do think that this is an area where, in fact, as
20 part of writing this, we should come up with some
21 recommendations.

22 In my mind, I would say that I have two categories:
23 First, they are the existing reactors that you have to think
24 about, and I suppose that means operating and under
25 construction; and then reactors under construction that have

1429 034

gshMMM

1 not yet begun, where you might again try to subdivide it
2 into two parts.

3 For the existing reactors, it would seem to me a
4 constructive step would be, one, to do a risk profile on
5 them, which you might call a WASH-1400 study, at least with
6 regard to which seemed to be the more probable sources of
7 serious accident, but not necessarily, just assuming the
8 same sequences of WASH-1400, because that won't get you the
9 right answer, necessarily.

10 In any event, getting some kind of risk profile this way
11 and also, looking at what measures, either preventative or
12 mitigative, would change this. What do these measures cost?
13 What additional risks might they introduce? And then
14 somehow, and this would involve policy considerations, it
15 wouldn't be strictly, I think, to arrive at some kind of
16 judgment, whether the features that have been provided in
17 response to the existing design basis accidents remain
18 adequate or changes are appropriate.

19 We heard from Harold Denton yesterday that for other
20 reasons, namely the concern about the ability to evacuate
21 out to 10 miles, they are thinking down this line in the
22 mitigative end for design at Indian Point.

23 But it's the kind of thing, I think, that one could
24 recommend or consider recommending as a step for trying to
25 make a rational decision.

1429 035

gshMMM

1 In other words, one can look to see what is your best
2 judgment now about contributors to the probability of an
3 accident, in these things here or for mitigated features.

4 Actually, you may not do radically different things for a
5 new design, except in new designs, from the beginning you
6 can look at how it's laid out to see whether you
7 unnecessarily introduced unreliabilities. Considering the
8 feedwater system, you might just as easily have made
9 that more reliable or maybe with not much effort, provided
10 the ability to ride out a loss of all power for 20 hours
11 instead of one hour, and so forth.

12 You know, when you think about some of these things, you
13 can make relatively simple changes from the point of view of
14 overall cost or complexity that provide certain abilities.

15 I think it's worth the committee's thinking about whether
16 it wants to consider this kind of recommendation. That's
17 sort of in my mind not saying, here are other design basis.

18 In my mind it's saying, let's look at what seemed to be
19 the probable source of accidents and seeing, are there
20 things that one can do to reduce these? And also, are there
21 features we think can mitigate accidents in a meaningful way
22 and at least develop the information?

23 Now I think that that recommendation is going to be made
24 by somebody else, whether we make it or not myself, or a
25 policy may be adopted.

1429 636

gshMMM

1 I really think the committee may want to recommend it.

2 MR. BENDER: I had covered a little bit of the
3 mitigation business in the discussion on siting. Maybe it
4 should have been put in there.

5 DR. OKRENT: In fact, the ideas are suggested in
6 what you have written, but it doesn't come through as an
7 actual recommendation. But you have suggested much of what
8 I've said.

9 MR. BENDER: Let me ask whether we can take this
10 approach in order to have something that represents a
11 closure position on this section.

12 Did I follow the thought that Dade offered that since
13 TMI 2 came very close to design basis conditions, that
14 perhaps -- probably there should be an examination to see
15 whether the umbrellas should be brought to deal with other
16 kinds of contingencies?

17 Would that be an overstatement or an understatement?

18 PROF. KERR: I didn't hear him say that, but maybe
19 you did.

20 MR. BENDER: Maybe I didn't hear him say that.

21 DR. MOELLER: I think that says -- I think that's
22 a worthwhile statement.

23 PROF. KERR: You think you should have said that even if
24 you didn't? Dave, I thought you were saying
25 something that really didn't have much to do with design

1429 037

gshMMM 1 basis accidents; rather, you were saying that we ought to
2 look at existing plants to see what the risk profile is to
3 see if there are some obvious things that one can do to
4 reduce the risk. And one ought to look at new plants to see
5 if similar changes that are perhaps easier to initiate could
6 be introduced.

7 DR. OKRENT: In effect -- no, that's what I said.
8 I'm in effect saying that the design basis accidents that we
9 currently have been using, or have been used in the recent
10 past, don't of themselves automatically provide
11 inadequate --

12 PROF. KERR: I would interpret that approach to be
13 a rather significant departure from the design basis
14 accident approach.

15 DR. OKRENT: Yes.....

16 DR. CARBON: Would you finish your sentence before
17 Bill interrupted there? You said that you don't feel the
18 design basis accident necessarily what?

19 DR. OKRENT: Provides an adequate protection
20 to public health and safety.

21 That's an understatement of what I think.

22 DR. CARBON: I would like to support this quite
23 strongly. I tried to say in that write-up there not that we
24 should do away with the design basis accident, design beyond
25 Class 8, necessarily, but that we certainly ought to look at

gshMMM 1 and study and explore beyond Class 8 to know what can
2 happen, might happen, what kinds of changes we might easily
3 and readily make which would appreciably increase safety at
4 low cost and/or just to know what we may get into in some of
5 these accidents.

6 I don't think we should have been caught with our pants
7 down at Three Mile Island, and we were.

8 MR. EBERSOLE: When you say "beyond Class 8," are
9 you thinking in the context of worse consequences?

10 DR. CARBON: I'm really speaking in the context
11 of what we get into when we have partial, when we have
12 cladding melt, core melt. Not necessarily consequences, no.

13 MR. EBERSOLE: I think the critical thing is not
14 maybe the worst consequences, although they can be worse,
15 but rather, the different routes by which these same effects
16 can be produced.

17 DR. CARBON: The routes, the kinds of things that
18 lead us into questions about are there steam explosions, was
19 there a hydrogen problem?

20 MR. EBERSOLE: You know, the innocent beginnings
21 with the terrible, ultimate consequence.

22 DR. CARBON: Bill?

23 PROF. KERR: It's hard to be against additional
24 study, and I'm not sure I am.

25 I think the study of existing plants and the conclusions

gshMMM 1 that one reaches would have to be balanced against two
2 difficulties that appear to me to be very important.

3 One is a concern I have about backfitting existing
4 plants. I don't know how to evaluate the decrease in safety
5 that comes from backfitting. I am sure it is significant.

6 Anything you do to try to go in and change an existing
7 system is just very likely to foul things up. It also may
8 improve things. But I don't know how to evaluate. You can
9 do the paper studies and convince yourself that you would
10 have a decreased risk, but I don't know how to do the study
11 that describes the damage done by workmen and other people
12 to an old system which is critical to a new system.

13 It doesn't mean that you don't do it. But I think not a
14 sufficient amount of attention has been given to this in the
15 backfitting problem. Maybe implicitly it has.

16 The second difficulty is one with which we are beginning
17 to wrestle with already, and that is having the risk
18 numbers, how you decide how far you go? Do you conclude
19 that all existing plants are too risky and therefore, we
20 have got to reduce the risk? And so anything we sort of
21 start with those items of increasing reduction and work down
22 until we run out of resources?

23 Or do we, in endorsing this approach, attempt to set a
24 risk basis, or do we take a, what is it, not an ALARA, but
25 what was the thing that was coined yesterday, AGARA?

gshMMM

1 That strikes me -- we are going to have to do explicitly
2 or implicitly if the study has any significance. Otherwise,
3 we just study and find out where the risks are, but we don't
4 know what to do about them.

5

6

7

8

9

10

11

12

13

e-4

14

15

16

17

18

19

20

21

22

23

24

25

8176 05 01

kap/MM

1 DR. OKRENT: I think we are always taking an AGARA
2 approach, as it were. If you make no changes, you decide
3 that what you now have is as good as is reasonably
4 achievable, because anything beyond this is not worthwhile.
5 And I certainly am not in favor of trying to make every
6 plant that's built the same as a plant I would build. I
7 think that's not the central approach. I think there are
8 two or more advantages, major advantages, to trying to look
9 at existing plants to see where you think there may be weak
10 spots. By that, I mean potentially high probability sources
11 of problems.

12 In the first place, some of them you may not have
13 known about and they may be really not all that hard to
14 remedy rather quickly. They will also bear on your
15 operating experience, on how you interpret operating
16 experience and so forth.

17 I think that kind of study is worth recommending.
18 I think it's going to be done. As I say, it's starting to
19 be done, in fact, the staff is doing it. Right now they
20 have been doing a systematic evaluation program, not in
21 those terms. This is sort of what bothers me a little bit.
22 They are looking at -- expending a lot of effort and they're
23 looking at these plants in what I will call the
24 old-fashioned framework.

25 As part of that, one could be doing this other

1429 042

8176 05 02

bop/MA

1 kind of look instead. What is going to happen, probably, it
2 will be done sequentially or as two separate things. But
3 yet, the things they arrive at by their current look, in
4 their systematic way, they may or may not pick up things
5 which are of as much interest, let's say, as you would get
6 by an event tree kind of look at these plants.

7 DR. SHEWMON: I don't like what I'm hearing, I
8 think. We haven't got more than half way through the
9 current safety evaluation program, or whatever it is we have
10 for older reactors, and now you're suggesting that we hurry
11 up, tell them to hurry up with that so they can start off
12 with yet another one which uses different approaches -- and
13 do it all over again?

14 DR. OKRENT: No, what I'm saying is I think that's
15 what's going to happen, is that they're going to do it --

16 DR. SHEWMON: So that we might as well hurry up
17 and get in front of the cow because we're their leader --
18 pardon me, finish your sentence.

19 DR. OKRENT: I'll try. What I said was: the
20 existing systematic evaluation program is not being done
21 using an approach like, for example, they are going through
22 at Crystal River, looking at different possible contributors
23 to risk and so forth. I think more and more, if not all the
24 plants, in fact, are going to get a look at their systems
25 like was done for the auxiliary feedwater systems. But it

1429 043

176 05 03

1 will be done system-by-system or plant-by-plant, or both. I
2 don't know about that, but I have little doubt that that's
3 the trend.

4 PROF. KERR: Dave, I don't think I disagree with
5 what you suggest. I am suggesting that, I think what you
6 have come up with isn't complete unless you decide what
7 you're going to do with it. You know, it's a start, but at
8 some point, you know, we can look at the auxiliary feedwater
9 system and conclude that out of 100 there is one that's more
10 reliable than all the others. So maybe there's one that's
11 100 times as reliable as all the others, and we have sort of
12 got the feeling that probably that one ought to be
13 eliminated.

14 That doesn't really tell one, however, how much
15 one has contributed to the reliability of the total power
16 plant or to the reduction of risk, unless I know something
17 about the way in which auxiliary feedwater systems
18 contribute to overall risk. We have a feeling that they are
19 bad because of TMI and we had a gut feeling, I think, that
20 it was bad, even before that because you certainly don't
21 want something that you are depending on in an emergency to
22 be extremely unreliable.

23 But if we're going to do this in a systematic way,
24 I think we have to look at these systems in the context of
25 what they contribute to the total plant risk. And I haven't

1429 044

16 05 04

1 seen anything that necessarily demonstrates what the system
2 contributes to the total plant risk yet. Rather, we are
3 concentrating on auxiliary feedwater systems. I don't think
4 that's all bad; we do the same sort of thing with diesel
5 systems. We've got a nice criterion for the reliability of
6 diesels to start, in the context in which we don't really
7 have a requirement for what the reliability of the emergency
8 power system should be.

9 Well, you're more aware of these examples than I
10 am. So I'm saying, it has to be embedded in some sort of --

11 DR. OKRENT: That's why I said larger profile.

12 MR. BENDER: I would like to suggest this: as
13 this thing is written, it says when we get it we ought to
14 use the risk methodology, but we don't have it right now.
15 And I think that's somewhat evident by the discussion.

16 MR. EBERSOLE: Don't we have it in a relativistic
17 sense, though, and usefully so?

18 MR. BENDER: I don't know how useful it is for
19 making judgments.

20 MR. EBERSOLE: I'm talking now in a purely
21 relative way.

22 MR. BENDER: Relative means you can decide whether
23 X is better than Y. I think you can do some of that.

24 MR. EBERSOLE: That's important.

25 MR. BENDER: But it won't help you very much in

1429 045

16 05 05

K/MA 1 determining whether you should decide to design the
2 engineered safety features on the basis of the core being
3 melted down in the containment, as opposed to the core being
4 -- sitting in a coolable configuration.

5 MR. EBERSOLE: I think you start with the latter,
6 in the "prevent" logic.

7 MR. BENDER: That's the kind of thing I am trying
8 to establish now. The design basis says you can maintain
9 the core in a coolable form, and that you can provide safety
10 features that will assure that, and that the containment
11 will hold in the radionuclides. Now, how we get there
12 involves a lot of things. Some of them have to do with how
13 long we have emergency power, and some things have to do
14 with whether we can have auxiliary feedwater supply if the
15 primary feedwater disappears.

16 But still, those are implementing things
17 associated with just keeping the core in a coolable form,
18 being able to get some cooling to it. Now, my question is
19 really: are we satisfied to say the design basis should
20 stay where it is, as a coolable core that is contained by
21 the secondary containment device or primary containment
22 device around it? That's the kind of questions being asked
23 right now, I think.

24 MR. EBERSOLE: It's not first design basis,
25 though, is a reasonable cost to never let the core be

1429 046

76 05 06

k MM 1 damaged?

2 MR. BENDER: That's a reasonable objective, one
3 which we all want and everybody is striving to get, some
4 people with better judgment than others, Jesse, but
5 everybody is trying that.

6 DR. CARBON: Doesn't the Rasmussen study say
7 something about that, and doesn't it say the chances for
8 core meltdown or non-coolable geometry are relatively
9 probable?

10 PROF. KERR: What does relatively probable mean?
11 Relative to what?

12 DR. CARBON: Something that's going to occur
13 occasionally.

14 MR. BENDER: They predict core melting. What
15 about one in every 10,000 reactor years, is that the number?

16 DR. LAWROSKI: 20,000.

17 DR. CARBON: 10-to-the-minus-four.

18 MR. BENDER: That doesn't necessarily mean
19 anything more than that some of the fuel melted, but it
20 didn't necessarily mean that you couldn't cool the core
21 after it melted. And consequently the premises might be,
22 never be any different if you have some core melting than if
23 you do.

24 MR. EBERSOLE: By the way, I'd like to get a
25 clarification on the melting problem. We talk about fuel

1429 047

76 05 01

k MM

1 melting, when we ought to distinguish between clad failure
2 and fuel melting, because clad failure is not necessarily
3 fuel melting. I don't guess TMI has had any fuel melting.

4 MR. BENDER: I do, in fact, differentiate between
5 them. I don't know whether TMI has fuel melting or not.
6 Some people say it has and some say it hasn't.

7 MR. EBERSOLE: Anyway, it's an important
8 difference. Clad melting is not going to propagate through
9 the containment, probably.

10 MR. BENDER: The only thing that will permit
11 propagation through the containment is uncoolable fuel
12 sitting in the bottom of the reactor of the containment.

13 MR. EBERSOLE: That's the top side. Pellets.

14 MR. BENDER: where the heat has to be dissipated
15 through.

16 MR. EBERSOLE: Right.

17 MR. BENDER: The point I'm trying to establish now
18 is whether we're satisfied to let the staff develop a design
19 basis and say that its engineered safeguards are designed to
20 deal with the event where the core is coolable.

21 DR. OKRENT: Well, the staff is departing from
22 that design basis.

23 MR. BENDER: I know that. That's exactly why I am
24 pushing the point right now.

25 DR. SHEMMON: The evidence we have of staff design

1429 048

16 05 08

KMM

1 deviating from that is the fact that they are willing to
2 talk about core melts again yesterday?

3 DR. OKRENT: It's in the long-term lessons learned
4 final report, or whatever you want to call it. They
5 recommend rulemaking for substantial amounts of hydrogen
6 buildup and for filter vented containment and other measures
7 that relate to accidents involving large-scale or full core
8 melt.

9 DR. SHEWMON: Large amount of hydrogen buildup
10 doesn't require core melt.

11 DR. OKRENT: But I said both of those are in the
12 recommendation.

13 DR. CARBON: You're talking about FNP.

14 DR. SHEWMON: I'm not talking about FNP.

15 DR. CARBON: No, no, the staff is. Also, core
16 ladles at Zion, Indian Point.

17 DR. OKRENT: In fact, they're talking about
18 implementing these things on Indian Point and Zion long
19 before the -- or the possibility of it, not about
20 implementing, but they're starting to study it well before
21 they would get into rulemaking in a general way.

22 DR. CARBON: I think our past practice of sort of
23 just drawing the curtain at the Class 8 accident and
24 refusing to look at, think about and study anything having
25 to do with core melt is totally wrong. I personally believe

1429 049

16 05 09

k YMA

1 that. And I think that that policy is what caused all the
2 ruckus at Three Mile Island.

3 If we had been prepared to handle the hydrogen
4 problem without scaring people out of their wits, and had
5 had answers to the steam explosion problem without scaring
6 people, there wouldn't have been any serious sort of thing
7 at TMI.

8 DR. SHEWMON: What scared them was the staff not
9 knowing how hydrogen got recombined. That wasn't a matter
10 of the nation's lack of understanding; it was their own
11 staff people opening their mouth.

12 DR. CARBON: That they hadn't looked at it.

13 DR. SHEWMON: Other people in the country
14 knew it. The staff never headed in the right
15 direction.

16 DR. CARBON: But the staff hadn't.

17 DR. SHEWMON: The research program ought to be to
18 educate the staff before they open their mouth.

19 MR. BENDER: I guess I would have to say Roger
20 Mattson hadn't thought about it, Vic Stello had. They had
21 thought about the same length of time, but they had come to
22 different conclusions.

23 DR. CARBON: Okay, but somebody should have
24 studied this thing ahead of time so that people didn't get
25 caught by surprise. But people got caught by surprise and

1429 050

176 05 10

1 they shouldn't have been.

2 PROF. KERR: Well, it would be nice if we could
3 ensure that nobody ever got caught by surprise, but I guess
4 I'm not that sanguine about the future. Hal Lewis pointed
5 out, I think it was yesterday, that the Rasmussen study
6 predicted a Three Mile Island type accident about once every
7 500 reactor years, and that's sort of what we got. So it
8 wasn't really lack of study or lack of knowledge that caused
9 the difficulty.

10 DR. CARBON: To a considerable extent it was.
11 People weren't prepared for it. They hadn't thought about
12 it.

13 PROF. KERR: It wasn't because the situation
14 hadn't been studied, Max, it had been studied very
15 carefully.

16 DR. CARBON: By whom? Who expected hydrogen?

17 PROF. KERR: If people didn't expect it, they just
18 hadn't looked at the results of that study.

19 DR. CARBON: They must not have.

20 DR. SHEWMON: Max, what scared people was the
21 staff announcing that there was a probability of hydrogen
22 inside the pressure vessel exploding. That's physical
23 nonsense. Everybody who looked seriously at it since the
24 first water reactor knew better than that.

25 DR. CARBON: Yes, but all I'm saying is that our

1429 051

176 05 11

K/MA
1 current staff people, when that hydrogen showed up it caught
2 them by surprise. They hadn't thought through, Will this
3 explode or won't it explode? You may have, but they
4 hadn't. And not having anticipated it, not having thought
5 about it, not having had answers to it, they came out with
6 some ridiculous statements and as you say, scared high hell
7 out of people.

8 MR. EBERSOLE: Why were they ridiculous? In fact,
9 if just hydrogen was there there was a spike, wasn't there?

10 DR. SHEWMON: In the containment.

11 MR. EBERSOLE: That was in the containment. That
12 spike could have been of a nature to blow the containment --
13 it would have to be out in the containment. It would have
14 to be released to a point where it could explode because of
15 the presence of oxygen, but then, it could have produced a
16 spike which -- in particular in the case of these 12 psi
17 containments -- could've absolutely blown it.

18 I really don't think the evacuation instruction
19 was all that much out of order.

20 DR. SIESS: Based on the wrong reasons.

21 MR. EBERSOLE: Yes, that's all.

22

23

24

25

1429 052

Cr. 8179
t-
sls-1

1 My point was the staff should have gone through some
2 areas like this, looked at this, had some areas like this,
3 prepared their answers ahead of time.

4 PROF. KERR: You're sort of saying instead of a
5 design basis accident the staff should study every possible
6 accident including ones we haven't thought of. If one is not
7 going to be surprised, one is going to have to study every
8 possible accident that can occur.

9 DR. CARBON: No, I think you go at it from
10 the standpoint of assuming partial core degradation, some more
11 core degradation. Worse, I don't know how you get there.

12 MR. LEWIS: One thing you can do, though, which
13 many people have said -- of course you can't study every
14 possible accident. You wouldn't want to. But what you can
15 do is start at the top of the maligned Rasmussen list and go
16 down them one at a time and make yourself sufficiently
17 educated that you won't be surprised if Rasmussen is right
18 and the relative ranking, let alone the absolute numbers,
19 even with you know 30 percent or 50 percent exceptions in
20 which they are dramatically wrong, then doing that for the
21 top 50 accidents is going to give you a reasonable assurance
22 that you won't be surprised by the next accident. That's a
23 way of doing it.

24 PROF. KERR: But that's already been done.

25 MR. LEWIS: I don't think it has.

sls-2
1 PROF. KERR: I mean the study is there. People have
2 looked at it in enough detail.

3 MR. LEWIS: But they are gun shy about taking it
4 seriously now for reasons we needn't discuss.

5 PROF. KERR: But now you are back to the Kemeny
6 Commission recommendations which is that the attitudes have
7 to be changed. We aren't really asking for additional studies,
8 we're asking for different attitudes.

9 DR. MARK: The problem here seems to be really more
10 fundamental than what you are saying. It is impossible to
11 think of anyone knowing enough and certainly not many people
12 knowing enough so that they may not be surprised by something
13 to which they haven't given much attention. What you've got
14 to hope for and which might even be manageable is either to
15 persuade people or have such people that they are unwilling
16 to give opinions about things of which they know they haven't
17 thought. And unless you have that you are always going to
18 have goofy opinions appearing.

19 DR. CARBON: But let's think about some of
20 these.

21 DR. MARK: Think as much as you can. You will still
22 be surprised. You ought to recognize what you know and what
23 you don't know and only talk about the things of which you
24 know you've got a basis for talking. And unless you have that
25 you are always going to have somebody saying something wrong.

sls-3
1 DR. CARBON: Paul?

2 DR. SHEWMON: Let me come back to Mike's point about
3 coolable geometry. I guess the thing I would hope would come
4 out of this staff study, or whatever, is some reasonably
5 careful thought be given to getting the first fuel melting
6 someplace in the core, the molten core at the bottom of the
7 pressure vessel.

8 For example, whether Pigford's comment -- sorry, the
9 staff of the Kemeny Commission saying indeed they couldn't
10 get the core disassembled and down it.

11 I am particularly concerned or interested in the possi-
12 bility in the modes of transition between the first bit of
13 fuel melting someplace in the core and this transforming to
14 what is often assumed of as a core melt which is, gee whiz,
15 we can't think of how it got there, maybe, but let's assume it
16 is down there as an uncoolable mass and then see what happens.
17 That's certainly worse than what other possibilities you might
18 come up with.

19 This offense may intellectually vary substantially. I
20 think the Germans have done a much better approach at this than
21 we have. They have at least considered it and apparently the
22 Kemeny Commission staff looked at it. And if we get into
23 this I guess the only thing I would urge is that a fair amount
24 of work be done on the possibilities and probabilities of that
25 transition instead of what I look upon as a cop-out to go to

1429 055

sls-4
1 this uncoolable mass and talk about it migrating towards
2 China.

3 DR. OKRENT: Actually, the methods for calculating
4 the pathway of the fuel, assuming you lose an ability to
5 cool it where it originally was, were developed in the U.S.
6 before they were developed in Germany.

7 DR. SHEWMON: My point was when the first bit of
8 fuel melts to the core -- now, once you can't cool it, I grant
9 you are headed downhill on grease skids, but that is a big
10 assumption from where I started.

11 DR. OKRENT: But there are some events where you
12 lose your ability to take the heat away. Now, if you are
13 going to say let's not consider any events where you lose
14 your ability to take the heat away, you've got a situation
15 where you won't be able to take the heat away. I agree.

16 DR. SHEWMON: The most recent cop-out is ATWS. If
17 we yield any part of the core we assume a meltdown. That was
18 the staff's best effort. And there is a long way between
19 yielding the highest best part of the pressure vessel and
20 melting a whole core I would argue.

21 MR. BENDER: Mr. Chairman, what I would like to
22 pose to the Committee that I do with this section is to just
23 make the point that the present design basis which is no
24 core melting with containment will probably continue to be
25 used as a basis for design. But both the probabilistic

sls-5
1 analysis and some broader overview of other accidents probably
2 should be continued in order to get a better understanding of
3 what the potential risks are from using the current design
4 basis.

5 Now, that sounds like sort of copping out, but right now
6 I don't see how I can say much more than that. We are still
7 working on the basis that we expect to keep the core cool. Now,
8 in the event of a serious accident, TMI 2 notwithstanding,
9 that the engineered safety features should be designed with
10 that thought in mind.

11 Now, there is a question about whether the survivability
12 of the engineered safety features should be evaluated beyond
13 that point. And I don't know whether that has come out of
14 this discussion.

15 DR. OKRENT: I don't agree that we are working on
16 the basis that you have described. I think that was the
17 basis, but I think the staff is moving away from the basis. If
18 the Committee wants to stay with it, I suppose it can, but it
19 is going to be left behind. I am not myself prepared to say
20 that that's going to be the case.

21 MR. BENDER: We don't know where the staff has
22 gone. They are going off helter-skelter in a lot of directions
23 as nearly as I can tell with not knowing as Bill pointed out,
24 I think rightly, whether the changes that might be made in
25 existing plants wouldn't do more harm than good. 1429 057

sls-6
1 DR. OKRENT: It might. But we can use that argument
2 to say don't look because it might, but that's not what Bill
3 did. But I am saying that it can be turned around that way.
4 I think the handwriting is on the wall. People are going to try
5 to do more to prevent these things and there's going to be a
6 lot of effort. But they are also going to try to do things
7 to mitigate them as they see that there are ways to do it.

8 DR. CARBON: Dade?

9 DR. MOELLER: I thought we were beginning to zero
10 in on the following conclusion or statement. That is, that the
11 design basis approach, accident approach, does provide an
12 umbrella, but we do not consider that umbrella broad enough
13 particularly at the top end. In other words, we do not consider
14 that the DBA as currently envisioned provides an adequate
15 basis for the design of plants that provides sufficient
16 protection to the health and safety of the public and it needs
17 to be expanded. And I think that's what we have to say.

18 DR. CARBON: I don't believe that the DBA is
19 adequate. To go back to Jesse, you were talking about --
20 I assume that you would define TMI as the core was not
21 cooled. There's no question about that. So, hydrogen was
22 released and we are talking about venting the hydrogen to get
23 it out of the top of the pressure vessel because it's down
24 there. I don't know whether we are still going to do that or
25 not.

1429 058

sls-7
1 And then we get into this possibility of blowing up
2 some of the 12 PSI containment systems. Blow up is too bad
3 a word, I suppose, but I don't think our engineered safety
4 features are enough if there's a possibility of rupturing
5 the containment due to hydrogen release that way. And maybe
6 we came close to it there, I don't know. But I question --

7 MR. BENDER: Let's take it one step further then
8 and say, Okay, we have to cope with the next level, whatever
9 that is.

10 Let's presume it's a hydrogen explosion and core
11 melting of some degree. How do you plan to draw the next
12 line?

13 DR. CARBON: I don't know because I don't know
14 what the next line is. I would hope -- I would want to do at
15 least two or three things, and one is to find out what these
16 lines are and to try to put some probability to it and I guess
17 beyond that I don't have the answer. I don't know.

18 MR. BENDER: Well, in the interim period here are
19 the plants built. There are engineered safety features that
20 deal with the existing design basis accident. There are about
21 70 plants in operation today, as I understand it which have
22 that design basis accident. And I have to ask myself if I want
23 to have some different accident than that, what am I telling
24 myself? What am I telling the public? And what do I expect
25 to do to make those plants conform to my new designs?

DR. CARBON: I guess I can answer part of that.

If I were to carry out the studies and to conclude that, gee, truly there is a potential for rupture of a containment in the current plants due to a hydrogen explosion in a TMI incident, I think the thing I would immediately do is to try to explore vented containment on maybe a crash basis or some such thing.

PROF. KERR: Max, you don't have to carry out a study to know that there is a potential for hydrogen explosion in every containment that exists. We know that. It isn't a question of whether the potential exists, it's what the probability is.

1429 060

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

sls-8

End t-6

PV MM

1 PROF. KERR: So, you have got to decide that
2 either you're going to have an absolutely risk-free system
3 or else you're going to have to decide what level of risk
4 you're willing to accept.

5 DR. CARBON: But we have concluded, I believe,
6 that unless we get the amount of hydrogen from clad melting
7 that we can take care of the hydrogen in the containments.
8 The probabilities are very, very low.

9 PROF. KERR: But I don't think we have
10 containments which we can take all of the hydrogen that
11 would be generated, all of the cladding --

12 DR. CARBON: No, no, we don't. In the past, we
13 have based our --

14 PROF. KERR: Then there is a potential. We don't
15 have to do any studies to know that there is a potential for
16 a hydrogen explosion in every containment that exists. So,
17 if I follow your statement to its logical conclusion, it
18 seems to me you would recommend shutdown for all the
19 operating reactors.

20 DR. CARBON: No, because I don't know today
21 whether we came close to getting enough hydrogen to rupture.

22 PROF. KERR: But you know that a potential for
23 hydrogen explosion exists in every reactor containment.

24 DR. CARBON: But I want to put it partly certainly
25 on the basis of probability. I don't want to put things

1429 061

76 07 02

pv MM

1 totally on potential.

2 PROF. KERR: What probability are you willing to
3 accept?

4 DR. CARBON: I don't know. I have not studied
5 it. I haven't thought about it.

6 PROF. KERR: There isn't a lot of point in making
7 the probabilistic study unless you have at least some idea
8 what probability you are willing to accept. I don't mean
9 you have to have an exact number, but within maybe a couple
10 of orders of magnitude you need to know. Otherwise, when
11 you get through, the numbers won't help you make a decision,
12 either.

13 DR. CARBON: I guess I would say if the Rasmussen
14 report says probability of core meltdown is 10^{-4} and then if
15 the Lewis study says it may be off by a factor of 10^{-2} ,
16 raising it to 10^{-2} , I am concerned.

17 PROF. KERR: See, the Rasmussen study really said
18 -- and perhaps not with the proper conclusion -- said
19 hydrogen didn't have much to do with the probability of core
20 melt.

21 DR. CARBON: May not have much to do with the
22 probability of core melt. But what did it say about the
23 probability of rupturing the containment and having the kind
24 of --

25 PROF. KERR: I am simply saying if you're willing

1429 062

76 07 03

pv MM

1 to accept the Rasmussen study risk numbers -- using those
2 kinds of containments, of course -- then you don't have to
3 worry about hydrogen.

4 DR. CARBON: But obviously, we -- I can't accept
5 it, then. It appears that we had a hydrogen problem at
6 TMI. We had some sort of burp on the containment.

7 MR. EBERSOLE: Mr. Chairman, isn't it true that
8 the Rasmussen report did not couple a core
9 melt to a containment explosion and thereby did obtain the
10 low probability of containment failure via that route? In
11 short, if one looks at the core melt probability, there is
12 now recognized a potential for consequential containment
13 failures as well as hydrogen explosion.

14 DR. CARBON: There is now because of our TMI
15 experience. But you are saying, are you then, that the
16 Rasmussen study didn't couple those?

17 MR. EBERSOLE: I think they looked upon --
18 somebody can say.

19 MR. BAER: Yes, I worked on the Rasmussen study.
20 We ducked the question of partial core melt. The assumption
21 was made that if you exceed a design basis condition, you
22 got a complete core melt. In that event, you penetrated the
23 containment by one means or another, either by melting
24 through or gas generation from disintegration. And in that
25 event, the hydrogen was, I think, judged to be probably the

1429 063

76 07 04

pv MM

1 least probable mode of containment failure. But the
2 assumption was made that you had a probability of one of
3 failing the containment once you melted the core.

4 MR. LEWIS: That was a deceptive probability for
5 many people because the major fraction of that was what Jane
6 Fonda would call the "China Syndrome." That is, going
7 through the bottom wall of the containment, whereas the
8 kinds of -- and then that leads to all kinds of questions of
9 liquid pathways and things like that. But the kinds of
10 catastrophic release that people are most concerned about
11 was a small fraction of the core melt instances. And it
12 was, as I recall -- and you correct me on this -- it was
13 either overpressurization over a period of time or a steam
14 explosion.

15 So, you're quite right that hydrogen explosions
16 were a small fraction of that, and the probability for steam
17 explosions given in the Rasmussen report was, as I recall,
18 drawn entirely out of the whole cloth.

19 MR. BAER: Very broad range. I don't recall --

20 MR. LEWIS: It was invented. It was given as .1,
21 and it was simply invented.

22 MR. BAER: I think a major point was we didn't
23 consider partial core melts. Three Mile Island situation
24 was never considered.

25 MR. LEWIS: That's certainly right. And if you

1429 064

76 07 05

pv MM

1 took the methodology and you started with what actually
2 happened at Three Mile Island, you would have gone all the
3 way. That is, no mitigated features once you started --

4 MR. BAER: That was one of the assumptions.

5 DR. SIESS: I need some help. If there is enough
6 hydrogen released to the containment that you cannot control
7 it with recombiners, what's the probability that there will
8 also be a significant amount of radioactivity in there? It
9 seems to me it must be close to one. So, what we are
10 saying, then, is that a hydrogen explosion that reaches
11 containment automatically releases radioactivity.

12 MR. LEWIS: Yes.

13 DR. SIESS: More than Three Mile Island,
14 obviously; less than a PWR-2, I assume.

15 DR. OKRENT: Yes.

16 DR. SHEWMON: I don't know whether it is too
17 wild-eyed to take any credit for, but there is a significant
18 range variously quoted from 10-15 and 15-20 percent hydrogen
19 and air at which the stuff burns instead of explodes. And
20 the best thing is that that's indeed what happened in
21 Three Mile Island. So, they call it a "pulse" and not an
22 "explosion." I think that's the distinction we probably
23 should stay with.

24 MR. ETHERINGTON: I think the same study, pressure
25 either way. The pressure depends on the temperatures you

1429 065

76 07 06

pv MM

1 get --

2 DR. SHEWMON: So on the ice condensers you are out
3 of luck; on the others you may end up sort of expanding
4 things with one case but not --

5 MR. ETHERINGTON: That's right.

6 DR. CARBON: But, Paul, this is exactly what I am
7 aiming at here. You're speculating. You bring a point up
8 here, and it may be completely correct, but I think somebody
9 ought to be able to walk in this room and tell us exactly
10 what the story is in each of these cases, that there is --
11 that something will explode or it won't, burn or it won't,
12 that the pressure will be such and such, that we don't have
13 to sit around here and speculate.

14 MR. BENDER: Look, there's a lot known about when
15 hydrogen will or won't burn. What is not known is what the
16 concentration of hydrogen is under the circumstances when
17 the accident occurs. Where is the hydrogen and what kind of
18 mixes do you have.

19 Now, if that's to be decided, it's to be on the
20 basis of pure speculation, because the mechanism for getting
21 out is not very well known, and there's no way to determine
22 it. We'd have to go through 15 different accidents --

23 DR. SIESS: I was trying to get back to what
24 Harold said. Suppose there were an ignition point or points
25 inside the containment so that as soon as hydrogen reached

1429 066

76 07 07

py MM

1 the flammability level it burned, but the supply of hydrogen
2 was continuing, the static pressure would still build up.
3 Right?

4 MR. ETHERINGTON: (Nodding affirmatively.)

5 DR. SIESS: From the temperature.

6 DR. PLESSET: Chet, you're releasing energy,
7 you're going to heat up the containment.

8 DR. OKRENT: It depends on whether your sprays are
9 on or whether you have an ice condenser and the ice will
10 condense.

11 DR. SIESS: Unless you postulate some ignition
12 source. If you're going to let the hydrogen build up to an
13 explosive level and then ignite it, you've got a problem:
14 the containment is going to be breached, and the reactivity
15 is going to be released.

16 MR. BENDER: There is a move going on in the staff
17 to consider inerting some containments on the basis that
18 they might not be able to withstand the pressure built up by
19 the hydrogen pressure.

20 DR. SIESS: I don't think there's any containment
21 built up to the hydrogen burn if it's uncontrolled,
22 unlimited.

23 DR. MARK: It is almost certain that what went on
24 in TMI was an explosion and not a burning.

25 DR. PLESSET: What was that?

1429 067

76 07 08

pv MM

1 DR. MARK: I say it seems to me it's at least
2 essentially certain it was an explosion and not a burning.

3 MR. LEWIS: It was a spike.

4 (Simultaneous discussion.)

5 DR. PLESSET: It wasn't a real detonation.

6 DR. MARK: I agree with that. But that pressure
7 was down in four seconds.

8 DR. SIESS: It does matter, because you can get a
9 higher pressure transient if it explodes. You get a shock
10 wave --

11 DR. PLESSET: That's not necessarily bad.

12 DR. SIESS: Not necessarily, but you have to
13 analyze it.

14 DR. PLESSET: I don't think we know enough about
15 that kind of an effect if we get a shock compared to a
16 gradual pressure rise.

17 DR. SIESS: As far as the resistance of the
18 containment to it, I don't think so, especially if it's
19 localized.

20 DR. PLESSET: How can it be localized?

21 DR. SIESS: I worked a lot in the dynamic
22 resistance of structures, and I don't think we know all that
23 much about it.

24 DR. PLESSET: Localized in what sense?

25 DR. SIESS: A local explosion.

1429 068

76 07 09

py MM

1 DR. PLESSET: But the explosion is going to
2 propagate in the containments; it's not going to hit at one
3 point.

4 DR. SIESS: No, but it won't hit all of it at the
5 same time, either. If it starts from one side, you get
6 unsymmetrical loadings, for example. It depends on where
7 the shock wave originates. But I don't get that much
8 automatic comfort from the dynamic resistance for dynamic
9 impulse versus the static. I would have to go into it a lot
10 farther than we have.

11 MR. LEWIS: This kind of question, the kind of
12 question you are discussing, depends on the relative speed
13 of sound in the concrete and the shock wave in the air and
14 that sort of thing. And you're right: that has to be
15 analyzed on a case-by-case basis. But there's not that much
16 difference, is there, between the sound speed in the
17 concrete, reinforced concrete, and the shock speed in the
18 air of a hydrogen explosion?

19 DR. SIESS: It's not quite that simple. It's the
20 response of the structure, not just the transmission through
21 it, and there's been a lot of work done in connection with
22 weapons blast on both steel and concrete, but not on this
23 type of contained thing, that I know of. Maybe it's in the
24 classified literature. What I know about is building
25 shelters, that type of thing.

1429 069

pv MM

1 But I just say it's not that simple. I don't want
2 to dismiss the dynamic load problem.

3 MR. ETHERINGTON: It's not particularly easy to
4 get a shock wave of any significance in a large space
5 without pretty close to stoichiometric compositions, and I
6 think what we have is a deflagration and any shock --

7 MR. LEWIS: Could somebody educate me on what the
8 facts are? We all know the theory, but the spike itself,
9 what was the width of the observed spike and what fraction
10 of that was instrumental?

11 DR. PLESSET: I think it was just instrumental.

12 MR. LEWIS: It was simply an instrumental width,
13 so it could have been zero width as far as we know.

14 DR. SIESS: We got something on that.

15 DR. MARK: You got something on it from the
16 staff. The pressure was back down in four seconds. That
17 could not have been done by a spray.

18 DR. PLESSET: Not a microsecond or a millisecond.
19 It was seconds.

20 DR. MARK: But it takes --

21 MR. BENDER: We really need to zero in on how to
22 decide whether we want to stay with our current design basis
23 accident, and, if we don't, where do we want to draw the
24 next line. And the best I have heard, really, is still Max'
25 suggestion, even though I am puzzled about where to draw the

1429 070

pv MM

1 line. I suspect that about the best we can do is say we are
2 going to need to study more in order to determine where to
3 draw the line. And that's about all the recommendation we
4 can make right now.

5 But I would be very much inclined to say we should
6 change the design basis at this stage of the game without
7 knowing where we were going, even though I think Dade
8 suggests we ought to broaden the umbrella. I thought I
9 interpreted right what you are suggesting.

10 MR. LEWIS: Mike, isn't there a suggestion, at
11 least on the record, which we also accept or reject that one
12 rational way to broaden the umbrella is by reference to
13 WASH-1400?

14 MR. BENDER: Yes, I think so. But there is a
15 matter of when things are going to -- when something is
16 going to be done about something. I very much would like to
17 see a good probabilistic basis for designing things. But
18 things being what they are, I don't expect to see much that
19 engineering kinds of people can use for a few years or a few
20 decades. I am not sure which is right. It's not going to
21 be very fast.

22 So, I don't know much to do but to say, "Well,
23 let's look at what the consequences can be." In the old
24 days, what we did was say, "Well, let's see whether we could
25 go farther and still tolerate it in the sense of being able

1429 071

py MM

1 to go ahead with whatever the project is."

2 PROF. KERR: Mr. Chairman, I am not in favor of
3 progress in the wrong direction, but I do think we ought to
4 make some in some direction. Would it be possible for Dave,
5 for example, to prepare a paragraph, somebody else to
6 prepare a paragraph? There seems to me to be some consensus
7 that we need to move in the direction of a change. I would
8 be willing to consider some alternative paragraph and see if
9 we couldn't arrive at something.

10 MR. BENDER: I think that would be a constructive
11 thing to do.

12 DR. OKRENT: Would you write one, too?

13 PROF. KERR: I am willing to try to write one,
14 sure.

15 DR. CARBON: It's been suggested, Dave, will you
16 write one?

17 DR. OKRENT: I am willing to. In fact, I am going
18 to try to write a series of recommendations -- not
19 necessarily a complete set -- but I am going to try to go
20 through Knight's report and see what possible recommendation
21 would occur to me as being related to these, some of which
22 may be there openly or under the surface already. And I
23 would suggest that other people try to do the same thing,
24 because, in the first place, different things occur to
25 different people; and also, some of the same topics will

1429 072

pv MM

1 come out in a different flavor. And I will try to include
 2 one in this area as part of it. I haven't gotten very far.
 3 I think I have written one such or two such. But as I say,
 4 I will try to cover this also.

5 DR. CARBON: Bill, if you think your views would
 6 differ from what Dave might come up with, I would welcome
 7 your writing one, or use your own judgment.

8

9

10

11

12

13

14

15

E7

16

17

18

19

20

21

22

23

24

25

Cr. 8176
t-8
sls 1

1 PROF. KERR: My views are not that well settled,
2 but I can write us a different version so that we will have
3 something to consider. Not necessarily because I disagree with
4 him. I am not sure, but I have to decide an appropriate
5 direction at this point.

6 DR. CARBON: Mike, I wonder if we ought to take a
7 break here.

8 MR. BENDER: It sounds reasonable.

9 (Brief recess.)

10 DR. CARBON: Gentlemen, let me have your attention.
11 Before we start with the report again, let me bring up a
12 scheduling matter. It seems very desirable that we put as
13 much time on this report as possible. Mike cannot be here
14 tomorrow. Unless it is going to work a hardship on anyone
15 I would like to propose that we stick with today's work until
16 about 8:30 this evening. We are only scheduled until 7:15
17 now, but we will continue to about 8:30. And I imagine that
18 if we work on this, 7:30, 8:00 and so on, we'll all be
19 snapping and biting. So, what I would actually propose is
20 that we will move the NUREG 0600 activity back -- deferred
21 until late in the day such that we will be working on Mike's
22 report in the afternoon. Is this going to work a hardship
23 on anyone if we stick with it until about 8:30?

24 DR. PLESSET: It works a hardship on everybody.

25 (Laughter.)

1429 074

sls-2

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

DR. CARBON: Having heard no great complaints --

DR. MARK: Just stunned.

DR. CARBON: Just stay that way until I get this set up. Fine. Let's go ahead with the report then.

MR. BENDER: Let me go to the next section, and I'll just read it through.

"Criteria for nuclear power plants siting have revolved around definition of power plant exclusion areas, low population zones and the dependence which should be placed on engineered safety features to assure the health and safety of the public in the event of unforeseen accidents.

"At one time in the period of active power plant licensing the capability of engineered safety features was a major consideration in determining how closely a power plant could be sited with respect to population centers. More recently there has been a tendency to discount this dependence on engineered safety features.

"The effects of meteorology are still an important factor in airborne radioactivity dispersion and leak tightness of the containment system determines the availability of radionuclides to be dispersed.

"The recent accident at TMI-2, while not exposing the public to damaging radiation has shown that neither containment, leak tightness nor meteorology by themselves

1429 075

sls-3
1 are safety controlling features. Other factors within the
2 containment can have an ameliorating effect on dispersal."

3 MR. EBERSOLE: Do you want the comments as you go
4 on?

5 MR. BENDER: No, let me read through. We can go
6 back to it.

7 "The internal trapping capability of steam and
8 water, tankage and internal surfaces all contribute to the
9 reduction in potential for airborne radionuclide dispersal
10 following an accident. All measures are of some considera-
11 tion in determining the consequences of the more likely
12 accident. At the same time, minimum low compilation, zone
13 radius and maximum population density are undoubtedly
14 important if site evacuation is to be relied upon by the
15 public as the ultimate safety protection.

16 "The reactor safety studies show the likelihood of
17 core melt was high enough to deserve consideration in
18 siting. The extent of core melting determines the threat
19 to public safety."

20 And then if you just skip the next three lines and
21 start with the fourth line, "The WASH 1400 study indicated
22 that the hydrological path for dispersal in a direction
23 adversely affecting the public health and safety was
24 generally long enough to eliminate it as a short-term
25 threat to the public in the event of a melt-through

1429 076

sls-4

1 accident. The longer range implication of a melt-through,
2 as with other nuclear waste consideration was not considered
3 adequately by the reactor safety study and more attention
4 to the ultimate consequences of such events is needed.

5 "Siting criteria should be aimed towards establishing
6 sites best able to accommodate core melting contingencies
7 over the long term. In particular, the hydrological
8 considerations involving potable water systems should not
9 be ignored. Methods for protecting potable water systems
10 from radionuclide exposure should be practical for nuclear
11 power plant sites. Hydrogen generation by metal water
12 reaction is also seen to be a potential safety problem by
13 recent events. Hence, the question of potential for
14 hydrogen combustion as a threat to containment integrity is
15 a site-related concern.

16 "Experience at TMI-2 indicates a need for further
17 attention to the potential for hydrogen combustion because
18 consequential overpressure could rupture containment and
19 open direct airborne pathways to the environment beyond
20 the nuclear site."

21 And then I have added this sentence instead of the
22 one that's down there. "This containment failure should be
23 evaluated to determine whether siting practices are
24 influenced by this circumstance."

25 Now, to some degree that's an extension of what we

1429 077

sls-5
1 talked about in the previous section. But the orientation is
2 slightly different. It doesn't address the design basis
3 accident. It just says look at how we are deciding about sites
4 and consider hydrology in terms of what we might do to protect
5 potable water systems if there were a core melt-through and
6 consider whether the hydrogen combustion -- does this make us
7 want to worry more about airborne pathways? That's the
8 substance of it.

9 Jesse, did you want to comment?

10 MR. EBERSOLE: Yes. Over on the first page there
11 I thought there was a sort of a reversal of logically you say
12 in the first sentence, the fourth line, "the health and safety
13 of the public in the event of unforeseen accidents." In fact,
14 siting has always considered foreseeable or postulated
15 accidents, which is the LOCA, the mitigating systems that
16 mitigate it.

17 So, I think where you say unforeseen you should
18 say postulated and further down you say it one time in the
19 period of active -- the capability of the engineered safety
20 features with some major considerations. You ought to add
21 up engineered safety features mitigated unforeseeable
22 or postulated accidents.

23 In short we'd have a package there.

24 MR. BENDER: Okay. Good point.

25 MR. EBERSOLE: Finally over here on the second page

1429 078

sls-6

1 where you discount the concept of penetration, containment by
2 core melting, I call your attention to the fact that
3 penetration characteristically are located between the equipment
4 and environment rooms and the primary containment. Penetration
5 failure therefore may not have the benefit of atmospheric
6 diffusion but release radionuclides as well as steam and water
7 into the equipment environment, thereby compounding the
8 difficulty of maintaining long-term core cooling because of
9 the ultimate effect on the equipment.

10 MR. BENDER: I don't argue with that. As a matter
11 of fact, I think that will come up later in another part of
12 this discussion. This was just oriented to the question of
13 when we want to decide where a plant can be located, what should
14 we keep in mind?

15 MR. EBERSOLE: Not just luck. It's beyond that,
16 now.

17 DR. SIESS: Mike, you say hydrogen combustion is
18 a threat to containment integrity is a site-related concern.
19 Does that mean that there are sites where we don't need to be
20 worried about hydrogen combustion?

21 MR. BENDER: Let me put it this way: If the site
22 is remote enough, and the containment ruptures there would
23 still be a lot of opportunity for getting people out of the
24 path of the dispersed radioactivity, and the threat to the
25 people that are in the environs might be relatively small.

1s-7
1 DR. SIESS: I read that report by Von Hippel and
2 what's his name -- Belia, where they postulated larger releases
3 than Three Mile all the way up to Three Mile-2. And I don't
4 think I have to go up to the PWR-2 to find very few places
5 where containment breach wouldn't be a significant concern for
6 population and for property damage.

7 MR. BENDER: Well, I didn't say there wouldn't be
8 of significant concern. Again, as a matter of relative
9 risk we have to look at which property and which people are
10 threatened and you can't reduce the threat to zero. You can
11 decide --

12 DR. SIESS: A class 9 accident is a site-related
13 concern.

14 MR. BENDER: I don't know whether I should have
15 picked on hydrogen.

16 DR. SIESS: You know, containment breach by any of
17 the alpha beta through delta methods, other than the ground
18 release --

19 MR. BENDER: I think Jesse's point --

20 MR. EBERSOLE: May I comment on the whole argument?
21 The consequences may only be multiplied by a fraction of two,
22 three or four depending on the size of the nuclear part,
23 because at presently operating environment is not protected
24 from these sorts of events. It's not a design practice to
25 protect the operators from this, so therefore they would be

sls-8
1 victimized by this containment failure.

2 PROF. KERP: Unless it is multiplied by a factor
3 of ten it's inconsequential.

4 MR. EBERSOLE: On an investment basis that may not
5 be true.

6 DR. SIESS: It seems to me you could divide this
7 up into two parts; breach of containment through the bottom
8 where you then talk about the hydrological, and breach of
9 containment upward which you have the second paragraph doesn't
10 mention meteorology and so forth. Then you go to hydrology
11 and back to hydrogen generation. It should be lumped into with
12 that first one, I think.

13 DR. MOELLER: One aspect that this discussion
14 does not cover is the one that Jesse just mentioned. That is:
15 multi-unit sites versus single. I summarized what I hoped
16 were the thoughts on this in my summary of the site evaluation
17 subcommittee which is in the folder. Would it be appropriate
18 to look at a couple of paragraphs and see if you want to --
19 if any of them would be appropriate.

20 PROF. KERR: You had some paragraphs left over?

21 DR. MOELLER: It's in 7.1 and it's the last thing
22 in 7.1.

23 And Mr. Chairman, let me just ask if the Committee
24 would look it may be almost the last page. Well, we may have
25 to sort of look at most all of it, but it has a first page in

sls-9

1 which -- are you able to find it? It's the last thing in
2 Tab 7.1, the last three or four sheets -- three sheets.
3 The draft for -- first of all we did look at NUREG 0625, and in
4 that task force report they suggested two items which were on
5 the middle of the first page: A, that we establish various
6 parameters in determining the acceptability of proposed sites,
7 and two, we consider establishing minimum standards for the
8 number, type and level performance required for engineered
9 safety features to be incorporated into the nuclear power
10 plants so that you couldn't let distance negate having to put
11 those in.

12 Well, then at the bottom of the page we say, well,
13 these proposals have merit and should be evaluated. The ACRS
14 believes in terms of overall safety attention is also to be
15 directed to improving the effectiveness of existing sites.
16 This is particularly appropriate in view of the fact that
17 existing sites are in use while it is doubtful that many new
18 sites will be selected over the next few years.

19 And so there are several changes and approaches
20 that may have the potential for contributing to enhance safety.
21 These changes which have been proposed by among others, the
22 Institute for Energy Analysis would be directed to what's
23 considered by that group to be a more complete and effective
24 utilization of the best of the existing sites. And under that
25 approach, A, the new sites would be licensed by exception, not

sls-10
1 by rule. This would result in an increasing number of
2 existing sites serving as a location for multi-unit stations.
3 And they claim certain advantages for that.

4 And in the last page one of the major impacts
5 would be to limit the number of utilities licensed to operate
6 power plants and this Institute group claims that those that
7 do operate plants would have larger staffs which would be
8 better trained and qualified.

9 Now, the final paragraph points out, if on the
10 other hand one assumes the probability of an accident at a
11 multi-unit site, say a five reactor site, is five times or even
12 greater than that as a single-unit site, the wisdom of this
13 approach could be seriously questioned. And an accident at any
14 one unit would have serious consequences on any of the other
15 units.

16 And perhaps as Bender has suggested, we should
17 share expertise, rather than sites. If such an approach could
18 be made effective, and if the concerns are valid, this would
19 represent the better policy. Therefore, for siting we need
20 someone to look into this situation to gather the data so that
21 we can make a proper judgment.

22 PROF. KERR: I just want to determine what the
23 probability is at our five-unit site.

24 DR. MOELLER: I don't know offhand, but I do know
25 again, being a proponent of LER that you could look at the

1429 083

sls-11

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14
- 15
- 16
- 17
- 18
- 19
- 20
- 21
- 22
- 23
- 24
- 25

frequency of LER so the types of LERs that are occurring at multi-unit sites versus single-unit sites and at least begin to get some handle on the probabilities of failures at single versus multi-unit sites.

End t-8

1429 084

pv MM

1 DR. SIESS: In view of the uncertainties and the
2 probabilities expounded on in WASH-1400 and as enhanced by
3 the Lewis report, are we really worried about a factor of
4 five in probabilities?

5 DR. MOELLER: (Indicating negatively.)

6 DR. SIESS: I am concerned about that. I suspect
7 I could offset that by several things. I have a question
8 about Mike's draft here. In the first paragraph it's sort
9 of reviewing the history. It seems to me we ought to start
10 off with the idea that the early siting practice did rely on
11 distance of population. That was then changed to rely more
12 on engineered safety features. And the trend now in the
13 very recent sites study is going back to distance.

14 And in the second paragraph, I don't really see
15 how Three Mile Island showed that either containment
16 leak-tightness or meteorology are by themselves safety
17 controlling features.

18 MR. BENDER: I guess the interpretation I put on
19 it is something like this.

20 DR. SIESS: I think it showed the opposite.

21 MR. BENDER: There was a direct opening in the
22 containment, and yet the radioactivity didn't get out in
23 large quantities into the environment.

24 DR. SIESS: But it seems to me to say that there
25 were other factors that kept it from getting out besides

1429 085

pv MM 1 leak-tightness. Where was the direct opening in the
2 containment?

3 MR. BENDER: When the sump pumps operated --

4 DR. SIESS: But the activity that got out got out
5 through leakage in the auxiliary building.

6 MR. BENDER: That's exactly the point I was trying
7 to make. They said they were providing entrapment
8 capability. It wasn't really the containment itself that
9 was protecting the system. You may be right, Chet. There
10 are ways --

11 DR. SIESS: What this says to me is that there
12 were other factors that had an ameliorating effect, and my
13 thought was that there were other factors that had the
14 opposite effect. The fact that the containment was tight
15 was fine, but there were other leak paths that allowed these
16 small amounts of activity to escape.

17 MR. BENDER: I couldn't find the containment being
18 tight when there was an opening that allowed the stuff to
19 get out.

20 DR. SIESS: The opening that allowed it to get out
21 was the connection between the containment and the auxiliary
22 building through the RHR system or the letdown system or
23 whatever it was. I don't think enough got out through that
24 sump. I don't think that was the source of the activity.
25 That was closed off before the core was uncovered.

pv MM

1 MR. BENDER: I don't think anybody really knows
2 that.

3 DR. SIESS: The studies I have read --

4 MR. BENDER: The studies I read was that the
5 source --

6 DR. SIESS: The pump seals or rupture seals in the
7 auxiliary building have been blamed for most of it. They
8 postulated that they might have got a siphon effect after
9 the pumps were cut off. I mentioned this before. The staff
10 has been reviewing leakage from pump seals or rupture seals
11 during the long-term period following the LOCA, and I have
12 never seen how much does they've figured on that. They
13 computed it and said it's small compared to the Part 100
14 dose. Well, what got out at Three Mile Island was small
15 compared to the Part 100 dose, but it wasn't small on an
16 absolute basis.

17 MR. BENDER: I guess my point is if there hadn't
18 been some other things in the way of that radioactivity
19 besides containment, it would have been all over the place.

20 DR. SIESS: Besides the containment?

21 DR. OKRENT: The bulk of it stayed in the
22 containment.

23 DR. SIESS: To me, this was a triumph for the
24 containment.

25 MR. BENDER: Not necessarily, because the

1429 087

pv MM

1 containment wall itself was so tight.

2 MR. LEWIS: The Rasmussen report has five
3 mechanisms for the stuff leaking out of the containment.
4 The dominant one was melt through the bottom, and the
5 second dominant one was what they call "beta," and beta was
6 failure to isolate for one reason or another, no damage to
7 the gadget, just that you didn't cover it up. And Three
8 Mile Island falls into that category. It's clearly a
9 threat. Does one need to define it more closely to know
10 what we are doing here?

11 MR. BENDER: I don't know that we do.

12 DR. SIESS: If the containment had been completely
13 isolated, we might have had other problems.

14 MR. LEWIS: We might, conceivably.

15 DR. SIESS: I mean, if all the valves had been
16 closed.

17 MR. LEWIS: Yes, we might have.

18 MR. BENDER: There's no sense in belaboring the
19 point.

20 DR. SIESS: I don't see how the meteorology, what
21 we learned about the meteorology --

22 MR. BENDER: I think the point I was trying to
23 make was what the meteorology was didn't have much effect on
24 how the public was protected.

25 DR. SIESS: You didn't say that. You said neither

1429 088

pv MM

1 containment leak-tightness nor meteorology by themselves are
2 controlling features. I agree to that, but I don't agree
3 that I learned that from Three Mile Island, which is what
4 the sentence says.

5 MR. BENDER: Okay, I will accept that as a valid
6 comment. I think all Three Mile Island does is illustrate
7 the point.

8 DR. SIESS: Now, Jesse made a statement a few
9 minutes ago that we don't look at class 9 accidents for
10 siting -- and I think he said "we." That's not true for
11 this committee. This committee has always looked at class 9
12 accidents for siting. Our SPI's value was clearly based on
13 class 9 values, and I think has been based on it for a long
14 time. And I have never been able to feel that the siting
15 criteria made any sense except for a class 9 accident, what
16 little there was to it, the population center distance.

17 So, I can't accept that as a statement that refers
18 to this committee, and I don't know whether we want to make
19 that distinction in here or not.

20 MR. BENDER: Does anybody but us know that?

21 DR. SIESS: Well, I told the Congress that when
22 they asked me why we asked for evacuation plans, but not in
23 low population for Newboldt Island. I was testifying, and I
24 was asked specifically why we said that, and I explained
25 that the low population zone exclusion boundary requirements

pv MM

1 could not keep you away from the city and the population
2 center distance didn't keep you very far, and we were
3 concerned about accidents greater than the design basis
4 accident and we thought evacuation was the only solution.
5 That's on the record.

6 I don't know whether it's been said in anything we
7 wrote or not, but when we put out our SPI index or SPI
8 value, finally, we modified it down somewhat, but it was
9 still looking at larger releases than Part 100. The history
10 of it went out, not just the final document. We published
11 everything we churned out in all those papers, and the first
12 thinking of it, we were alking about -- what -- a thousand
13 rem at various distances and how many people would be killed
14 and how many people would be injured. Those were our two
15 values we averaged. We later changed the "people killed" to
16 "people evacuated" or something like that.

17 But the record shows otherwise, so anybody who
18 wants to dig into it, we can document our concern, our way
19 of thinking about it.

20 MR. BENDER: Does the committee have any concern
21 with the major points in this thing; namely, that we could
22 be looking at whether sites could deal with a core melt in
23 terms of controlling what happens to potable water systems
24 if there is a melt-through, and the other question of
25 whether we can consider potential containment bursts due to

PV MM

1 something like hydrogen combustion? Are those points that
2 the committee wants to accept, or believes that we've got to
3 have something different?

4 DR. SIESS: When you say "hydrogen," you mean
5 consider potential containment bursts due to hydrogen
6 burning for something less than a core-melt accident?

7 MR. BENDER: Something less.

8 DR. SIESS: Because if you're going to talk about
9 core-melt accidents, that's just one of them, one of the
10 mechanisms.

11 MR. BENDER: I am not a proponent of these
12 things. I am just putting myself on this thing. That's the
13 question: do we want to accept those things?

14 DR. SIESS: I think one of the lessons learned is
15 that the potential breach in containment release of
16 radioactivity for an event of less than a core-melt
17 accident, and probably more probable than a core-melt
18 accident, is something that has to be thought about, has to
19 be considered. If we didn't learn that lesson, I don't know
20 what we learned.

21 DR. MOELLER: Mike's comments on hydrology are
22 certainly in line with what we have been saying, and I think
23 they should be repeated.

24 DR. SIESS: Let me take this opportunity to
25 present something I dug up on siting policy in terms of

1429 091

pv MM

1 population. I asked the staff to get me the last 20 sites
2 that were approved and the SPI values for them. And just
3 for your information, I think they got me 24 plants. 18 of
4 these had SPI values of less than .1. There were four
5 between 12 and 14, one in 16 and one in 22. And with one
6 exception, all the high ones were New England sites. One of
7 them was Davis-Besse, including Sumner, and I don't know what
8 the year average would be.

9 But it seems to me that there has been a fairly
10 consistent trend to get sites into very low population
11 areas, and I don't believe you can have a population center
12 very close to a plant and get a SPI as low as 10. I would
13 have to check that, but I don't think you can do it, even
14 though we averaged around the sectors to get that. So, I
15 think there has been a trend.

16 .1 is 10. I am sorry.

17 I think there has been a clear trend in siting,
18 whether it's coming from the industry, whether Newboldt
19 Island precipitated it, I don't think that was the final --
20 it might have been the last straw.

21 But the distribution is skewed very differently
22 heavily toward the low values. It looks like exponential
23 distribution.

24 DR. CARBON: Mike, I think the answer to your
25 question is "Yes."

1429 092

pv MM

1 MR. BENDER: Okay. Why don't we go to the next
2 one.

3 DR. MOELLER: I gather no one is interested in
4 commenting at all on multi-unit versus single-unit sites?

5 MR. BENDER: That question got lost, Dade. Maybe
6 we ought to come back to it. We ought not to leave it
7 open.

8 DR. MOELLER: Well, I would appreciate a
9 resolution.

10 MR. BENDER: This thing says there are some pluses
11 and some minuses to it.

12 DR. MOELLER: (Nodding affirmatively.)

13 MR. BENDER: Is the thrust of what you are
14 suggesting that this report say something about trying to
15 say something about those pluses and minuses? I wouldn't
16 see anything wrong with adding that. It's certainly a valid
17 thing, that we've talked about a lot of times, how many
18 plants ought to be at one site. We don't have much position
19 on it.

20 DR. MOELLER: Well, my point is we're supposed to
21 be an advisory committee on reactor safety. Well, if
22 through putting three units per site we can enhance safety,
23 or if it decreases safety, we should know it and we should
24 have a position and it should be based on facts. And if
25 those facts don't exist now, we should ask for them.

1429 093

pv MM

1 MR. BENDER: Well, at the time, we agreed to to --
2 was Shearon Harris the first one that was a four-unit plant?
3 That was a long, long discussion.

4 DR. MOELLER: And when Dr. Burwell, from Oak
5 Ridge, spoke before our subcommittee, he pointed out that
6 they're actively meeting with the utilities and encouraging
7 the utilities to change the site for given plants, move them
8 to an existing site where there's another reactor. And so
9 people are taking action, and we ought to know whether
10 that's the proper action.

11 MR. BENDER: Let me take what you've got. I
12 haven't looked at it enough to know how to use it, but I
13 will incorporate it in some way.

14
15
16
17
18
19
20
21
22
23
24
25

1429 094

gsh/MMM

1 DR. OKRENT: The question of multi-unit sites is
2 not necessarily coupled to the use of existing sites. And I
3 don't think that we should present it only in the framework
4 of the use of existing sites.

5 In fact, one could make arguments that if you are going
6 for the multi-unit site approach, you may not want to use
7 existing sites because you would like to better design each
8 reactor to be able to accommodate a serious problem at one
9 of the neighbors on the site than you might be able to do
10 with the existing reactors.

11 I just mention that thought.

12 MR. RAY: There might be good economic reasons for
13 not considering existing sites, too, because you may not be
14 able to get the transmission in and out of the site. You
15 may, therefore, be forced into a very, very expensive
16 underground cable at 500 KV, for instance, which is
17 tremendous.

18 MR. BENDER: The practicality of it, and also the
19 whole utility organizational structure.

20 DR. OKRENT: I just don't want to tie the
21 multi-unit site idea which has advantages to the use of
22 existing sites if that's the only way it should be done.

23 Do you understand?

24 DR. MOELLER: Right. It could be tied in, but it
25 also need not be.

1429 095

gshMM

1 DR. OKRENT: Need not be.

2 DR. MOELLER: Yes.

3 MR. BENDER: Can I go to the next section? The
4 next section is 6.3. And I suggest that we start on page 69
5 and ignore everything above paragraph 70 and let's start
6 with paragraph 70, and I will read from there.

7 The rest of it can probably be thrown away.

8 The NRC has placed great reliance on the separate lines
9 of defense in its regulatory philosophy. The engineered
10 safety features are provided to back up the normally
11 anticipated high reliability of nuclear power plant
12 equipment.

13 These engineered safety features work independently of
14 other equipment, other plant equipment, and are intended to
15 assure the safety of the public even if the plant itself
16 does not perform as expected.

17 So the reliability of these features has to be very high.

18 Emergency core cooling, for example, requires
19 ultra-reliable pumping circuits, valves, heat transfer
20 systems and instrumentation.

21 Since some portion of these features could suffer
22 failures during service demands, the NRC depends upon
23 redundancy, testability, and similar reliability practices
24 to assure functional adequacy of the engineered safety
25 features.

gshMMM

1 Hence, when some portion of a safety feature is reported
2 to have failed, the question to be considered is whether the
3 failure represents unacceptable loss of function in the
4 safety feature or merely an acceptable failure included in
5 design.

6 One aspect of the issue is the single failure criterion.
7 It was originally derived from electrical circuitry design
8 practice. That's my opinion. It may not be right, but I
9 think it is -- intended to assure that one relay or one
10 circuit breaker failure could not jeopardize the reliability
11 of an electrical system.

12 When the single failure approach is applied to an entire
13 system, the number of single failures that may be involved
14 in system action could make the probability of several
15 failures high and thus make the reliability premise
16 meaningless.

17 There is a need to re-examine the failure questions
18 associated with the use of the single failure criterion
19 since it may be used improperly in more complex systems.

20 A second important aspect of failure definition is how to
21 establish acceptable levels of failure. Although piping
22 systems, for example, have suffered stress corrosion
23 cracking, the extent of such cracks has not yet led to
24 significant loss of coolant accidents.

25 Failure control of such problems usually involve

1429 097

gshMMM 1 monitoring with the intent of taking corrective action
2 before the condition reaches serious failure proportions.

3 For steady state conditions under normal operating
4 circumstances, this seems to be good practice. There is
5 some concern, however, that other types of transient
6 conditions caused by external phenomena could accelerate the
7 failure propagation rate.

8 The acceptability of failure conditions like stress
9 corrosion cracking thus requires determination of how such
10 conditions would change under the transient circumstances to
11 be considered in nuclear power plant operation.

12 The effect of transient conditions needs clarification
13 for failure evaluation purposes.

14 A third problem is failure incurred because of
15 environmental conditions not totally expected by design. I
16 decided to use Jessie's case instead of fire.

17 A ruptured steamline, for example, could totally destroy
18 the redundant capability of an emergency safety feature,
19 thereby negating the contingency provision intended to
20 establish the need of such reliability.

21 Whether such failures are acceptable in nuclear plants
22 depends upon the frequency with which such environmental
23 disturbances arise and whether they involve a loss of
24 function permitted to design.

25 A fourth aspect of the failure question is directed

gshMMM 1 towards methods of preventing serious failures from
2 occurring. These are physical constraints, ultra-reliable
3 circuitry, and alternative protection measures have all been
4 included in NRC regulatory considerations.

5 It is possible to overcorrect and to introduce contingent
6 provisions which, while useful under some circumstances, may
7 on the whole degrade the reliability of the installation by
8 increasing the demand on engineered safety features.

9 A balance between failure prevention and tolerance for
10 failure of consequence must be established. But the balance
11 point is not defined adequately. The tolerance which most
12 plant designs have a design error, equipment malfunction,
13 construction mistakes, and even operator errors determines
14 their acceptability.

15 Failures reported with much public attention in the
16 communication media are often permitted by design at some
17 frequency rate as an acceptable characteristic.

18 The issue is how much tolerance exists for these
19 failures, when are they minor and when are they major, and
20 can their occurrence be symptomatic of conditions which may
21 with time worsen sufficiently to cause public safety
22 concern?

23 The NRC reporting systems are intended to identify such
24 failures. The ability to analyze them and evaluate their
25 potential to cause public safety problems is fundamental to

gshMMM

1 the reliability premises on which safety arguments are
2 based.

3 The reporting devices such as licensing event reports in
4 use by the NRC and the nuclear industry has not yet been
5 adequately applied in the licensing process to establish
6 whether tolerance limits are being met.

7 This list of failure considerations could be extended
8 further. The intent here is only to characterize
9 technological issues and show how it relates to the
10 regulatory process.

11 The problem of failure definition requires the best
12 engineering and scientific skills available to the industry
13 and the regulatory organization.

14 The current practices and requirements and probably
15 generally appropriate to public safety needs but may need
16 changes in detail.

17 The question of how to define failure importance and how
18 to identify the extent of its consequences and how to treat
19 the failure by design are all matters of continuing concern
20 for those involved in nuclear power plant safety.

21 Such matters are getting attention and the NRC staff is
22 concentrating much of its review in these areas.

23 Nevertheless, because it is important to public safety
24 for failure matters to be addressed in the regulatory
25 process, a broader effort is needed in this aspect of the

1429 100

gshMMM

1 regulatory program.

2 That last paragraph has a lot of words in it that it
3 could be boiled down to a couple of sentences.

4 What I tried to do is just bring all the points that have
5 come up about what acceptable failure is into one place. I
6 don't know whether I did a good job or not.

7 DR. SIESS: If this is addressed at least in part
8 to a layman, it seems to me that it would be worthwhile to
9 try to explain what you are referring to as a single failure
10 criteria a little bit more completely.

11 From the layman's point of view, it's really a double
12 failure criteria. First you have a pipe break or whatever
13 it is that constitutes the failure. Second, you have a
14 failure of one of your engineered safety features which was
15 intended to mitigate the consequences.

16 And that, I think, would be worthwhile in explaining that
17 it isn't just one failure.

18 Now that doesn't solve a lot of our problems. The
19 biggest objection that I can see in the single failure
20 criteria, it doesn't give you any quantitatively
21 measurable -- quantitative guarantee of reliability and it
22 doesn't give uniform or even necessarily desirable levels of
23 reliability related to consequences.

24 The other point is in something you read that has changed
25 where you talk about the steamline break could totally

1429 101

gsnMMM 1 destroy the redundant capability.

2 I don't quite know how to interpret "could," but if that
3 is true, we have a terribly significant deficiency.

4 MR. BENDER: That's the point that Jessie keeps
5 raising and I sort of put it out here to see if people
6 wanted --

7 DR. SIESS: This whole recent flap about high
8 level breaks -- is it that obvious that it could --

9 MR. RAY: I guess "could" mean potentially --

10 PROF. KERR: Jessie doesn't really say that it
11 destroys the redundant capability. He says that you have to
12 postulate a failure of one of the redundant valves, a
13 consequent failure, and then you have to postulate the
14 failure of the other, which is a redundant capability.

15 So it is not the accident which destroys the redundant
16 capability; indeed, it leaves the redundant capability
17 accident intact.

18 But if you do not have a failure of the second one of
19 these two redundant valves, you are in trouble, he says.

20 It destroys the redundant capability if by that you
21 mean that you no longer have a redundant set of valves
22 available. But in some senses, that's why you have two, it
23 seems to me.

24 MR. BENDER: The problem is how you get there, I
25 guess.

gshMMM

1 DR. SIESS: The most serious disruption of
2 redundancy is allowing equipment to be out of service for
3 maintenance or test for significant periods of time now. On
4 the reliability basis, that can be quantified.

5 But let's face it, there are a lot of systems in the
6 plant that are not redundant for appreciable periods of
7 time.

8 I'm talking about mechanical, because mostly electrical
9 is such that two out of three, or whatever, becomes one out
10 of two, or something.

11 But I guess the word "could" --

12 MR. BENDER: I can fix that,

13 DR. SIESS: You can postulate this. The studies
14 that have been made indicate that it may be a problem. But
15 if it is, we're going to fix it. But it's not inherent --

16 MR. BENDER: I want to fix this thing so that the
17 single failure thing by itself didn't become the whole
18 concern.

19 I think we're still worried about all the other things
20 that could go wrong in a plant as well as the single-failure
21 criterion.

22 That was all I was trying to do when I put this together.
23 I don't know whether I was successful in doing that.

24 DR. SIESS: What you are trying to do here, I
25 gather, is to try to make a distinction between component

1429 103

gshMMM 1 failures -- I use that as a simplified term -- maybe even a
2 system failure that might get reported in the newspapers on
3 LERs, and the ultimate failure which endangers the health
4 and safety of the public.

5 We could argue whether Three Mile Island was that
6 ultimate failure or not. But you are trying to make that
7 distinction that you have to go down several steps before a
8 component failure is the ultimate failure.

9 It didn't come through quite that strong somewhere.

10 MR. BENDER: If there is nothing wrong with the
11 principle that I have stated here, I will try to work on it
12 in an editorial sense to make it read better and bring the
13 points out a little better.

14 I have so many of these things to do that I don't know
15 that we can do much more than just agree that something has
16 to be done with it, at such point, I'll do something with
17 it.

18 6.4, in systems interactions. In the prior discussion of
19 failure, reference was made to interactions between various
20 operating systems and how they might lead to significant
21 failures from the public safety standpoint.

22 The term, "systems interaction," as currently used,
23 refers to all of those circumstances that may arise where
24 events occurring in one system might impose a safety stress
25 on another.

gshMMM

1 A fire, for example, which spreads sufficiently to destroy
 2 all controls, could invalidate the capability of all
 3 engineered safety features.

4 This assumes interaction questions involves such matters
 5 as the relationship between the control systems and the
 6 so-called safety protection systems that are presumed to be
 7 isolated from each other, but could have interactive
 8 effects.

9 The release of radionuclides or steam into the operating
 10 environment of engineered safety features do interfere with
 11 their long- or short-term performance and possibly negate
 12 their safety functions.

13 And three, a cross-over of short circuit fall from one
 14 circuit to another. That could destroy redundant electrical
 15 equipment from adequate public safety reliability purposes.

16 Most of these matters are given some consideration in the
 17 licensing process. The regulations are intended to avoid
 18 deleterious safety interactions. But some recent
 19 experiences suggest that the whole subject should be under
 20 constant surveillance by personnel who have insight to
 21 potential system interaction difficulties.

22 That one really doesn't say much.

23 PROF. KERR: I am surprised to see fire classified
 24 as a systems interaction, when I guess that I would have
 25 tended to classify it as a common mode failure agent.

gshMMM

1 I had thought by systems interaction, here's a system
2 over here and it may have an unexpected influence on another
3 system.

4 MR. BENDER: I probably should have used the
5 firewater system instead of the fire.

6 PROF. KERR: Okay.

7 DR. PLESSET: I don't think the Browns Ferry fire
8 is typical. We haven't had too many of those.

9 DR. OKRENT: If you want an example, th Quad City
10 raw water recirculating system failure flooding the turbine
11 building and affecting other pumps would be an example.

12 MR. BENDER: I think your point is well taken. One
13 is not typical, famous, but not typical.

14 This thing doesn't say all that much. I'm not sure
15 whether it was worth saying at all.

16 DR. SIESS: I don't see how this committee could
17 write a report without talking about systems interactions.

18 DR. PLESSET: Yes, it has to stay in, Mike. It's
19 good.

20 DR. OKRENT: I have a question that comes to mind
21 on this topic in thinking back to a presentation we had this
22 morning by a member of the staff.

23 It is the following. In writing this, do you want in any
24 way to refer to what the staff is doing? Remember, he told
25 us that they are going to have the recommendation from the

1429 106

gshMMM

1 lessons learned task force?

2 I'm not urging anything. I'm just raising a kind of
3 question.

4 MR. BENDER: I think that's something that we need
5 to think about. They criticize the Kemeny Report because
6 they didn't -- the Kemeny Committee did not take into
7 account what the staff was doing.

8 And I suppose we shouldn't be guilty of that.

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

kap/MM

1 MR. BENDER: We shouldn't be guilty of not
2 recognizing what they're doing, although I must admit a lot
3 of what they're doing represent words rather than deeds.
4 But nevertheless, many of their approaches are the kinds of
5 things that are talked about here, and probably somewhere at
6 the end of these chapters we might be able to point out what
7 the staff is doing in these areas. I would try to do that.

8 DR. SIESS: Maybe we should encourage the staff to
9 start licensing plants so we can find out what they're
10 really going to do.

11 (Laughter.)

12 MR. BENDER: Why don't we plan to try to recognize
13 what the staff has in its plans, if we can find out.

14 DR. CARBON: (Nodding affirmatively.)

15 MR. BENDER: Let me go on to Section 6-5,
16 separation. This is a section I really spent some time
17 massaging. Most of these others I just tried to put in a
18 logical sequence without trying to worry too much about
19 whether they said exactly what I thought or you thought,
20 just to get something out for you to think about. But this
21 one has been worked on.

22 "The NRC regulations are generally founded on the
23 idea that if systems important to safety are carefully
24 reviewed and the plants are properly constructed under
25 suitable engineering criteria, then when credit is given for

1429 108

kap/MM

1 "emergency," the ECCS is classified as a system
2 important-to-safety and receives commensurate treatment and
3 attention.

4 "On the other hand, decay heat removal during
5 normal shutdown, an even more compelling need, does not
6 receive the same emphasis because it is considered a part of
7 the non-safety related portion of the plant.

8 "The end product of this separation philosophy is
9 the creation of two systems which are treated differently in
10 the safety reviews. The safety system is scrutinized
11 carefully but the non-safety system may be totally ignored
12 in the review process. Important safety matters could be
13 excluded from review if improperly classified.

14 "The concept of separation in some cases places
15 overdependence on a specialized safety provisions whose
16 safety capability would be better realized if considered as
17 part of the whole operating plant. Feedwater systems to
18 steam generators cannot, for example, be rationally
19 separated into safety and non-safety categories.

20 "The separation of safety from non-safety
21 functions is a desirable approach primarily when the two
22 functions have independent and perhaps contradictory
23 requirements. 'The Reactor Safety Study,' WASH-1400, pointed
24 out some fallacies in this emphasis on the separation of
25 safety and non-safety functions and some adjustments have

kap/MM

1 resulted. Nevertheless, the separation concept has not
2 changed markedly.

3 "Because it is impractical to impose all of the
4 safety stringencies on every plant detail, the separation
5 concept must be used. A few very important features having
6 extremely high public safety protection value will need
7 special quality, redundancy and testability properties that
8 cannot be extended to every plant element. The extent for
9 this type of treatment may need to be greater than has been
10 provided in the past. Alternatively, new approaches could
11 be developed where the safety treatment placed less
12 dependence on such safety-related features. Higher
13 reliability may be attained in some cases if the separation
14 concept is discarded so that the entire system can be
15 considered as responding to the safety requirements. Credit
16 for the capability of features previously considered outside
17 the public safety provisions may also be justifiable.

18 "Indeed, the review process itself cannot be
19 permitted to follow arbitrary lines of separation between
20 safety and non-safety features since this could easily
21 result in overlooking important systems interactions or
22 malfunctions that have public safety importance. The whole
23 principle of safety separation needs to be redefined with
24 the intent of developing a more logical and more effective
25 result."

kap/MM

1 DR. OKRENT: When I read this, I end up a little
2 bit unclear as to what it's saying with regard to separation
3 of safety from non-safety systems, whether it's arguing this
4 concept should be dropped or what. The idea that you cannot
5 separate the systems into safety and non-safety systems, and
6 not look at the non-safety systems for their possible
7 implications on safety, I think that's one that you make
8 here. I think the staff has accepted that now and so forth,
9 and I think we adopted it in one of our TMI type
10 recommendations.

11 I don't think that recommendation or approach is
12 at all incompatible with the idea that for some safety
13 systems you avoid having any unnecessary functions connected
14 with it. For example, Ebersole has on occasion suggested
15 that if you want some batteries available to provide vital
16 D/C power, you might do well not to give those same
17 batteries which are service functions, which indeed you
18 don't need in a safety role, because this could lead to
19 various complications. I find that kind of position by
20 Ebersole not inconsistent with the idea that you don't
21 ignore the non-safety systems when you are reviewing
22 safety.

23 But one could read this and get the idea we didn't
24 support the idea of trying to make a demarkation where it
25 made sense, in the design of specific systems.

1429 111

kap/MM

1 PROF. KERR: You could reach exactly that same
2 conclusion without talking about separation at all. What
3 you're talking about is reliability, and you conclude that
4 the reliability of the system is enhanced if you only have
5 those batteries available to those systems. We're not
6 talking about separation at all. And indeed, unless you do
7 increase reliability thereby, there's no point in doing it.

8 DR. OKRENT: Well, I'm not going to argue with
9 you, because the people who are talking in favor of
10 separation in that case are trying to get enhanced
11 reliability when they need it. And if you want to say, "I'm
12 going to favor reliability," they'll say they're favoring
13 reliability, and that's the way they think for those systems
14 you should get it.

15 PROF. KERR: To me, the weakness of their
16 approach, when it has one, is that one can eventually begin
17 to use separation as an end in itself. And I don't think
18 it's an end in itself. It's desirable only if it enhances
19 safety. There may be cases in which safety is not enhanced
20 by separation.

21 DR. OKRENT: Certainly the answer is, yes, safety
22 is not enhanced by separation if you only look at half the
23 systems. But that's not a necessity; in other words, you
24 could say, "I'm going to keep my protection system separate
25 from my control system" -- assuming you can really do this

1429 112

kap/MM 1 -- "but I'm going to also look at my control system and
2 thereby I will have a more reliable protection system. And
3 I will also have evaluated the control system.

4 PROF. KERR: You can say the "therefore," but it
5 really doesn't demonstrate it.

6 DR. OKRENT: In any event, I am not clear, in
7 fact, what this section is trying to say in that regard, so
8 I don't know whether I agree with it or not. That's part of
9 my problem. I can't disagree with the need to look at
10 safety and control systems, whatever you want to call them,
11 on overall systems, but there is more than one thing mixed
12 in here now.

13 MR. BENDER: Dave, the point you made about
14 needing to keep some things separated probably doesn't come
15 across here as well as it should.

16 DR. OKRENT: It's in there, in fact.

17 MR. BENDER: It just doesn't come across well
18 enough.

19 PROF. KERR: Let me read an alternative to help us
20 out in the second paragraph, which may not be acceptable --
21 I think it's the last paragraph, I'm sorry. It may not do
22 what you want to do because it doesn't talk about
23 separation. It begins with the "Because it is impractical
24 to impose. . ."

25 And I would suggest that it might read: Because

kap/MM 1 it is impractical to impose the same level of safety
2 stringency on every plant details, different parts of the
3 plant must be constructed to different safety standards.
4 Few of their important features having extremely high safety
5 protection will need special quality, redundancy testability
6 -- cannot be extended to every plant element.

7 These quality standards may need to be applied to
8 a larger fraction of the plant system than has been the case
9 heretofore.

10 Then I would continue to read as is.

11 MR. BENDER: Would that help, Dave?

12 PROF. KERR: That doesn't emphasize separation. It
13 just says, view the plant with different qualities --

14 DR. OKRENT: I don't have any particular problem
15 with what Bill read. I'm just saying, reading through the
16 whole three pages it sort of wanders around in this area,
17 and I think you see what --

18 MR. BENDER: What I probably need to do is to just
19 put something in there that directly makes the point that
20 you made. In a sense, I wanted to -- in writing this thing,
21 it was sort of trying to rebuild what Bill had done,
22 primarily. I reorganized some of it. I don't know that I
23 did it well.

24 PROF. KERR: Dave, would your concerns be met? It
25 seems to me what Mike is suggesting to be a weakness is an

kap/MM

1 effective separation has been an emphasis on the safety
2 grade system has been -- okay, it's that part of separation
3 that you would like to see eliminated. So perhaps in some
4 fashion you can make that clear. The physical separation
5 which, to some extent, is what you're talking about, not
6 that all together, but physically separate the batteries
7 from anything other than safety systems. You may want to
8 retain that.

9 MR. BENDER: I thought the point that Dave was
10 bothered about as not coming out too well was this thing
11 jumps back and forth. It says, in some cases, it's good to
12 separate; in some cases it's better to combine. I really
13 think that, and that there's no hard-and-fast rule.

14 But I think we could say in this that there could
15 be more design emphasis on trying to separate where
16 separation could lead you to a more reliable type of
17 system. I think Jesse -- I heard him make this point a
18 number of times -- has said, Well, look, if I could find a
19 few things that I could design very reliably, I could
20 probably let the rest of the plant go to hell.

21 DR. OKRENT: Dedicated function.

22 MR. BENDER: Yes. I don't know that I wholly
23 agree with his idea, but I don't reject it, either. And
24 that point doesn't come out as well.

25 DR. OKRENT: If I can raise a couple of less

kap/MM 1 sweeping questions.

2 On the bottom of page 6-15, it wasn't clear to me
3 what you thought the Reactor Safety Study had pointed out
4 were fallacies in the emphasis of separation.

5 MR. BENDER: I'll turn that to Bill Kerr. I'll
6 let him answer.

7 DR. OKRENT: What are the examples?

8 MR. BENDER: Do you remember any, Bill?

9 PROF. KERR: I can't think of a specific example,
10 but my impression is that it showed, in some cases,
11 non-safety grade system malfunctioning -- the malfunction of
12 non-safety grade systems could leads to difficulties and if
13 one does not eliminate this, then one is going to be unaware
14 of possible significant contributors.

15 DR. OKRENT: Well, the way that paragraph is
16 written, first there's a sentence about independent or
17 perhaps contradictory requirements. Then the next sentence
18 sort of follows on as if there is something in mind which
19 has independent and perhaps contradictory requirements. It
20 would help me if I could see that there was an example that
21 fit this, or something else.

22 PROF. KERR: That's a good point. I'll try to
23 look on up.

24 DR. OKRENT: The only other thing, as I recall,
25 somewhere in here you talk about auxiliary feedwater?

kap/MM

1 MR. BENDER: It's just in the footnote.

2 DR. OKRENT: Yes, it says "feedwater systems to
3 steam generators cannot, for example, be rationally
4 separated for safety and non-safety categories."

5 I don't know that you would be unanimously
6 supported on that point of view.

7 MR. BENDER: All I can say is one is the
8 alternative for the other. If you wanted to make one of
9 them more reliable, you can sure do that.

10 DR. OKRENT: But the auxiliary feedwater system is
11 looked upon, certainly in the German plants, and I thought
12 in the U.S. plants, as a needed safety function to PWRs.

13 MR. BENDER: Feedwater is a needed safety
14 function.

15

16

17

18

19

20

21

22

23

24

25

1429 117

1 DR. OKRENT: The main feedwater system, if you
2 wish to have power, the auxiliary feedwater system, you need
3 to have for removing decay heat if you don't want to open up
4 the power system, and even then that may not work too well.

5 So I'm not prepared to say I can't rationally
6 separate those two, and as I say, I think there are people
7 who think they have rationally separated them.

8 MR. BENDER: I know I can file better examples
9 than that. I just happened to pick that one.

10 DR. OKRENT: I suggest you find a better example.

11 PROFESSOR KERR: Maybe the separation has been
12 rational but not logical.

13 (Laughter.)

14 PROFESSOR KERR: For example, if the main
15 feedwater system works and works well, you may not need the
16 auxiliary feedwater systems in a good many cases. You can
17 certainly look at LERs and see examples in which
18 malfunctions of the feedwater system has caused the plant to
19 shut down. Now you can argue that the plant did not thereby
20 become unsafe, and so you don't worry about it, but it does
21 enhance the frequency with which the safety system is called
22 upon to function, about which we have said we have some
23 concern.

24 DR. OKRENT: I'm not arguing that the main
25 feedwater system is unable of itself to cause a transient

176 12 02

1 obviously, but I think you can set up a rational and logical
2 separation of the main feedwater and the auxiliary feedwater
3 system into different categories. If I lose offsite power, I
4 also lose my main feedwater.

5 PROFESSOR KERR: Sure, you can put them into
6 different categories, but the categories won't be safety and
7 non-safety. They'll be safety and perhaps less-safety.

8 MR. BENDER: I think my point had to do with
9 whether they were interrelated and really separated from
10 each other. They are both feeding the same water into a
11 steam generator. About the only difference between them is,
12 one has a little less capacity than the other and can
13 operate with a little bit less power demand. I'm sure that
14 there's much else of a differentiation.

15 DR. OKRENT: That little less power demand is the
16 difference between being able to use offsite and onsite
17 power.

18 MR. BENDER: I understand what your saying, but
19 that's not really separation of the feedwater systems.
20 That's power supply provision. I can put a motor on the
21 feedwater, main feedwater system, and accomplish the same
22 thing. And I wouldn't do it that way, but I could.

23 DR. OKRENT: I agree you could. But if I follow
24 Bill's point about everything affecting safety, almost
25 everything, anything that can cause a transient affects

1429 119

76 12 03

m. M 1 safety. So therefore, if we go all the way back down the
2 power line and every telephone pole -- well, telephone pole
3 near it as well as power and so forth is related to safety.

4 PROFESSOR KERR: But on a frequency basis, the
5 telephone poles don't cause as many transients as the
6 feedwater system.

7 DR. OKRENT: It depends on your reactor.

8 MR. BENDER: I think we are belaboring a point
9 which maybe we shouldn't belabor. I understand what you
10 were saying. Dave, I didn't think it was that bad an
11 example, but I can look for others that may be better.

12 PROFESSOR KERR: Mike, in paragraph 81 --

13 MR. BENDER: I have your note, incidentally.

14 PROFESSOR KERR: I suggest that you may be talking
15 about systems here rather than functions.

16 MR. BENDER: It could very well be.

17 MR. MOELLER: In paragraph 79, I can give you this
18 in the last sentence if you buy it. It seems to me that we
19 should say that "the NRC review practice has been one which
20 separates safety from non-safety systems, with primary
21 attention being given to the safety systems" as contrasted
22 to saying "with no attention being given to the non-safety
23 systems."

24 MR. BENDER: Okay, Dade. That's good.

25 Let me go to the next item which is man-machine

1429 120

176 12 04

m M 1 interfaces.

2 "Nuclear power stations cannot be operated solely
3 by human action or by machine automation. Operators are
4 needed to establish a state of readiness for the plant, to
5 relate them to the external electrical demands, to provide
6 fuel maintenance and similar service activities. However,
7 the only way to minimize human mistakes is to automate the
8 plants or provide better computerized analysis, so that the
9 likelihood of human thinking errors will be minimized.

10 "None of the older plant designs have sufficient
11 computerized analysis capability to be useful in analyzing
12 most operational symptoms quickly. Some newer designs have
13 improved computerized analysis capability, but the only
14 purely automated functions are still the emergency power
15 supply systems, reactor safety protection systems, pressure
16 relief containment closure valves, and a few basic
17 mechanical equipment functions.

18 "There may be advantages to expanding the
19 automated plant features to reduce the need for operator
20 action during transient operating periods. But how and
21 whether this should be done deserves considerable thought.
22 Most of the modern plants are providing additional
23 computerized control capability that could, by computer
24 initiated control signals, ease the knowledge requirements
25 put on operators, but concern has been expressed about such

1429 12

176 12 05

1 systems causing undesirable operational actions through
2 computer malfunctions. The safety threat from such
3 malfunction, when it is provided to reduce demands on
4 operator thinking capability, to some extent offsets the
5 desirability of computerized response.

6 "There may be a need to improve the information
7 displays in control rooms. These have been developed along
8 lines which follow customary display practice for existing
9 power stations, combined with the now traditional display
10 scheme for nuclear controls. This display has considerable
11 merit because operating personnel are accustomed to it, but
12 it may not draw operator attention adequately to the crucial
13 instrumentation needed in emergencies. The alarm systems
14 may be excessively confusing, and some information displays
15 could be better located."

16 Now that's where it stops. Whether we ought to
17 say something about how to go about this so-called human
18 engineering or whatever it is, I'm not sure what to say.

19 MR. EBERSOLE: Mike, beginning about 1968 or
20 thereabouts, there was a big flap in this business because
21 of the importance of operator indication, as it came to be
22 known, and up to that time, to '79, only considered
23 automated circuitry important to the safety function.
24 Therefore, there was a big issue as to whether those
25 circuits that provide indicating functions should be

1429 122

176 12 06

m AM 1 classified as safety-grade, given the benefit of power
2 supply reliability, separation, and all the other good
3 things that you do to safety circuitry.

4 There is beginning about that time, and certainly
5 prior to it, a mishmash of designs where indicating circuitry
6 is not safety-grade, and after that it is probably a mixture
7 of safety and non-safety-grade, and at best it might come in
8 only redundant configurations, which as you well know
9 contrasted automatic response, permits the operator -- or
10 rather puts him in a position where he must deal with
11 conflicting outputs. Redundancy buys you nothing but
12 potential confusion, and the matter, so far as I know, has
13 not been settled about how you now give the operator truly
14 reliable signal indication, either in the context of making
15 it safety-grade or requiring, in fact, auctioneering input
16 to the operator so he can determine what action he should
17 take.

18 His potential action could be bi-directional.
19 Unlike most control systems, he can do the wrong thing as
20 well as the right thing, depending on what comes to him. I
21 think there are major issues yet to be settled with the
22 qualification of indicating circuitry which is now
23 recognized to be essential to plant safety.

24 MR. BENDER: I think you are directing your
25 commentary to a slightly different matter than this

1429 123

76 12 07

m MM 1 particular thing.

2 MR. EBERSOLE: You're talking about operator
3 interfaces. I'm talking about his information input, the
4 quality of it.

5 MR. BENDER: I guess this is more directed to the matter
6 of when we should decide to let him do the thinking.

7 MR. EBERSOLE: And on what basis of information.
8 That can't be separated.

9 MR. BENDER: Yes. I don't know how to get the
10 instrumentation philosophy cranked into this, which is the
11 thing you're talking about right now.

12 MR. EBERSOLE: His actions are going to be guided
13 by what he sees. Now, what's the quality of what he sees?
14 It's almost the same argument we had --

15 MR. BENDER: Tell me what I should be saying.

16 MR. EBERSOLE: I think we need to say that new
17 investigations of the quality of operator input need to be
18 undertaken to resolve the matter of potential conflicting
19 information which derives from redundant configurations, and
20 maybe to ensure that diversity in the operator signal to do
21 certain things is always available. There is no methodical
22 process by which this is currently done.

23 MR. MOELLER: It seems to me, Mike, you've covered
24 one aspect of it. When I think of a machine and man use of
25 it, I think of the design and his ability to keep up with

1429 124

176 12 08

m MM 1 what's going on, and obviously prior to TMI, there had been
2 a number of studies done which had told them they needed to,
3 you know, improve control rooms. And subsequent to TMI,
4 there's a lot of action in this area.

5 So I think what Jesse has said is good, and maybe
6 if it's appropriate, you could have a couple of sentences
7 which say that it is being looked at and that action is
8 underway, and we are happy with it.

9 MR. EBERSOLE: Control room redesign is a part of
10 this, but having got that put by, now remains the adequacy
11 of the control room information on the redesign basis.

12 MR. MOELLER: Oh, yes. It has to be the right
13 kind of information in the proper form so he can use it, and
14 in a way so that his natural response will be the correct
15 response.

16 MR. EBERSOLE: In a way, it's like redeveloping
17 the arguments that have attended the core protection calculator at
18 Arkansas 2, since we now know that operator input is going
19 to largely be by -- it's going to be solid-state
20 computerized, and therefore, it carries with it all the
21 potential failure regimes carried by CPCs, except this time
22 the operator will be the final mechanical element that
23 performs the function.

24 MR. BENDER: And so --

25 MR. EBERSOLE: One, it all ends up as to how

1429 125

1 76 12 09

1 reliable is the operator input?

2 MR. BENDER: Well, I could say, nevertheless, we
3 should do this. But if we do it, we need to have some way
4 of being sure that we are getting adequate reliability.

5 MR. EBERSOLE: Yes, in the operator input. That
6 is a field of endeavor that has not gotten much attention.

7 MR. BENDER: In terms of the quality of the
8 signals?

9 MR. EBERSOLE: Yes. Potential conflict on
10 redundant systems.

11 MR. BENDER: Being sure that no ambiguity -- are
12 those the things that you were after?

13 MR. EBERSOLE: Yes. Right.

14 MR. BENDER: Okay. I think I can get something in
15 there.

16 MR. MATHIS: Mike, just one other point. The
17 first sentence say, "Nuclear power stations cannot be
18 operated solely by human action or machine automation." I
19 think they could be operated solely by human actions, but it
20 would be a little tough.

21 MR. EBERSOLE: Practically? Now, there's just a
22 little bit --

23 MR. BENDER: Fine. Thank you. I think you're
24 right. It would be difficult. I'll fix it up.

25 Can I go to the section on safety improvements?

1429 126

76 12 10

1 DR. CARBON: Yes.

2 MR. BENDER: "Nuclear power stations have
3 incorporated many features intended primarily to enhance
4 their public safety protection as a result of direct
5 regulatory requirements, including off gas filtration,
6 automated containment closure, and hydrogen recombiners for
7 containment. Further improvement may be desirable in some
8 areas.

9 "A comprehensive study is needed to define the
10 most urgent needs. The discussion which follows illustrates
11 the types of safety improvement which can be of value.

12 "An important safety contribution would be a
13 filtration system which could recover radionuclides from the
14 contained volume after an accident so that the residual
15 gases could be vented to the public atmosphere safely.
16 However, these filters -- how these filters could be used
17 and the performance reliability required of them would
18 involve some research and experimental work. If provided,
19 the public safety actions after a Three Mile Island type of
20 event would be easier.

21 "More versatile and more reliable core cooling
22 capability is another area that might enhance public
23 safety. The experience at Brown's Ferry and TMI-2 both
24 point to the desirability of being able to provide reliable
25 core cooling capability from multiple sources. Diversity

1429 127

76 12 11

m M 1 of the capability, its independence of accident
2 circumstances, its resistance to deliberate sabotage, and
3 its ability to directly cool the core under a range of
4 circumstances could directly reduce the likelihood of TMI-22
5 type accidents as well as other accidents offering a
6 potential for core damage and even fuel melting. Conceptual
7 engineering studies would be valuable in determining how
8 this capability could be realized.

9 "The ACRS has identified these two matters as ripe
10 for investigation in the NRC research program. Other types
11 of safety improvements might be envisioned. These include
12 different means for primary system pressure relief, changes
13 in materials of construction, techniques for minimizing
14 accumulation of radioactive materials that directly
15 interfere with in-service inspection, and modifications in
16 existing containment concepts.

17 "However more independent initiative is needed by
18 the nuclear industry in identifying safety improvements.
19 The public might react more favorably to the future of
20 nuclear power if there were some visible efforts in this
21 direction."

22 MR. EBERSOLE: There's got to be something added.
23 There is no incentive. An incentive must be created which
24 will encourage this sort of effort, and that incentive, I
25 think, maybe is in reduced costs for safe operation. I

1429 128

76 12 12

m MM 1 don't know. But right now, there's no incentive.

2 DR. OKRENT: Jesse, I would say there may be a
3 very big incentive.

4 MR. EBERSOLE: Survival?

5 DR. OKRENT: I suspect that if this is not done by
6 the industry and done seriously, and if they don't try to
7 pursue what I call something that looks like an AGARA
8 principle, it will be survival.

9 MR. EBERSOLE: That was one thing I was not
10 including. It may well be.

11 DR. SHEWMON: That may be possible, but I don't see --
12 That is a sword of Damocles hanging over your head, and
13 you can't see who's got a knife against the hair that's
14 holding it. It seems to me that having something more
15 palpable or more short-term is still a valid point.

16 MR. EBERSOLE: I think release from existing
17 regulatory requirements where suitable would be a desirable
18 incentive to offer to the industry, to give them the impetus
19 to develop and improve a more simple process for safety.
20 They've always bitched about being hung forever with
21 existing regulations to the point where there was no merit
22 in finding an easier and better way to do something, since
23 it would only be superimposed on what they already had to
24 do. And that's true.

25 The regulator process is unbending in releasing

1429 129

76 12 13

m MM 1 existing regulatory requirements. I think it must bend if it
2 sees truly adequate efforts to do things in different ways
3 and better ways.

4 MR. MATHIS: When we talk about incentives, it
5 seems to me that the avoidance of the costs that Met Edison
6 has incurred at IMI ought to be enough incentive to do an
7 awful lot of things.

8 MR. EBERSOLE: Yes.

9 DR. SHEWMON: You've got them scared, but how are
10 you going to make it effective?

11 MR. MATHIS: I don't know. But this is why we
12 continually look for improved safety. How do you make that
13 effective to avoid an incident.

14 MR. BENDER: The safety pressures that have been
15 put on them have diverted their attention in some instances.

16 DR. SHEWMON: Look at the BWR --

17 MR. EBERSOLE: Look at the BWR ATWS. If a BW
18 ATWS occurred, you'd lose a multi-unit station.

19 DR. SHEWMON: I would suggest that you put in some
20 words that at least suggest the staff look into
21 incentives. Perhaps flexibility and dropping older
22 requirements is a better -- or better procedures can be
23 presented.

24 MR. EBERSOLE: Fire protection, Mike, in its present
25 diffuse form is a good point. We can lock safety functions

1429 130

176 12 14
m MM
1 into clearly discernible areas of protective environments,
2 and then we can relinquish a lot of expensive fire
3 protection requirements currently existing for nuclear
4 safety. We might still keep some of them for protection of
5 economic investment, but they wouldn't be nearly so complex.

6 The horribly complex requirement for unique
7 separation of A function to B function in the heterogeneous
8 environment of an auxiliary building is a terrible thing to
9 achieve when you consider environmental impacts. I'm really
10 talking about compartmentalized functions.

11 MR. BENDER: We're not going to be able to go
12 through the designs per se here. I think the best we can do
13 is sort of lean toward the idea of them saying, "Well, if
14 effort were made to find some incentives to encourage the
15 industry, this would be a help."

16 MR. EBERSOLE: Yes. Just even a hint that they
17 would be able to get rid of some of the existing regulations
18 if they found a better way would be enough.

19 MR. BENDER: We could say they might include
20 relaxation of some regulations, perhaps some caused --

21 MR. FRALEY: We could abolish backfitting
22 requirements.

23 MR. EBERSOLE: If we found a better way.

24 MR. BENDER: Any other points?

25 (No response.)

76 12 15

m M 1 MR. BENDER: Let me go to the section on
2 standardization then.

3 "The concept of standardization was originally
4 envisioned as a way to accelerate the licensing process by
5 minimizing impact. Most nuclear steam suppliers have
6 established basically uniform configurations. All major
7 equipment is standardized in manufacture and performance.
8 The thrust of recent standardization has been to obtain
9 design approval on a system basis so that system review will
10 not have to be performed repetitiously.

11 "Balance of plant design by AEs has followed a
12 similar trend. The level of detail provided in standardized
13 designs is not as complete as might be seen, for example, in
14 air transport systems, partially because much plant
15 equipment is purchased in the competitive marketplace after
16 the construction license is granted.

17 "The adequacy of the system definition including
18 level of detail to be provided for final approval of
19 standardized design has not been yet established.
20 Insufficient experience is available to display the
21 anticipated benefits from standardization.

22 "Up to now, it seems to extend further the
23 variability of designs from those of existing plants. A
24 variation of standardization that has received considerable
25 support is the replication of existing designs. This

1429 132

176 12 16

m MM 1 approach does reduce the variability since the intent is to
2 follow closely what has been done before.

3 "As applied in recent licensing actions,
4 replication approaches have unfortunately tended to restrict
5 initiatives for safety improvements on the basis that they
6 violated the principle of design stability which
7 standardization is intended to promote as a means of
8 streamlining the approval process.

9 "This restriction might also be interpreted as a
10 mechanism for circumventing requirements for public safety
11 improvements that the regulatory process should encourage.
12 There are certainly advantages to standardization that could
13 be realized if the licensing program were to be expanded
14 rapidly.

15 "It is not certain that the present NRC approach
16 really brings forth the best values from standardization.
17 The mode in which standardization is being used should be
18 re-examined to determine whether alterations would enhance
19 its value without loss of the streamlining effects on
20 licensing that it is intended to provide."

21 MR. EBERSOLE: I have a paragraph to add here
22 which I am sure is going to be bloody, but I'll read it
23 because I believe it.

24 "The content set by the standard LWR design for
25 national use has been suggested. Such a design would evolve

1429 133

76 12 17

m M 1 from careful sifting of the current design to identify the
2 range of reliability and safety developed under present
3 narrative regulations, GDC's reg guides, SRPs, and the
4 like. Such a review would follow the general pattern
5 recently used to comparatively analyze the safety and
6 reliability of current PWR auxiliary feedwater systems.
7 This investigation disclosed systems which has an apparent
8 reliability safety range of upwards of 1 to 100, which
9 suggests" -- hang on -- "what is being done with a degree of
10 freedom made available by narrative regulations in
11 virtually all systems.

12 "Such a range might well be found in many of the
13 critical systems of the plants and may well in fact show
14 that even the PWR or the BWR should be eliminated from the
15 new LWR designs which will utilize nuclear energy for the
16 near-term future."

17
18
19
20
21
22
23
24
25

1429 134

76 13 01

p. 1

1 MR. EBERSOLE: That's rough language.

2

3

It's the general context that I wonder if on a collegial basis here this committee is willing to make a statement.

4

5

MR. BENDER: I think the letter we wrote to Mr. Udall said --

7

MR. EBERSOLE: That was a negative letter.

8

MR. BENDER: That was your interpretation, that it was negative, Jesse. Because it wasn't; it was properly cautious.

10

11

(Laughter.)

12

13

MR. EBERSOLE: It was the glass is half empty, not half full.

14

15

DR. SHENMON: Your suggestion is to pull the glass away completely?

16

17

MR. BENDER: I think some people thought it was properly cautious. You may have thought it was negative.

18

19

20

21

MR. EBERSOLE: I think my prejudice stems from having looked on a comparative basis at the core design, and having found therein weird departures from the best way to accomplish the same functions.

22

23

MR. BENDER: Why don't you write out what you want to say?

24

25

MR. EBERSOLE: I will write it out. Better than that, I will have it typed.

1429 135

176 13 02

1 MR. BENDER: We can cut down the red corpuscle
2 content a little bit so that it doesn't look so nasty, and
3 we will see if we can fit it in.

4 DR. SHEWMON: Mike, in the last paragraph, second
5 line there, that could be realized if the licensing program
6 were to be expanded rapidly. Do you mean if we quadruple
7 the number of NRC people or if we quadrupled the number of
8 reactors to be reviewed?

9 MR. BENDER: I mean the latter. It doesn't come
10 across that way.

11 DR. SHEWMON: It seems to me there's a more direct
12 way you can say it. Can't you just say if the number of
13 reactors to be licensed --

14 PROF. KERR: I am sorry. Where are we?

15 MR. BENDER: First line of the last paragraph:
16 "If many reactors needed to be licensed rapidly" -- okay,
17 Paul, thank you.

18 Other comments on this section?

19 (No response.)

20 DR. CARBON: Charge on.

21 MR. BENDER: Let me go to emergency response --

22 DR. SHEWMON: At the end of 96, is it really
23 generally agreed that we want to have every plant unique, and
24 every time we come up with what we think might be a better
25 one we should go put it in the first plant we can?

1429 136

1 MR. BENDER: No, that's not the thrust of what
2 this says at all. At least, that's not what I thought I was
3 saying.

4 DR. SHEMMON: "This restriction might be
5 interpreted as a mechanism for circumventing requirements
6 for public improvements that the regulatory process should
7 encourage."

8 MR. BENDER: It's a matter of how hard you want to
9 draw the line on this business. It has, in fact, been the
10 situation in many cases people have said, "We are
11 replicating it; because we are replicating, anything new is
12 absolutely ruled out. That's an agreement which we have
13 reached with the regulatory staff."

14 MR. MATHIS: That particular sentence sounds like
15 you are circumventing or the regulatory process is
16 encouraging circumventing.

17 MR. BENDER: I think it's being used that way in
18 some cases.

19 MR. MATHIS: I know. Shouldn't we just chop it
20 off and say "circumventing requirements for public safety
21 improvements" -- period?

22 MR. CHECK: Let me see where I am. I haven't
23 thought that much about it.

24 MR. MATHIS: It's just the way he read it that hit
25 me the other way.

176 13 04

1 MR. BENDER: Okay. Well, there are some things
2 that have turned up in these replicated plants where the
3 guys that are building the plants have said, "Well, it may e
4 in the regulations, but you agreed when we went to
5 replication that we wouldn't have to meet those
6 requirements." Now you're saying take out the
7 requirements.

8 MR. MATHIS: No.

9 MR. BENDER: What are you saying, then?

10 MR. MATHIS: I am just saying stop the sentence at
11 the end of "public safety improvements." That way, you get
12 rid of the ambiguity --

13 MR. BENDER: Fine. Thank you.

14 MR. MATHIS: -- That you are circumventing or
15 recommending certain things.

16 MR. BENDER: Can I go to emergency response?

17 DR. CARBON: Go ahead.

18 MR. BENDER: "Questions concerning nuclear
19 industry capabilities for handling problems associated with
20 accident situations have been of interest since the
21 beginning of nuclear power plant development. Those
22 responsible for the safety of nuclear installations,
23 beginning with the Atomic Energy Commission, recognized the
24 need to develop such capabilities but it was never practical
25 to achieve this goal because of the general disinterest in

1429 138

176 13 05

p MM 1 such matters at the state and local level.

2 "As a result, it has been necessary, even in
3 recent years, for the NRC to require its licensees to
4 establish emergency plans which were heavily dependent on
5 the cooperation of state and local governments even though
6 these groups did not have either the funds or the personnel
7 to participate on an effective basis.

8 "Also contributing to these problems is the fact
9 that in the past the NRC has had no regulatory authority
10 over state or local agencies. As a result, the NRC staff
11 could only ask to review the radiological emergency plans of
12 such agencies. They have had no authority to make
13 recommendations for improvement, and they could discuss
14 these matters only on invitation by state or local groups.

15 "With the occurrence of the accident at Three Mile
16 Island, there has been a substantial alteration in this
17 situation, particularly with respect to the interest of
18 state and local governments in such matters. In addition,
19 several bills now pending before the Congress hold promise
20 of correcting certain aspects of these problems. These
21 actions are necessary to implement needed changes in the
22 regulatory process."

23 Dade, I take it you looked it up to include that
24 one bill I thought had gone up at one time?

25 DR. MOELLER: Yes.

1429 139

76 13 06

p. 1

1 MR. BENDER: Any problem with this?

2 (No response.)

3 MR. BENDER: Let me go to nuclear power plant
4 waste management.5 DR. LAWROSKI: It seems to me that another benefit
6 that you could mention that can be derived from
7 standardization would be that we could more quickly develop
8 reliability and risk assessments -- your data base for any
9 particular design is so much bigger.10 MR. BENDER: I think the point I was trying to
11 make -- and it evidently didn't come across very well -- was
12 there isn't anything wrong with the standardization, we
13 probably need it, but the way in which it's being used is
14 not getting you anywhere. Jesse is suggesting a way of
15 approaching standardization that might be constructive.
16 What I said here was take a look here at how it's being done
17 and see if we can find a better way to do it.18 I could put some incentives into it of the sort
19 you're talking about, with the intent of -- and then make
20 the points that you made. Okay?

21 DR. LAWROSKI: Okay.

22 MR. BENDER: I will do that.

23 DR. MOELLER: Excuse me. I think you are correct
24 and I am wrong on this. I don't know how to look at a bill,
25 but this says "An act and ordered to be printed as passed."

1429 140

176 13 07

p. MM

1 I don't know.

2 MR. BENDER: I recall this. It occurred to me
3 that I didn't know if the House had acted.

4 DR. MOELLER: We can ask the staff to check that
5 out.

6 MR. BENDER: If it were in fact enacted, I think
7 it would be a good idea to recognize its existence. If it
8 hasn't been, then, of course, the way we have said it is the
9 right thing.

10 MR. BENDER: I will fix that up, Steve.

11 Let me to go 6-10, nuclear power plant waste
12 management.

13 "Another problem that has received too little
14 attention is the matter of radionuclide cleanup following an
15 accident. Similar problems pertain to the decommissioning
16 processes for nuclear installations. The NRC has in the
17 past left these responsibilities to its licensees. As a
18 result, the associated planning and supporting research have
19 been inadequate.

20 "This is clearly shown by the inability to handle
21 the large volumes of radioactive gaseous and liquid wastes
22 that were generated by the Three Mile Island accident.
23 Neither the industry nor the involved federal agencies nor
24 their advisory groups envisioned or planned for accident
25 situations in which the character and the magnitude of the

1429 141

176 13 08

p (M) 1 waste management problems would be so different from those
2 of routine nuclear plant operations."

3 I would like to strike out the "so." Just say
4 "different." It would be just as well.

5 "The associated consequences included increased
6 personnel exposures, an inability to collect adequate
7 samples to assess the situation, and a delay in restoration
8 activities. The accompanying public opposition to plans for
9 the disposal of the decontaminated waste fluids" -- that
10 probably should be "decontaminated wastes" -- even though
11 these involve risks no greater than those associated with
12 similar wastes resulting from normal operations, has also
13 delayed cleanup of the plant.

14 "Until recently, the low-level radioactive waste
15 routinely generated in nuclear power plants and that which
16 occurs from the decontamination and cleanup processes
17 associated with the maintenance of power plant equipment
18 have essentially been ignored. The low-level wastes do not
19 pose serious human hazards if they are properly controlled
20 and confined to keep them out of food chains and away from
21 human contact exposure.

22 "These wastes have normally been shipped to
23 privately operated licensed burial grounds or to
24 government-owned facilities. The practices followed in the
25 commercial facilities have been less rigorous than desired,

1429 142

76 13 09

py MM 1 and the burial grounds themselves contain materials from
2 non-power plant sources that deserve better attention than
3 was provided.

4 "Because of both NRC's and the public's concern,
5 most of these burial grounds are now being closed. The need
6 for usable low-level waste disposal technology that meets
7 established criteria, policies, procedures, and regulations
8 is apparent. Meaningful regulatory action may dispel public
9 concern for this matter."

10 Does that cover the point adequately?

11 DR. MARK: Mike, I think, up at the top of page
12 6-24, the point pertains to transportation. That's what the
13 governors mainly complained about. That's somewhere at the
14 top of page 6-24. You say the practices followed in the
15 facilities, the burial grounds haven't done so well.
16 Transportation has aroused a certain amount of public
17 concern.

18 MR. BENDER: I will think about it. I didn't
19 think that --

20 DR. MARK: Packaging --

21 DR. LAWROSKI: Say, for example, packaging.

22 DR. MOELLER: They reported -- what -- 60 to 70
23 percent of the packages received, and these were reactor as
24 well as medical as well as research -- everybody's -- are
25 leaking or improperly labeled, et cetera.

1429 143

176 13 10

p MM 1 MR. BENDER: I will get that into this thing.

2 DR. MOELLER: Your third line on 6-24 could imply
3 it's mainly the non-power plant sources that deserve better
4 attention. It's really all of them.

5 DR. LAWROSKI: I think most of the problems with
6 Sheffield have really been with non-power plant sources.
7 Plutonium didn't come from power plants. It came from
8 national labs.

9 DR. MOELLER: Just so we keep that in mind.

10 MR. BENDER: It may be an extraneous point, but I
11 think that's what they really show.

12 DR. MOELLER: Right. And I have heard -- isn't it
13 upwards of half of the material there is not from the
14 commercial plants?

15 DR. LAWROSKI: Yes.

16 DR. SHEWMON: I have a certain amount of trouble
17 with that line simply in knowing what you're saying. If you
18 want to take out the second and third lines on 6-24, I don't
19 know that it would hurt anything. But if you want to leave
20 that in -- after "and the burial" -- I think we should make
21 it so clear that even I can understand what you're talking
22 about.

23 MR. BENDER: I might try to make a footnote out of
24 that. I think it might be a better way to handle it and get
25 it out of the body of the discussion. There are a couple of

1429 144

76 13 11

PM MM

1 things that I wanted to ask about. One, so far nothing has
2 been said about developing decontamination methods that
3 really apply to something like a TMI accident inside
4 containment, and I don't know what we should be saying about
5 it. I don't know as much as I ought to know about what was
6 done in similar kinds of accidents like the Canadian
7 reactors and the one up in Wisconsin, Elk River. Well,
8 let's see, Elk River was decommissioned, but I was thinking
9 about the one that all the fuel buried -- Lacrosse. In
10 order to get that thing back into business, they had to take
11 out a lot of damaged fuel material and put it somewhere.

12 And in a way, I think that what they did was
13 relevant to TMI, but I don't know enough about it to comment
14 on it. I wondered whether anybody else here did.

15 DR. RAY: Lacrosse?

16 DR. PLESSET: They had a cladding failure.

17 DR. SHENMON: They pulled it out and the rest of
18 the pieces were rattling around, and the big problem was to
19 find it, I thought, rather than what to do with it when they
20 got rid of it.

21 PROF. KERR: As far as I know, most of it is in
22 their spent-fuel storage pool right now.

23 DR. LAWROSKI: They did not report particularly
24 great difficulty in dealing with all that failed fuel at the
25 last subcommittee -- well, not the last -- the

1429 145

176 13 12

p MM 1 next-to-the-last subcommittee meeting.

2 MR. BENDER: Should we have something in here that
3 addresses the problem of what to do about reactors that have
4 actually been through one of these serious accidents?

5 DR. MOELLER: We have a suitable paragraph in the
6 July RSR report or one that might be a beginning. I can get
7 that for you.

8 MR. BENDER: Yes. Okay.

9 DR. MOELLER: I will do it.

10 MR. BENDER: What I might do would be to try to
11 find or add a section that covers accident recovery.

12 DR. SHEWMON: Mike, do you talk about spent fuel
13 someplace else in this?

14 MR. BENDER: No.

15 DR. SHEWMON: Well, you know, you've got two bad
16 problems: one, what are you going to do with spent fuel;
17 and the other, what are you going to do with short-term
18 waste. And constipation is tying up both systems just with
19 different time constants.

20 MR. BENDER: I didn't deal with the spent fuel
21 business, either. You think I should do that? What do you
22 want to say about spent fuel?

23 DR. SHEWMON: Well, I guess it's perceived as a
24 problem, and what we have done is to avoid it by doubling
25 the capacity of the spent fuels. And maybe you think

1429 146

76 13 13

1 political — I don't know what's happening. I think it's a
2 long-term major problem.

3 MR. BENDER: We have doubled the existing pool.
4 We could probably add four more pools to every reactor plant
5 we wanted to. I don't think there's anything that says that
6 those pools need to be exactly in one place. I think taking
7 the pools off site has created some concern, but having
8 another on-site pool wouldn't be all that much of a
9 problem.

10 DR. SHEWMON: I think that's putting your head in
11 the sand. I don't know whose job it is to worry about
12 what's going to happen to that stuff ultimately, and maybe
13 the NRC doesn't have anything to do with it. If so, then we
14 shouldn't mention it. On the other hand, if the NRC is
15 likely to have any role in what happens to that fuel when we
16 finally decide that six spent-fuel pools per reactor is
17 enough, then I think it should probably be brought up here.

18 MR. BENDER: What do you suggest we say?

19 DR. SHEWMON: I guess my feeling is that all
20 wastes are a problem. You have brought up two of them out
21 of three. One, bad accidents are something we haven't
22 looked at, and that's a very timely point. Two, they are
23 closing down all --

24 MR. BENDER: The low-level wastes.

25 DR. SHEWMON: — which has crisis proportions soon

1429 147

16 13 14

p. MM

1 and we may be walking around that one. Just as sure as the
2 Lord made little green apples, you're going to have a
3 problem with spent fuel down the road.

4 MR. BENDER: I could say something like we
5 shouldn't ignore the spent-fuel storage problem even though
6 the present plans to expand spent-fuel storage at the plant
7 sites represent a good short-term solution.

8 DR. SHEWMON: I think they represent a viable
9 postponement.

10 DR. RAY: Would you want to point out in
11 conjunction with that if they resumed reprocessing that they
12 would minimize the amount of waste that they would have to
13 store?

14 MR. BENDER: I think I am going to have to wait
15 until after the next election.

16 (Laughter.)

17 DR. CARBON: Yes. We really don't gain much by --

18 DR. LAWROSKI: By expanding, we simply say it's
19 crucial to get additional land burial sites licensed? That
20 takes care of the low-level wastes.

21 DR. SHEWMON: I think that's certainly true.

22 MR. BENDER: Your point is well taken here.

23 DR. LAWROSKI: That, followed by another one, that
24 until or unless reprocessing is resumed, the other part of
25 that waste management problem is that of the spent-fuel

1429 148

76 13 15

p M 1 storage.

2 MR. BENDER: If you guys want that in, I will put
3 it in. But I don't agree that that sort of --

4 DR. LAWROSKI: To me, the spent fuel is not a
5 major --

6 (Simultaneous discussion.)

7 DR. SHEWMON: Why do anything to it until it's a
8 major problem?

9 DR. LAWROSKI: No, no.

10 DR. CARBON: It is policy, and to me it's more of
11 a point that there is nothing we can do about it. The
12 President has said, "That's it," and we can recommend
13 anything we want to the NRC but they can't do anything about
14 it.

15 DR. LAWROSKI: That's his point, though.

16 DR. SHEWMON: Pardon me. I thought part of this
17 was go to up on the Hill with problems that somebody is to
18 worry about nationally. I have never seen this committee
19 before particularly reluctant, that, "Gee whiz, that's
20 somebody else's job connected with nuclear power."

21 DR. CARBON: I don't mind the "Gee whiz,
22 somebody else's job." I just figure there is nothing we can
23 gain by it.

24 DR. SHEWMON: You think it's totally political and
25 nontechnical and the NRC doesn't have anything to do about

1429 149

176 13 16

1 it? If asked, they can anytime they want to.

2 DR. CARBON: I figure they can't do anything --
3 period.

4 PROF. KERR: Let me point out that the low-level
5 waste is equally political, and if one uses the same logic,
6 it seems to me one stays away from it. I don't see any
7 logic in leaving out high-level waste if we're going to talk
8 about radioactive waste.

9 DR. LAWROSKI: I think it's certainly going to be
10 a problem if we don't resume reprocessing.

11 DR. SHEWMON: Or if you don't, at least get
12 someplace where they can take it out of the pool.

13

14

15

16

17

18

19

20

21

22

23

24

25

1429 150

Cr. 8176
t-1
sls 1

1 DR. MOELLER: Let me propose a paraphrase from the
2 words of the RSR report in July. It says more attention should
3 be directed to steps that might be implemented in the recovery
4 and re-entry phase following an accident. This program should
5 include evaluations of designs and procedures to facilitate
6 the decontamination recovery of major nuclear power plant
7 systems and handling the associated waste. It should also
8 include attention to decontaminating and reclaiming buildings
9 and equipment and the establishment of dose limits or guides
10 for their re-use.

11 MR. FRALEY: But there were also comments in that
12 report about the NRC -- I thought it was, maybe it was a
13 separate letter about the NRC's role in the waste management
14 program and guiding DOE and their expensors and what have you.
15 In fact, they complained that this was not being done in any of
16 its reports.

17 MR. BENDER: Any other comments on this thing?

18 Are there other places of things that ought to be
19 covered in this technological discussion?

20 I had at one time thought something on risk assess-
21 ment, per se, or to get in here. I was going to put it in the
22 section covered in the beginning, design basis accident, but
23 I didn't feel comfortable putting it in there. But if you
24 want something on risk assessments, methodology, we ought to
25 consider what ought to be said. Maybe Dave and his thought

1429 151

1 processed could crank up something that would be appropriate.

2 Can you do that, Dave?

3 DR. OKRENT: I can try.

4 MR. BENDER: Can we take a break, Mr. Chairman?

5 DR. CARBON: If you would like, we will be knocking
6 off in about 40 minutes or we'll take a break now if you wish.

7 MR. BENDER: I think we ought to take a break.

8 DR. CARBON: Let's try and make it a short one and
9 come back at a quarter to one.

10 (Recess.)

11 MR. BENDER: "The intent of the Congress when
12 creating the NRC was to establish a regulatory agent free
13 from promotional bias to oversee the safe use of nuclear
14 energy in order to improve public confidence in the
15 regulatory process. The law implied by its sanctioning
16 of nuclear plant licensing that the basic approach was
17 safe, but the policies and practices under which the
18 nuclear power was regulated might need some modification.

19 "Public understanding and acceptance of the nuclear
20 power as a beneficial source of energy depends upon
21 effective regulatory management. The regulatory function
22 is extremely complex. Some of it is legal in form, some
23 of it is political, and all of it involves very complex
24 technology. The regulatory process must be stable in the
25 eyes of the industry, it must be vigilant in protecting the

1429 152

sls-3

1 safety of the public, and it must handle safety questions
2 intelligently, responsibly and expeditiously." That's a
3 lot of words.

4 DR. SHEWMON: Why do we have protection in there?

5 MR. BENDER: Why do we have it in there?

6 DR. SHEWMON: I thought you were going to tell me
7 some particularly urgent management consideration.

8 MR. BENDER: It was just an introduction to what
9 is going to come on further. It may not be a good introduction.
10 That's why I say it probably should be thrown away.

11 "Regulatory Responsibility.

12 "The regulatory organizational structure has five
13 equal offices under the direction of an Executive Director
14 of Operations. The law makes each office directly account-
15 able to the Nuclear Regulatory Commission, thus exempting
16 the EDO from responsibility for public safety decisions.
17 The Commissioners themselves are selected in accord with
18 political affiliations. The Congress apparently intended
19 for the Commissioners to act in a policy making role, but
20 not in an executive role. The Regulatory Staff often has
21 not brought matters involving regulatory action to the
22 Commissioners soon enough to obtain timely policy guidance.
23 Offices sometimes act independently of each other and of
24 the Commission's direction when their actions should be
25 interdependent. The result is apparent confusion concerning

sls-4
1 the source of authority for regulatory positions, adversely
2 affecting public confidence in the regulatory process.
3 Integrated and identifiable authority is needed to correct
4 this situation.

5 "A matter of equal concern is whether the NRC has
6 delegated too much responsibility for public safety to the
7 licensee. The NRC could interject itself more into
8 operational planning and training. The presence of an NRC
9 representative at the plant offers NRC the prerogative to
10 decide when and whether plants should be started up or
11 shut down. The NRC could also set more explicit require-
12 ments with respect to plant design and operating procedures
13 and effluent discharge, and it could require all applicants
14 to follow these NRC directions. Regulatory practice has
15 avoided this in the past because it relieves the licensees
16 of responsibility for design and operational decisions.

17 "Recent experience shows that the licensee have
18 not accepted responsibility to the extent desired but the
19 responsibility role intended for the licensee by past
20 practice appears to be desirable in order to maintain
21 regulatory balance. The NRC has the authority to require
22 design improvements and enhanced operating controls when
23 ever public safety requirements indicate the need. The
24 objectivity of the NRC reviews might be lost if the agency
25 had to defend its own design and operating initiatives.

1429 154

sls-5
1 The crucial action is to establish that those who are
2 assigned responsibility are capable of and are accepting it
3 responsively."

4 That's too many words, and maybe it just ought to
5 say that the responsibilities within the regulatory organiza-
6 tion are a little confused, that those assigned to the licensees
7 are okay except that the licensees aren't accepting them as
8 fully as they are expected to be, and that's what it was
9 intended to say.

10 DR. SHEWMON: What is your basis for the last
11 clause that you just said that they aren't accepting their
12 responsibilities as much as they should?

13 MR. BENDER: I suppose TMI is the best example of
14 it. The fact that they haven't built up their capabilities
15 as well as they should build them up; the fact that they have
16 not --

17 DR. SHEWMON: Now you are painting all of them --
18 tarring all of them with the same brush.

19 MR. BENDER: It's true they all deserve to be tarred
20 with the same brush.

21 DR. SHEWMON: That's your feeling. The question is
22 whether it's the collegial feeling.

23 MR. BENDER: Okay.

24 DR. LAWROWSKI: I think a good share of them deserve
25 to be similarly tarred.

1429 155

sls-6

1 DR. SHEWMON: Well, I think they devote a fair
2 amount of effort and money in trying to comply with the regula-
3 tions that have been put out and to take Mike's position I
4 really don't think they are out to endanger the public for a
5 variety of reasons. So, I guess I would like to have something
6 that was a little bit more explicit as to where we feel they
7 have fallen down so badly or rejected their responsibility.
8 Right now we are just kicking them because it's stylish. That's
9 the way it's done now.

10 PROF. KERR: Are you pointing to something specific,
11 Paul, or just the general tone?

12 DR. SHEWMON: Recent experience shows that the
13 licensees collectively have not accepted responsibility to
14 the extent desired, but the responsibility role intended for
15 the licensee by past practice appears to be desirable in order
16 to maintain regulatory balance. Okay. The first half of that.
17 I would just like something more explicit if indeed it's there
18 about where we feel they haven't accepted their responsibility.

19 I think the EPRI or the programs they have through
20 EPRI are good and quite responsible, and I think there are
21 things that probably the NRC couldn't do near as well with
22 regard to training licensees in some self regulation.

23 DR. LAWROWSKI: That's again a question of post-
24 TMI or pre?

25 DR. SHEWMON: TMI I will kick with you or Met Ed.

1429 156

sls-7
1 but I guess the whole group I would like to have a little bit
2 clearer what we are kicking at or why.

3 MR. BENDER: Certainly to say all of them aren't
4 responsive may be tarring them all with the brush that is not
5 deserved. But I think more than a small number are not.

6 DR. LAWROWSKI: How about many?

7 MR. MATHIS: Just the fact that they have created
8 INPO I think is an admission on their part that they haven't
9 been doing what they should be.

10 PROF. KERR: That can be taken as a criticism for
11 lack of judgment, perhaps, but it seems to me one can certainly
12 learn by experience. You could either assume that they knew
13 all along that they should have had INPO, that they didn't
14 realize that until recently and now they are doing something
15 about it. I guess I am not sure which. Maybe some of both.

16 But Mike, if you did not intend to tar the whole
17 group it seems to me you could change that to say recent
18 experience has been interpreted by some to show that or --

19 MR. BENDER: I think that's a good proposal.

20 DR. SHEWMON: Or to the extent desirable.

21 MR. BENDER: Actually I was thinking in terms of
22 whether we ought to be saying something about whether the role
23 of the licensees and their responsibilities should be shifted
24 and more turned over to the regulatory side of the business.
25 And I was trying to develop an argument which said they may not

sls-8
1 be doing as well as they could, but it's better to make them
2 do what they ought to do than to take the responsibility away
3 from them. And I think I could fix it up so it says that
4 instead of being -- having the thing written so it is
5 interpreted as saying they are all doing the wrong job.

6 DR. MOELLER: I have trouble with it -- with the
7 sentence, I guess, just from understanding it. It says
8 recent experience shows they haven't accepted responsibility
9 desired. But the responsibility is desired. I guess what you
10 are saying is that they have not accepted the responsibility
11 to the extent desired even though this responsibility must be
12 assumed if the regulatory process is to function?

13 MR. BENDER: That's what I intended to say. I didn't
14 say it very well. That I agree with.

15 Why don't I shuffle it around a little bit along
16 the line that Bill Kerr suggested. Would that take care of
17 your concern, Paul?

18 DR. CARBON: Charge on.

19 MR. BENDER: "Legal Framework.

20 "A legal basis for regulation is essential to the
21 regulatory functions. The reviews by the ASLBS are
22 apparently intended to establish that the NRC has a basis
23 for its rules and regulations, and is following its own
24 regulatory requirements and policies, and is satisfying the
25 intent of NEPA. The NRC Legal Staff acts as the advocate

1429 158

sls-9
1 of the NRC licensing actions before the ASLB, sometimes as
2 the channel through which the Boards can probe the staff
3 positions on licensing actions.

4 "There are some significant advantages to the public
5 in this process. It sometimes provides an opportunity for
6 legitimate safety concerns not fully exposed in the ACRS
7 reviews to be examined further. It provides a valuable
8 forum for discussing NEPA issues of concern to the public.
9 Nevertheless, the hearing process tends to lean more toward
10 legal maneuvering than a total exposition of public safety
11 and environmental concerns. It seems to encourage minimal
12 discussion of safety issues in the Safety Evaluation Report
13 and other documentary evidence intended for Hearing Board
14 review, and legally oriented oral statements by staff
15 members. The regulatory staff is discouraged from discus-
16 sion of controversial subjects of safety concern in open
17 meetings including those with the ACRS. These restraints are
18 probably intended to eliminate extraneous matters from the
19 record that might unnecessarily delay the hearing process.
20 Unfortunately, they may also be preventing full exploration
21 of some significant safety issues because of concerns for
22 licensing delays.

23 "Since the SER now seems to be prepared mainly to
24 provide information for legal purposes at the ASLB Hearing,
25 it consists primarily of repetitive "boiler plate" which

1 tends to obscure the safety issues and provides little
2 amplification. The result is that the SER has become a
3 document of little value to the safety reviewer attempting
4 to gain understanding.

5 "Public safety is not well served by this legal
6 style of safety issue presentation. If the SER included a
7 discussion of the various aspects of each significant
8 safety issue together with the judgment basis for the NRC
9 Staff conclusions, the report could serve in a more
10 appropriate role at the AS:B hearing. Its reasoning could
11 be examined by the ACRS and the ASLB without the need for
12 advocacy by the NRC Legal Staff. Where a basis had been
13 previously established, the reference basis could be
14 identified. The public would then be able to see why,
15 where and how the NRC Staff's safety conclusions were
16 drawn.

17 "The hearings of the ASLBs are frequently adversarial
18 in form, and the NRC Staff has developed an approach to
19 coping with this aspect of its function that might be
20 interpreted as more a legal defense of its position than a
21 safety analysis of the proposed nuclear reactor station
22 and a technical basis for the Staff judgment."

23 I think that paragraph just ought to be struck. It
24 didn't say anything.

25 "ASLB rulings on specific safety issues have sometimes,

sls-11

1 because of legal considerations, tended to circumvent public
2 safety interests as the following illustration shows. The
3 ASLB has on occasion ruled that the NRC could not require
4 planning for emergencies beyond low population zones. It
5 has also ruled in some cases that the low population zone
6 radius must be reduced because of population growth near
7 the plant site. These two rulings combine to permit more
8 intensive local population density adjoining some sites
9 without planning for emergencies.

10 "The ASLB hearings are also used as a mechanism for
11 determining whether the NRC staff has an appropriate basis
12 for rule making. The hearing does provide an opportunity
13 for open debate, but it is sometimes outside the context
14 of specific licensing actions. Whether this provides the
15 proper forum for establishing technological validity is
16 not entirely clear."

17 DR. SIESS: Is that right to use boards for rule-
18 making?

19 MR. BENDER: I think they do. They appoint boards
20 to hear the rule making arguments.

21 DR. SIESS: Was there a board for the ECCS hearing?

22 DR. BAER: Yes, although the Commission limited
23 them to compiling a record.

24 DR. SIESS: Was it an ASLB?

25 DR. BAER: I don't know.

1429 161

sls-12

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

DR. SIESS: Because I thought there had been rulings in ASLB hearings that the Commission's rules were not in question.

DR. BAER: Once a rule has been promulgated by the Commission, from whatever source, the boards are not allowed to rule out the ruling of those regulations.

DR. SIESS: Okay. That goes back then to Paragraph 107 on that.

End t-14

1429 162

mgcMM

1 MR. BENDER: Skip over the next page, because for
2 some reason the rest of this paragraph got on 7-6.

3 "Adversary proceedings lasting more than a year
4 resulted in the development of an ECCS rule-making
5 concerning analysis techniques to show its performance
6 adequacy, but some reliability aspects were never adequately
7 during the hearing process. If the hearing process is to be
8 used as a basis for rule-making, the manner in which the
9 issues are to be addressed and the rules established need
10 further study."

11 Then going back to the previous page, "The
12 attention directed to the National Environmental Policy Act
13 may be directly interfering with public safety review by
14 diverting attention to other NEPA interests such as power
15 system growth, cost benefits of alternate power sources,
16 antitrust considerations, and other environmental matters.
17 These are matters of major public interest, and the NRC is
18 probably justified in its diligent attention to them.
19 However, there has been a tendency to move NEPA matters
20 ahead of public safety matters deserving of attention.

21 "The selection of a power plant site, for
22 instance, is weighed carefully by NRC with respect to its
23 economic benefits, social impacts, power system demand, but
24 in most cases, safety alternatives are weighed only with
25 respect to whether a particular site meets the minimum

1429 163

mgcMM

1 safety requirements. The public hearings" -- going back to
2 7-6 -- "The public hearings are an important aspect of the
3 nuclear regulatory process, but some consideration needs to
4 be given to changing the style of the hearings so that
5 safety issues can be exposed fully without unnecessarily
6 delaying licensing actions.

7 "The combining of NEPA and safety reviews in the
8 ASLB hearings may be a contributing complication. To the
9 extent practical, it would be desirable to separate them in
10 the hearing process."

11 DR. SIESS: One comment is -- I believe the
12 rule-making hearings and the ASLB hearings are mixed up in
13 here, and I don't see any objection to having them both in
14 the same chapter. But I think they could be separated out a
15 little bit.

16 In your first paragraph, you say, "The reviews for
17 the ASLBs are intended to establish the NRC as a basis for
18 its rules." That's a rule-making hearing, and that's really
19 not a normally ASLB function. It may be occasionally.

20 Then the paragraph 113, which does talk about
21 rule-making, I think is appropriate. But, you know,
22 separate the two functions.

23 MR. BENDER: Okay.

24 DR. SIESS: And we might ask Herzl to check
25 whether the rule-making hearings are -- the special boards

mgcMM 1 are ASLBs.

2 MR. BENDER: That's probably a good point. What I
3 did was just look in the regulations.

4 DR. SIESS: In paragraph 114 on NEPA, you say
5 "power system load growth, cost benefits, antitrust, and
6 other environmental matters." Do you consider antitrust and
7 power systems environmental? The figures -- antitrust is
8 not under NEPA. That's clearly not a NEPA item. That's a
9 separate part of the law, and I believe there's a
10 separate -- is there a separate law for antitrust hearings?

11 MR. BAER: I don't think so.

12 MR. BENDER: We'll get that looked up, too.

13 MR. MOELLER: You could delete the word
14 "environmental" -- just "in other matters."

15 MR. EBERSOLE:

16 DR. SIESS: You ought to get environmental matters
17 in there somewhere.

18 MR. BENDER: I think I can get the antitrust
19 business separated.

20 DR. SIESS: Leave the other out, because NEPA
21 review does cover need for power, cost benefits, and
22 environmental matters -- snail darters and things like that,
23 but it's not "other" environmental matters. That's the first
24 mention of it.

25 MR. BENDER: It's so broad, it doesn't say

mgcMM 1 anything about need for power. It's just the NRC's way of
2 saying --

3 DR. SIESS: I don't think if the NRC had its way,
4 it wouldn't do any of it. It was a decision by a judge in
5 Calvert Cliffs that told them what to do.

6 MR. BENDER: You're right. We'll get that looked
7 at.

8 Let me go to this next section on regulatory staff
9 competence.

10 "Taken as a whole, the professional competence of
11 the NRC staff is impressive because of its size, its varied
12 talents, and the high level of academic training and
13 experience which its members have obtained. Nevertheless,
14 each time a significant new safety event appears, it usually
15 points to a weakness in the regulatory staff expertise.
16 The areas that now seem to need the most attention are
17 systems analysis and plant operation.

18 "With respect to systems analysis, the staff which
19 has been highly compartmentalized needs to build a stronger
20 capability to understand and anticipate the interactions
21 between plant systems, the effects of accidents on
22 environment, systems disturbances from external phenomena,
23 and other comparable matters.

24 "Relative to plant operations, the I&E staff in
25 particular needs to understand the behavior of operating

mgc/MM

1 systems, assess the capabilities of operators, and assure
2 that operational activities do not jeopardize public safety
3 because of design, construction, or operational errors.

4 "The recent organization of a Systems Engineering
5 Group will be helpful in reducing the compartmentalization
6 of technical skills and may ultimately satisfy the systems
7 analysis need. The operational aspects of nuclear power
8 plants have not yet been examined sufficiently to clarify
9 how the staff capability should be strengthened. Training
10 methods, improved procedure format addressing symptomatic
11 analysis, broadened accident simulation capability for
12 operating plants, improved radionuclide effluent control
13 methods, improved in-service inspections of public safety
14 features are all representative of matters requiring
15 attention.

16 "These suggest a need for reorientation of review
17 attention, rather than the addition of new staff skills. If
18 the present staff is already preoccupied with existing
19 tasks, new sources of manpower may need to be obtained.

20 "One way to expand the I&E capability is through
21 the use of third-party review. The development of outside
22 review sources to review other plant features on a system
23 basis might be a useful approach. This approach is already
24 accepted by the NRC for the primary coolant circuit and
25 containment structures under the ASME boiler code.

mgcMM

1 Qualification of the reviewers' capability would need to be
2 established, but in principle this could extend the staff
3 capability directed to the nuclear quality assurance process
4 without requiring significant additions to the NRC staff.

5 "In order to avoid oversight concerning these
6 capabilities, the NRC should consider the establishment of
7 ad hoc review bodies to examine staff capabilities in order
8 to determine whether they are adequate for regulatory
9 purposes. While the ACRS can contribute to this activity,
10 its limited time may not be best used for this
11 purpose. Other arrangements for reviews of this should be
12 sought. Individual ACRS members might be able to lead ad
13 hoc reviews by consulting experts.

14 "It is important that such reviews be conducted by
15 people who appreciate time, funding, and responsibility
16 considerations as well as technological matters."

17 Any comments on that? Discussion?

18 DR. SIESS: Several. In 116, that statement that
19 "each time a significant new safety event appears, it
20 usually points to a weakness in the regulatory staff
21 expertise." I'm not too sure of that. I suspect you could
22 find somebody on the staff that was expert on just about
23 everything, including whether you can generate oxygen in a
24 PWR. But it's the process or the procedure or the system
25 that has a weakness. Otherwise, it wouldn't be -- I mean a

1429 168

mgcMM

1 new safety event, whatever "event" means --

2 MR. BENDER: Okay. Are you saying a weakness in
3 the process?

4 DR. SIESS: Yes. But since you're talking about
5 the staff's competence here, I think we need to think
6 whether you want it in there at all. I don't think that
7 sentence -- every time a new event -- you said down at the
8 bottom of the page that we don't need additional new staff
9 skills, and I believe that's wrong. The staff has admitted
10 that they don't have skills in human engineering.

11 MR. BENDER: Let's get rid of the sentence.

12 DR. SIESS: They need people there. I don't think
13 they've admitted that they don't have the skills in systems
14 analysis.

15 DR. CARBON: Mike is dropping the sentence.

16 MR. BENDER: I'll have to say something.

17 Nevertheless, some areas still need attention.

18 DR. SHEWMON: Are you on paragraph 116 or 118 now?

19 MR. BENDER: 116.

20 PROFESSOR KERR: Let me comment --

21 DR. SHEWMON: But there would still be question,
22 then, down in 118 at the bottom of the page as to whether
23 you want to modify that one, too.

24 PROFESSOR KERR: May I comment on 116? Mike, I
25 assume in line 3, you don't mean to imply that the staff

1429 169

mgcMM 1 has a high level of academic experience. If you don't, then
2 I would suggest inserting between the "and" and
3 "experience", "of professional."

4 DR. PLESSET: They have a high level of
5 experience. Put that first, and also have academic
6 training.

7 DR. SIESS: Max has been counting Ph.Ds.

8 PROFESSOR KERR: You're changing the sense of what
9 he said. I was only trying to help him say what I thought
10 he was trying to say.

11 DR. PLESSET: I wanted to change the sense of it.

12 MR. BENDER: Not literally, Chet, but you may be
13 right. I haven't checked on how much training the staff
14 has, but they've got a lot when you look it.

15 DR. SIESS: They go together. I don't put that
16 much faith in a Ph.D without the experience.

17 PROFESSOR KERR: Mr. Bender, I don't want to lose
18 a word of what you're saying. If you hold the microphone in
19 your lap, it sure makes it tough --

20 DR. CARBON: Other comments on this?

21 DR. SIESS: I've got a couple still. Second line
22 of 118, it says, "The operational aspects of nuclear power
23 plants have not yet been examined sufficiently." By us?
24 Because I&E just came out with a pretty comprehensive report
25 on what they think ought to be done, so the question is,

mgcMM

1 by whom, examined sufficiently?

2 DR. OKRENT: Or in what way?

3 DR. SIESS: Or in what way, yes.

4 MR. BENDER: Well, I think the I&E staff report
5 provided some information. I don't know that I would be
6 prepared today to say that that particular report,
7 particularly since it wasn't exactly one written by somebody
8 that was standing back, necessarily was representative of
9 the kind of evaluation that ought to be made, particularly
10 with respect to operations. But I don't want to say it
11 wasn't a good report.

12 DR. SIESS: But that list of things requiring
13 attention --

14 MR. BENDER: I think it just says it's
15 representative.

16 DR. SIESS: Okay. I'll leave that to the
17 Committee to decide.

18 In the next to last line, the last three, it says
19 they don't need new staff skills, and this is an area where
20 they are completely lacking in the human engineering
21 expertise, and they are looking for people. So I think that
22 is not quite true.

23 MR. BENDER: Perhaps I should say "and probably
24 the addition."

25 DR. SIESS: I've got one other question on the

1429 171

mgcMM 1 next page. You're talking about outside review sources, and
2 you say this is done for — using ASME Code, Section 3. For
3 the Section 3, Division 1, I think there is an independent
4 stress analysis stress report called for, isn't there, on
5 the vessel?

6 MR. BENDER: Yes.

7 DR. SIESS: Is that true on all the piping?

8 MR. BENDER: Primary piping.

9 DR. SIESS: Okay. But I don't think that's called
10 for for the containments, is it? In Division 2?

11 MR. BENDER: My recollection is that it is, Chet.

12 DR. SIESS: I think we ought to check, yes.

13 MR. BENDER: I'll be glad to look at the thing.

14 DR. SIESS: I didn't remember it for
15 containments. I think for the vessels in Division 2 it is.
16 You know, I don't think it is for containment.

17 MR. BENDER: The whole primary coolant system has
18 been dealt with. I have to see about containments. I
19 thought it was.

20 DR. CARBON: I think Dave asked for the floor
21 next.

22 DR. OKRENT: Take Paul.

23 DR. SHEWMON: I&E worries about operating plants.
24 Is that right?

25 DR. LAWROWSKI: No, construction, too.

1429 172

mgcMM

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14
- 15
- 16
- 17
- 18
- 19
- 20
- 21
- 22
- 23
- 24
- 25

DR. SHEWMON: So the review you are talking about
 in paragraph 119, then, is for a plant before its
 operating. Is that correct?

E/S

76 16 01

1 MR. BENDER: No, I didn't quite try to be that
2 definitive. I was trying to leave open where you would go
3 with it. I don't really know how you could go with it.

4 DR. SHEWMON: Well, paragraph 120 bothers me a
5 reasonable amount, I guess, partly because maybe we should
6 recommend it, but if we do I wish I knew a little bit more
7 of what you had in mind. Are we going to come in and
8 certify them periodically? Do we want a group that would
9 look over their shoulders and redo their calculations? What
10 would these review groups be? And are we limited to I&E
11 now, or are we talking about the whole staff or whatever?

12 MR. BENDER: Well, I think I am not talking about
13 the staff, but some outside organization becoming the
14 potential group.

15 DR. SHEWMON: And would recertify the staff?

16 MR. BENDER: I think the way in which the ASME
17 code does it --

18 DR. SIESS: He's in the next paragraph. 120.

19 MR. BENDER: Oh, I see. Okay.

20 DR. SIESS: If you want to stay on 119, I have got
21 another question.

22 MR. BENDER: Let me get answers. I didn't
23 understand your question, Paul. Say it again.

24 DR. SHEWMON: Well, in 120, I am not sure --
25 building from 119, I would say, "Well, you wanted to come in

1429 174

1/6 16 02

1 and redo calculational work for you, that they don't have
2 the time to do it." And I guess that's where the ASME group
3 does before it's built.

4 We come down to 120 and say these are review
5 oodies. This is more to certify the staff or their
6 competence?

7 MR. BENDER: That paragraph isn't written right,
8 because it clearly didn't get the right message across.
9 They are two separate thoughts. The one in 119 was
10 intended to say, "Look, if you don't think we want to build
11 up the staff anymore, then an alternative is to find some
12 outside way of doing reviews."

13 But separate from that ought to be some group on
14 the outside that is taking a look at the way in which the
15 organization is running itself, to see whether it has got
16 the right slant on doing business. And I don't think that
17 we necessarily are the right group to do it, although we
18 might be able to help organize such a review. My
19 inclination would be to decline to do it if I were asked.
20 But I didn't want to rule out that possibility.

21 Do you understand what I am -- the message I am
22 trying to get across?

23 DR. SHEMMON: Yes. I don't like it, but I guess I
24 understand it.

25 DR. LAWROSKI: Is it your concern that because it

1429 175

76 16 03

py MM

1 is seemingly limited to I&E?

2 DR. SHEMMON: No, it is just -- well, we haven't
3 called ECPD inspections. It has to do with somebody who
4 comes in as a one-day expert and says whether you should be
5 allowed to continue educating students or not, and, yeah,
6 maybe it's useful, but --

7 DR. LAWROSKI: It's two days.

8 DR. SHEMMON: I am not too enthusiastic about that
9 way of increasing the competence of the staff or certifying
10 it. Partly, that's the management's approach, or business
11 now. But I just don't think you are going to get together a
12 group that will come in -- you know, we can each point out
13 staff people we kind of wish were working for somebody other
14 than the NRC, but I don't know, once you get the list and
15 it's certified by a bunch of outside experts, what are you
16 going to do with it?

17 MR. BENDER: Well, I guess I haven't really
18 thought about it. I have seen a few management review
19 groups' work that were really good review groups, as opposed
20 to some that I know that didn't deserve the name. The good
21 ones will look at what kind of people are doing the job and
22 whether they've got the right slant on their job, and if
23 they have enough outside experience, they will be able to
24 see whether the people that are there are able to cope with
25 the assignment they have been asked to do. And it's really

1429 176

76 16 04

p. MM

1 very helpful to the internal management to have some
2 intelligent advice. At the moment, they are sort of
3 operating in a vacuum, and I think if they could get the
4 right kind of advice it would be helpful.

5 That's the thought that I have: if they get poor
6 advice, it's not worth anything -- just a waste of time.

7 DR. SIESS: Going back to paragraph 119 on the
8 outside review, you explained that to me, and I guess I
9 looked at it a little differently. That is sort of
10 complicated. You are talking about outside review to do
11 what the staff does, but to do more of it. Right?

12 MR. BENDER: Yes.

13 DR. SIESS: And not necessarily an independent
14 outside review. Certainly, the stress report under the ASME
15 code is just another person at the same level as the
16 applicant or the vendor doing it. It's an independent
17 review, but it's not independent of the owner, let's say.

18 What do you call it when the staff goes out to the
19 Franklin Institute to review all the unresolved issues of
20 the supplemental evaluation program? Is that an outside
21 review?

22 MR. BENDER: I hadn't quite envisioned that,
23 although that's an alternative. I had envisioned that the
24 staff would require the applicants to get these reviewers to
25 do the job, and that the applicant would pay them, but the

1429 177

1/6 16 05

1 staff would make sure that they were qualified.

2 DR. SIESS: That would be like the stress report,
3 then.

4 MR. BENDER: Yes.

5 DR. SIESS: And not like the Franklin Institute
6 thing where the staff is buying outside help?

7 MR. BENDER: That's right.

8 DR. SIESS: And not like a third-party inspection
9 of the TUV type where they are essentially independent of
10 the applicant -- I don't know whether that comes in the same
11 as the Franklin --

12 MR. BENDER: The thing to me is not a way unlike
13 the the ASME code and they function independently of the
14 group they are inspecting. But they are paid by the
15 organization that they are inspecting through some kind of a
16 fee system that can't be refused.

17 DR. SIESS: Who pays for it I am not sure is all
18 that important.

19 MR. BENDER: I don't think it is, either.

20 DR. SIESS: They use a proof engineer approach in
21 some places in Europe. When the building official doesn't
22 feel -- or the insurance agencies it might be -- doesn't
23 feel competent, they go out and hire somebody of suitable
24 stature to do it.

25 The thing is, other reviewers or other outside

1429 178

76 16 06

py MM

1 review sources of various levels of outside. And I wonder
2 if this paragraph with this particular example is exactly
3 what you want or whether you want to rule out the others.

4 MR. BENDER: I didn't want to rule out others, and
5 I didn't necessarily want to say that what's done should be
6 exactly like this. The point I am really trying to make
7 was this concept is not new to the NRC, they already have
8 some times when they are accepting outside independent
9 review of this sort, so they are not breaking new grounds.
10 Now, the approach which might be used in this case would
11 have to be -- I think would vary a great deal depending on
12 what you were planning to look at.

13 DR. SIESS: I remember under the code the staff
14 was having a problem accepting the third-party review --
15 that is, the boiler pressure vessel inspector review --
16 because they had no way of auditing what that third party
17 was doing.

18 MR. BENDER: The state inspectors.

19 DR. SIESS: The state inspectors, the authorized
20 inspecting agencies, who are certainly paid for by the
21 applicant. Did they resolve that by having the state
22 inspectors agree to be audited?

23 MR. BENDER: I think they finally got around to
24 it.

25 Do you know, Bob?

1429 179

76 16 07

pv MM

1 MR. BAER: No, I don't.

2 DR. SIESS: Does the staff have a way of auditing
3 stress report preparers to know whether they have got a QA
4 program? But they do accept stress reports; don't they?

5 MR. BENDER: I think what they do there is follow
6 the codes technique of saying the code requires that the guy
7 be qualified, have experience and be qualified in the area
8 in which he's reviewing.

9 DR. SIESS: See, that was true of the authorized
10 inspector, which the staff didn't accept because they said
11 we can't check on it. The staff's feeling is they have got
12 to have that responsibility. They have to have that
13 responsibility and know whether it's done right. Unless they
14 have some way of auditing, they can't accept it.

15 MR. BENDER: The state inspectors must submit
16 their qualifications. That is one of the issues. At one
17 time --

18 DR. CARBON: Let me give the floor to Dave here,
19 and we will try to knock off in about five minutes for
20 lunch.

21 DR. SIESS: Okay. Let's say we'll knock off when
22 Dave gets through.

23 DR. OKRENT: I have a short, easy question. The
24 title in front of all of this is "Urgent Regulatory
25 Management Considerations." I have the impression that the

1429 180

176 16 08

1 single most urgent regulatory management consideration is
2 whether there should be a five-commissioner NRC or an
3 administrator or some third form. I don't think that's
4 addressed in this section.

5 I have two suggestions: one is that the committee
6 decide whether it's going to talk about this and see whether
7 it has an opinion. I think you should seriously consider
8 the matter. You might decide you have no opinion. But I
9 think it's worth some committee discussion myself. It would
10 seem to me that should be an area where we might
11 individually have some thoughts, and if they turned out to
12 be in one direction or another that would be worth knowing.
13 If not, then I think we ought to change the heading and
14 call these "second priority."

15 (Laughter.)

16 MR. BENDER: That's just a matter of perception,
17 Dave. What's most important to you --

18 DR. SIESS: He didn't say "most important to him."
19 I think he said "most urgent in the whole arena." And I
20 have to agree 100 percent. I would like to see us comment
21 on a function --

22 MR. BENDER: I am not convinced you're right.

23 DR. SIESS: I would like to comment on it
24 functionally rather than procedurally. I really don't care
25 much whether there is a five-man commission, an independent

1429 181

76 16 09

p. MM

1 agency, or an administrator within the executive. I guess I
2 am not quite sure of the difference between an executive
3 office, executive department office, and an independent
4 agency. But functionally, I would like to see somebody in
5 charge and somebody -- a single person -- responsible, I
6 think, both in charge and responsible, and leave it to the
7 Congress to work out how they do it.

8 PROF. KERR: How do you get a single person in
9 charge with a commission?

10 DR. SIESS: It has been suggested that you could
11 have a commission chairman with a great deal of authority
12 and additional commissioners that advise and so forth.

13 DR. MARK: You have the chairman be named either
14 Dixie Lee Ray or Stronson.

15 MR. EBERSOLE: In the 7-3 regulatory function you
16 discussed on page 7-7 the general regulatory staff
17 competence. All at once you jump to the I&E capability. I
18 remember when we had a flap with Volgenau about extending
19 the I&E capability beyond what I will call "comparative
20 effort," wherein he had well-defined bases for his
21 inspection and enforcement activities, and we suggested he
22 extend his activity by an order of, say, 20 percent to do
23 engineering assessments in an area not ordinarily evaluated
24 by the ordinary review process; namely, in situ examination
25 of installations on a system-to-system basis, including

1429 182

76 16 10

1 intersystem relationships. That effort, so far as I know,
2 fizzled out to nothing.

3 I think we still must identify the I&E group as
4 currently performing against what they think to be perfectly
5 adequate standards against which they will do their work.
6 But they should consider that they should examine, in an
7 engineering evaluation sense, whether what they see is
8 adequate.

9 MR. BENDER: I might not have put it in the right
10 place, but I think I had something -- a paragraph in there
11 -- plant operation of the I&E staff particularly needs to
12 go forth, and just showed operational activity have not
13 jeopardized the public safety because of design and
14 construction of operating errors.

15 MR. EBERSOLE: I am asking you to look for that,
16 that thing in the battery room.

17 DR. OKRENT: One other kind of a general question
18 that arises out of this. When we spoke with the Rogovin
19 group, one of the questions I threw back at them in order to
20 keep them slightly off balance was were they asking
21 themselves how would the weaknesses that have turned up in
22 the overall regulatory system, including the industry role,
23 how would these weaknesses have been exposed if there had
24 not been a Three Mile Island accident, was there a
25 mechanism? I think it's something we ought to try to

1429 183

76 16 11

py MM

1 address here somehow. It's been hinted at, but maybe we
2 ought to address it more directly.

3 MR. BENDER: We ought not to have to have an
4 accident in order to get staff shaken up.:

5 DR. CARBON: With that point, let's break for
6 lunch.

7 (Whereupon, at 1:30 p.m., the meeting was
8 recessed, to reconvene at 2:30 p.m., this same day.)

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

1429 184

176 17 01

HEE 1

AFTERNOON SESSION

2

(2:30 p.m.)

3

DR. CARBON: Let's begin the afternoon session.

4

Chet?

5

DR. SIESS: Okay, this is nothing but Reg Guide

6

197, correct?

7

DR. CARBON: Correct.

8

DR. SIESS: Gentlemen, you have a copy of Reg

9

Guide 1.97 Revision 2 in Tab 6.3. And you have also been

10

handed out three other things. I think they were left on

11

your chair. One is a collection of comments that have been

12

received from various people including members of the

13

committee and consultants from industry. Another is a

14

revision to page three of the Reg Guide draft, a single

15

sheet. And the other is a draft of the proposed ANS 4.5

16

standard that is referenced in the guide.

17

Now, staff has prepared a revision to Reg Guide

18

1.97, the effective version of which -- and I use the word

19

"effective" advisedly -- is Revision 1. It's the staff's

20

desire that we look at this and then give them our desires

21

regarding it before -- let me put it to you differently.

22

The staff would like our approval to issue this

23

for comment. Usually approval to issue something for

24

comment is given by the Reg Guide Activities Committee, but

25

this is clearly in a different category. It is not out for

1429 185

175 17 02

KapHEE

1 comment. There were copies made available in connection
2 with the meeting, and some comments have been received from
3 the industry and the others I mentioned. Some of these were
4 discussed at the Reg Guide Activities Committee. The
5 subcommittee agreed that detailed comments that we had in
6 writing, or could be submitted in writing, should be pursued
7 by the staff along with the other detailed comments they
8 get during the comment period, and that the main thing we
9 were concerned about now was whether this was in such shape
10 that it could go out for comment so that we could begin to
11 deal with the industry.

12 It is the staff's intent, if this does go out for
13 comment, that they will arrange for a meeting with various
14 owners groups to discuss their concerns and explain what
15 this means.

16 With that introduction, the staff has a
17 presentation. Al Hintze has an excellent summary of the
18 history of this and how they got to this and what the
19 philosophy is. We also have Wenzinger, who has served on
20 the ANS 4.5 Working Group. And then you have a request for
21 oral comments by Mr. Polanski, representing the ANS 4.5
22 Working Group. So I would suggest that you let Mr. Hintze
23 start with his summary.

24 DR. CARBON: Fine. Mr. Hintze.

25 MR. HINTZE: I just wondered, do I need to hold

1429 186

176 17 03

KOPHEE

1 this to make it work?

2 DR. CARBON: I think you do.

3 MR. HINTZE: Our purpose in requesting a review by
4 the ACRS Regulatory Activities Subcommittee was to obtain
5 comments and suggestions on the proposed Revision 2 to
6 Regulatory Guide 1.9, to obtain subcommittee input to
7 whether we were going in the right direction and to obtain
8 concurrence in submitting the guide for public comment. We
9 were subsequently asked to make a presentation to the full
10 committee.

11 Development of Regulatory Guide 1.9,
12 Instrumentation for Light Water Crude Nuclear Power Plants
13 to Assess Plant Conditions During and Following an Accident
14 was begun in July 1973. The preliminary development of the
15 guide was based on a staff-sponsored study at Batelle
16 Columbus Laboratories. The initial draft of the guide
17 contained an extensive list of parameters, approximately 78,
18 to be considered for post-accident monitoring
19 instrumentation.

20 There were strong objections to the specificity
21 which the guide contained by those attending the open
22 session meeting of the ACRS. Upon consideration of these
23 objections, the guide was rewritten to provide guidelines
24 for the selection of post-accident monitoring
25 instrumentation, leaving the actual selection of the

1429 187

176 17 04

K. SHEE

1 instrumentation to the applicant. The guide was
2 subsequently issued for public comment in December 1975.
3 There were a large number of public comments received. The
4 resolution of these comments required about 20 months' time
5 and five ACRS open session meetings.

6 The main problem centered around what was called
7 the "open-endedness" of the objectives of post-accident
8 monitoring and the so-called ambiguity of the requirements.
9 The open-endedness was claimed because no limit was put on
10 the number of accidents which should be considered in
11 determining accident monitoring instrumentation. It was the
12 staff's contention that accident monitoring should be
13 prepared for any eventuality.

14 After several modifications, the guide was finally
15 issued as an effective guide in August 1977, with one
16 additional position pertaining to core parameters, to be
17 provided with high level measurement capability. This new
18 position resulted from addressing a specific concern of the
19 ACRS outlined in their letter of August 17, 1976. The
20 letter stated that the committee believed that a relatively
21 limited number of primary indicators -- pressure,
22 temperature, radiation, et cetera -- should have instrument
23 ranges which go beyond the Class 8 accidents, and that these
24 instruments should meet the various environmental
25 qualification criteria cited as practical.

1429 188

176 17 05

K. HEE

1 After Regulatory Guide 1.9 was issued, the
2 applicants were reluctant to implement the guide because
3 they felt more definitive guidance was needed to define
4 acceptable means of compliance. The applicants also
5 objected very strongly to the requirement for the high level
6 measurements. The reasons given for not accepting the
7 requirements for the high level measurements were that it
8 was likened to the camel's nose in the tent -- first they
9 would be required to provide the measurements for high level
10 conditions; the next step would be a requirement to design
11 plants to be able to withstand those conditions.

12 They contended that there was nothing in the
13 regulations that required consideration beyond the maximum
14 limits of Class 8 conditions. Subsequent to the issuance of
15 Regulatory Guide 1.97 in August 1977, Task Action Plan A-34
16 was initiated to develop guidance to help applicants,
17 licensees and staff reviewers in implementing the guide.
18 The A-34 Task Force was preparing to issue its report about
19 the time the incident at Three Mile Island occurred in March
20 of this year.

21 The report was not finalized, however, because it
22 was deemed advisable to evaluate TMI-2 before formalizing a
23 staff position. The preliminary report did include a
24 minimum list of variables, 36 for PWRs and 32 for BWRs,
25 which should be included for accident monitoring.

1429 189

175 17 06

KAPHEE

1 On July 12, 1979, an effort was initiated to
2 revise Regulatory Guide 1.97, which was to include a basic
3 list of parameters to be monitored. Concurrently, ANS 4
4 initiated the Standards Working Group to develop an ANSI
5 standard on accident monitoring. The staff task force was
6 assigned to work with the ANS 4 Working Group to develop the
7 standard, with a commitment to endorse the standard with the
8 revision of Regulatory Guide 1.9, if it could be done in an
9 acceptable manner.

10 A very short self-imposing schedule was laid out.
11 The draft standard included as part of the proposed Revision
12 2 to Regulatory Guide 1.97 is the first released draft
13 beyond the purview of the ANS committee and the NRC staff.
14 Admittedly it is very preliminary and requires more effort.
15 However, its developments were sought by public comment. It
16 was thought that the development time could be shortened by
17 concurrent public review and comment in conjunction with the
18 guide.

19 During the comment period, effort by the ANS 4
20 Working Group would continue. The staff effort in
21 developing the endorsing regulatory guide would work closely
22 with the ANS 4 Working Group in determining the plant
23 variables that should be monitored.

24 The draft ANSI standard and the regulatory guide
25 use a systematic approach. Five variable types are

1429 190

176 17 07

K-HEE

1 identified. The first type deals with operator manual
2 actions during accidents, which are identified in the plant
3 safety analysis, and are anticipated or pre-planned. These
4 variables are defined as those variables that provide
5 information to indicate information needed for pre-planned
6 manual action. They are designated as Type A.

7 The second type addresses whether the plant safety
8 functions are being accomplished. The functions of concern
9 are reactivity control, reactor core cooling, reactor
10 coolant system pressure control, primary containment
11 pressure control and radioactive effluent control. These
12 variables are defined as those variables that provide
13 information to indicate whether plant safety functions are
14 being accomplished, and are designated as Type B.

15 The third type deals with the conditions of the
16 barriers to fission product release, that is, fuel cladding,
17 primary coolant pressure boundary and containment. The
18 information desired is: are the barriers being threatened
19 by an extreme condition? Or have they already been reached?
20 These variables are defined as those variables that provide
21 information to indicate the potential for, or actual breach
22 of, the barriers division product release, and they are
23 designated as Type C.

24 The fourth type deals with variables that will
25 provide the operator with information as to whether the

1429 191

176 17 08

kapHEE

1 individual plant safety systems are functioning, so that he
2 can make decisions as to their use. These variables are
3 defined as those variables that provide information to
4 indicate the status and functioning of individual safety
5 systems, and they're designated as Type D.

6 The fifth type are those that provide in-depth
7 information and they are designated as Type E.

8 The five classes are not mutually exclusive, in
9 that a given variable or instrument may be included in one
10 or more types, as well as for normal power plant operation.
11 And it should be stated that wherever a variable is included
12 in one or more types or for any other safety function, the
13 most stringent requirement applies. The guide contains two
14 lists of variables, one for PWRs and one for BWRs. The list
15 took into consideration the list of variables developed by
16 the draft report of Task Action Plan A-34 and the TMI
17 Lessons Learned Task Force recommendations. It also
18 includes suggestions by the NRC staff and the industry
19 representatives who were invited to comment on the
20 preliminary draft of the ANS 4 standard.

21 We might mention that the list contained in the
22 regulatory guide used the aforementioned procedure to come
23 up with the final listing. As is often the case when an
24 industry standard is endorsed by a regulatory guide, there
25 are some exceptions taken. The principal questions and

1429 192

176 17 09

KAPHEE

1 differences between the NRC staff position and the ANS 4
2 Working Group position are as follows:

3 Question one: should the standard address the
4 monitoring concerns of only the control room operator, or
5 should it include all accident monitoring requirements
6 required by the plant operator or licensee? It is the
7 staff's position that the standard should cover all accident
8 monitoring requirements for the plant. Most of them will be
9 the concern of the control room operator.

10 However, there are other measurements which are
11 necessary for protecting the health and safety of the
12 public. These should also be addressed. Hence, position one
13 was included in the regulatory guide.

14 Question two: should the standard include
15 measurements to indicate an approach to breach of the fuel
16 cladding and the primary coolant system pressure boundary in
17 addition to the approach to breach of the containment? The
18 standard includes a requirement to measure the actual breach
19 of the fuel cladding, the primary coolant pressure boundary
20 and the containment. However, it only includes the
21 potential for breach of the containment.

22 It is the staff's position that the standard
23 should also include a requirement to measure conditions that
24 would indicate an approach to breach of the fuel cladding
25 and the primary coolant pressure boundary. Thus, possible

1429 193

176 17 10

KASHHEE 1 mitigating actions can be taken to prevent a breach. Hence,
2 position two was included in the guide.

3 Question three: should the standard include
4 monitoring requirements for all design basis events requiring
5 pre-planned manual action, or just those defined as actions
6 which may occur during the lifetime of a plant, excluding
7 those expected to occur during a calendar year.

8 It is the staff's position that in order to have
9 an integrated system, all design basis events should be
10 included. Hence, position three was included in the guide.

11 Question four: should Type B variables be
12 included in accident monitoring or are they less important
13 and should not be included? We might mention again that
14 Type B are those variables that provide information to
15 indicate performance of individual safety systems. It is
16 the staff's position that for the operator to take
17 mitigating actions, he must know what systems are
18 functioning and which failed. Therefore, Type B is
19 important to accident monitoring; hence, position four was
20 included.

21 Question five: should the standard include a
22 specific list of accident monitoring variables? It was the
23 staff's position that such a list should be provided;
24 hence, Tables 2 and 3 were included in the guide.

25 I might mention that the standard does give

1429 194

176 17 11

KPOHEE

1 recommendations or suggestions for Types A and B. If we
2 make a comparison between the guide and the standard on
3 those two types, the standard requires for PWRs 11 -- or at
4 least suggests 11 parameters for Type A and B. The guide
5 has 17. For BWRs, the standard suggests 12; the guide has
6 17.

7
8 The standard requires that the length of time for
9 phase two should be 100 days, unless a shorter time could be
10 justified. The standard defines phase two as that period of
11 the accident between when the plant is brought under control
12 and when access can be obtained to areas requiring
13 inspection, repair or replacement. The staff position is
14 that in light of TMI-2, 200 days is more appropriate.
15 Hence, position nine was included in the guide.

16 Since we transmitted the guide to the ACRS in
17 October, on October 16th, we have received several sets of
18 comments from ACRS members and consultants. Some written
19 comments were handed to us at the Wednesday meeting. These
20 written comments contain a number of detailed comments on
21 the guide. With the agreement of the ACRS Regulatory
22 Activities Subcommittee we will address each commentor's
23 input during the public comment period. We will, however,
24 try to respond to comments given here today.

25 Our principal aim is to obtain your input on the
approach we are taking and to get concurrence in sending the

1429 195

176 17 12

KapHEE

1 guide out for public comment. The purpose of this comment
2 period will be to solicit input on the technical basis for
3 selecting accident monitoring variables, the proposed
4 minimum list of variables to be monitored and the design
5 criteria to be applied to the instruments. The guide was
6 written for forward thinking.

7 During the public comment period we intend to meet
8 with the various owners groups to obtain input on
9 backfitting recommendations and impact which will, at a
10 future meeting, be presented to the ACRS and the RRRC.

11 That concludes my presentation.

12 DR. CARBON: Thank you, Mr. Hintze. Dade?

13 DR. MOELLER: There is a Reg Guide 1.97, so to
14 speak, that is out now. This is a revision. Are the
15 applicants or the licensees supposed to continue with the
16 recommendations in the existing reg guide?

17 MR. BENERAYA: Mr. Moeller, the reg guide --

18 DR. CARBON: Could you identify?

19 MR. BENERAYA: Vic Beneraya, Operations Systems
20 Branch. The Reg Guide 1.97 must be -- regards what we have
21 now and what we're concerned about is who will have the
22 rules. And we will discuss it with every one of you, and
23 then we will decide which road to take.

24 DR. MOELLER: So nothing much will be done until
25 this new version is revised and approved?

1429.196

kap/MM

1 siting, the public will be adequately protected. The NRC
2 review practice has been one which separates safety from
3 non-safety systems and addresses only the safety systems.

4 "The initial intent of the separation philosophy
5 was probably to avoid conflict between demands from normal
6 operating modes and those peculiar to safety functions. As
7 now applied, the philosophy is also used to distinguish
8 between safety-related and non-safety related functions with
9 respect to their quality and reliability.

10 "An advantage of a properly implemented separation
11 philosophy is that safety-related functions requiring very
12 high reliability can be designed specifically to meet their
13 requirements without imposing these costly and sometimes
14 impractical requirements on those non-safety related
15 features which require less rigorous design.

16 "A disadvantage of the separation philosophy is
17 that it cannot be implemented perfectly and is therefore
18 sometimes arbitrary and artificial. For example, a control
19 system and shutdown protection system should be considered
20 in an integrated control system because they are
21 interactive.

22 "As reactor licensing has broadened in scope, the
23 separation philosophy has permeated the design process, but
24 not with consistent logic. One important example of this
25 type is decay heat removal. In what is perceived as an

1429 197

KASHIEE 1 MR. BENERAYA: I would think that we will hope to
2 get the revisions or the backfitting conditions pretty soon
3 and pretty fast implemented once we get going. Once we get
4 the approval of the ACRS.

5 DR. SIESS: A limited amount of implementation of
6 the high level instruments will be done under the Lessons
7 Learned recommendations.

8 MR. BENERAYA: Yes, sir, those have already gone
9 out and they are being implemented at this time.

10 DR. MOELLER: Have any surveys been conducted of
11 licensees operating plants, to see what impact the existing
12 reg guide has had?

13 MR. BENERAYA: We have had some unofficial
14 meetings with some of the engineers to get a feeling and we
15 are looking into it. And the first reading is that it might
16 double the price.

17 DR. SHEWMON: Double the price of what? The whole
18 plant?

19 MR. BENERAYA: For instrumentation, the cost of
20 instrumentation.

21 DR. SHEWMON: Instrumentation only for one guide,
22 1.97, 1st and 2nd Revisions or all instrumentation in the
23 plant?

24 MR. BENERAYA: 1.97 one.

25 DR. CARBON: What is the magnitude of that?

176 17 14

W. HEE

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14
- 15
- 16
- 17
- 18
- 19
- 20
- 21
- 22
- 23
- 24
- 25

MR. BENERAYA: I don't know that.

MR. EBERSOLE: Is that a real price, in your opinion, or a synthesized price to discourage the installation of this equipment?

MR. BENERAYA: From what we understand from the industry, it is not a prohibitive amount.

1429 199

10-12

175 13 01

SHEE

1 DR. SHEWMON: What percentage of what you're
2 requiring here is indeed established material, equipment
3 they can buy off the shelf? I notice one has a 10 to the 12
4 range on it, which is impressive to a non-instruments man.
5 It may seem trivial to you. One of the comments earlier was
6 that the staff had picked upper limits on their range which
7 were beyond the capability of what you could buy off the
8 shelf.

9 MR. BENERAYA: No, sir. The only item that we
10 have that is not developed yet is the level in the reactors
11 or pressurizers. The other equipment, if it is not
12 available in the market right now, it can readily be built
13 with the information knowledge we have.

14 DR. SHEWMON: That is your judgment? Or the ANS'
15 judgment?

16 MR. BENERAYA: The people we talked to in the
17 industry.

18 DR. SHEWMON: Now the ANS Committee on this, you
19 have been working with them over the last couple of months.
20 Is that right?

21 MR. WENGINGER: My name is Ed Wenginger. I'm with
22 the Reactor Systems Branch in the Office of Standards
23 Development. We asked the question of availability of
24 several industry organizations and have only gotten
25 fragmented answers. If I can summarize the answers, I think

1429 200

175 18 02

IEEE 1 the biggest problem is not with the availability of
2 instruments that provide the required range, although I
3 think I might let somebody else answer with regard to
4 radiation monitoring, but in the area of process
5 instrumentation other than radiation monitors, the
6 instruments are generally available, again with the
7 exception of the level sensors for the vessel.

8 The problem with with regard to the qualification
9 for environmental conditions and seismic events, and in a
10 number of cases, the instruments, although available, would
11 not be off-the-shelf available or already qualified in
12 accordance with such standards IEEE 323 and 344 and that
13 there would be some testing as a minimum requirement in
14 order to make instruments available for those
15 qualifications.

16 DR. SHEWMON: Now part of the reason you had
17 fragmented answers is the very short time constants you
18 asked for responses on.

19 MR. WENGINER: Yes, sir. That's correct.

20 DR. SHEWMON: But is your decision to -- instead
21 of let these Committees study it at what they feel is a
22 doable pace, to go ahead and send out the Reg Guide before
23 you have their comments and try to do three things at once.

24 MR. WENGINER: The purpose right now is to go out
25 and obtain their comments. That is what we would like to

1429 201

macHEE 1 do.

2 DR. SHEWMON: If you obtain comments on getting
3 codes at a couple of different times --

4 MR. BENERAYA: May I add something here, please?
5 We did check with an architect engineer, a big one, and we
6 asked him if there was a single instrument there that could
7 not be provided right away, and the answer was, "No,
8 everything can be available."

9 DR. SHEWMON: No, I'm not on that subject
10 anymore. You answered that once or twice for me, and I'll
11 take that. I guess this is maybe more to check as to
12 whether he feels that, indeed, the approach being taken by
13 the staff this time is the best way to get industrial
14 participation in the development of what is a reasonable and
15 doable guide.

16 DR. SIESS: I don't usually worry myself about
17 that. If it is a Reg Guide and it is approved, it will be
18 done. What they have done is to take Position C-1 and C-2
19 of the previous guide -- and by "they" I guess I mean
20 everybody from Batelle through the ANS working group -- and
21 try to make those studies that were recommended there to
22 decide what implementation is needed and then to actually
23 list them.

24 You see the original guide simply said they should
25 study all the accidents in Chapter 15 and try to picture

175 18 04

HEE

1 scenarios in their course and decide what instrumentation
2 was needed to follow them.

3 Now what they have done now, somebody has gone
4 through that process at some level, and actually at the
5 working group they went through five phases -- the accident
6 and several post-accident phases -- decided what instruments
7 were needed and they are now listed.

8 So the implementation is a lot easier of this in
9 one sense. One of the problems with the implementation
10 before was that nobody when they said they didn't know what
11 the guidelines were for making those analyses, and those
12 have now been made. Now it is just a question of what
13 instruments. There are still a lot of detail questions left
14 to be worked out, but I don't see how they can be put in the
15 Reg Guide, at least not now.

16 DR. SHEWMON: Well, let me ask one more detailed
17 question, then, and I will quit.

18 The way I heard what you read was, you wanted
19 instrumentation to approach, to indicate the approach to
20 breach of cladding. What do you propose to monitor for
21 that?

22 MR. BENERAYA: In this case, we had the
23 thermocouples.

24 DR. SHEWMON: Which presumably will read above 750
25 degrees Fahrenheit?

1429 203

MACHEE

1 MR. BENERAYA: Yes, sir. We have the pressure and
2 temperatures of the system, so that we can start looking at
3 that as we are getting in trouble, and the level of the
4 boiler. I think that is about all right now.

5 DR. SHEWMON: Now do they have to integrate these
6 into a system which will read out in the control room a
7 probability of core breach or percentage of weight of core
8 breach? Or what is it you are requiring for them?

9 MR. BENERAYA: No single instrument is going to
10 give the whole story, sir, and we don't claim that. What we
11 are saying he is going to have enough information so that
12 the people that are in the control room and behind his
13 support can start analyzing and find out where it is going
14 and whether they are getting in trouble.

15 DR. SHEWMON: I guess I just wouldn't take an
16 approach or a percentage of the weight of core breach as
17 being the most useful thing for an operator who wanted to
18 avoid a bad accident.

19 MR. BENERAYA: You start taking samples from the
20 water, also.

21 DR. SHEWMON: Well that won't tell him how close
22 he is to making his breach. And what you said was approach
23 to breach.

24 MR. BENERAYA: Yes, sir. The temperatures would
25 tell him that.

1429 204

1 75 18 06

mcsHEE

1 DR. SHEWMON: I guess, Mr. Chairman, I just have
2 the impression that things have been done with such haste
3 that I have concern about this being the best way to sort
4 things out, but maybe it is.

5 DR. SIESS: I don't quite know what you mean by
6 "haste." The ANS 4-5 Working Group has been working on this
7 for how long?

8 MR. HINTZE: Since July.

9 DR. SHEWMON: Professors don't work too much in
10 the summer. Don't you think those guys should go back and
11 do the surveys they want to? They've yanked them out before
12 they've had a chance to answer them.

13 DR. SIESS: I don't think many professors were
14 working on that, were they?

15 MR. BENERAYA: No.

16 VOICE: Monty Schultz and John Posten are two that
17 were involved as well as a fellow from Ohio State.

18 MR. WENGINER: So you may be referring to some
19 work we asked Ohio State to do for us. Is that what you're
20 referring to?

21 DR. SHEWMON: There was a committee in which my
22 impression -- Miller was asked to chair.

23 MR. WENGINER: Yes. We asked that committee if
24 they would be able to put together a list of instrumentation
25 availability. We gave them our list of instruments and

1429 205

175 18 07

HEE

1 said, "Would you please not comment on the list." That is
2 not what we asked them to do, but "Would you please tell us
3 which of these instruments are available with which
4 qualifications", and so on. We did not explicitly for their
5 comment on whether this was the right list, although we
6 said, "If you wish to do that, we'll be glad to accept those
7 comments also."

8 DR. SHEWMON: The last thing I heard, you're time
9 constants were so unreasonable that they, in a sense, came
10 back and said, no.

11 MR. WENGINGER: No. They, in fact, sent us a list
12 of what was available. At the time, they had it available.
13 They gave us a fairly reasonable response. In the area of
14 radiation monitors, the list was reasonably complete. In
15 the area of process instrumentation, the list was not too
16 complete, and we did the work that Victor Beneraya referred
17 to in inquiring of the architect engineers.

18 DR. SHEWMON: I'm not prepared to debate this
19 subject, but I still have the feeling that it has been
20 prepared with such haste that we're making extra work for
21 ourselves.

22 MR. HINTZE: If there's a complaint from that
23 work, that's not the ANS group. That is the ASI group that
24 we asked to determine if we were asking the impossible or
25 whether it was practical to ask for the instruments we were

1429 206

176 18 08

MACHEE

1 asking for. They were willing to give us a college-try at
2 answering that in a very short period of time. If they had
3 complaint, they did not relay that on to us.

4 DR. MOELLER: I have question which I'd like to
5 ask of the staff, which Chet could help me with.

6 I understand that certain key pieces of equipment
7 to follow the course of an accident, certain key pieces, are
8 being required through the Lessons Learned approach. Now
9 are you happy with the instrumentation required there versus
10 the instrumentation that is required in Reg Guide 1.97,
11 which will be delayed until it is finished?

12 DR. SIESS: What they required from the Lessons
13 Learned, if I recall, were four high level instruments and
14 C-3 of Reg Guide 1.97 Revision 1: coolant pressure,
15 containment pressure, radiation inside containment, those
16 three. Now the fourth was radiation at identified release
17 points. I don't believe that is being required, but that is
18 part of this.

19 MR. BENERAYA: Hydrogen concentration.

20 DR. SIESS: Well that was in Reg Guide 1.97,
21 hydrogen concentration. But the main three -- pick the ones
22 out of Position C-3. What the Reg Guide said before was to
23 make all these analyses and decide what you need. It said,
24 however, we want these -- no matter what you come up with,
25 and those were C-3, and those have been the Lessons Learned.

1429 207

176 18 09

PACHEE

1 So that's no problem to me.

2 DR. MOELLER: All right. That is helpful for me.

3 Thank you.

4 DR. CARBON: Chet, do you have concerns on haste
5 and speed here, as Paul is expressing?

6 DR. SIESS: No, I'm not concerned about the speed
7 with which it is done. I have usually complained the other
8 way, and we shouldn't confuse speed with writing or speed
9 with implementing. It's still going to take some time to
10 get it implemented. When it goes out for comments, there
11 are going to be a lot of comments. I'm sure the Working
12 Group does not agree with what the staff has done, and we
13 will hear, I think, from Mr. Polanski on that. But the
14 sooner we can get it out and get the comments and get them
15 cleared up and the staff explains this, the better. And
16 then they can start implementing it.

17 DR. CARBON: Is this the appropriate time to have
18 Mr. Polanski speak?

19 DR. OKRENT: Can I ask one or two questions?
20 There is a reference to gamma ray spectrum measurement.
21 Could you tell me a little bit -- a minute's worth -- about
22 what it is supposed to be able to do, and what it is not
23 able to do?

24 MR. STODDARD: Phil Stoddard, NRC staff. The
25 instrument you are referring to is a portable instrument

1429 208

176 18 10

macHEE

1 designed for use offsite in the event of an accident, which
2 would essentially run everybody out of the site. It is
3 designed for taking air samples offsite and getting a kind
4 of rough spectrum analysis. It is not designed for use in
5 containment or any of the high level samples. The 100
6 channel battery-operated spectrometer, it is not a high
7 solution device at all.

8 DR. OKRENT: Say there would be no gamma ray
9 spectrum capability for what is inside the containment if
10 you have a substantial release? Is that what you are
11 telling me?

12 MR. STODDARD: That is essentially correct. The
13 Lessons Learned Task Force does require the capability for
14 taking primary coolant samples or containment air samples
15 and for measurement of those samples on site by gamma
16 spectrum analysis. However, the analytical equipment is not
17 within the containment, and it would be somewhat remote from
18 the containment in a raw shield background area.

19 DR. OKRENT: Well, I don't think I want the
20 analytical equipment in the containment.

21 PROFESSOR KERR: We agree.

22 MR. STODDARD: I believe some of the comments
23 addressed being able to identify this equipment, and there
24 is no provision for any direct measurement of that sort.

25 DR. OKRENT: But I am interested in knowing what

1429 209

176 18 11

MSHHEE 1 your ability would be to measure whether there is one level
2 or another of cesium, and that is a fine isotope in
3 containment. Could it be done? How long would it take, and
4 what would it take to do it continuously? Or is that
5 impossible?

6 MR. STODDARD: To do that sort of thing
7 continuously is impossible, as I understand, in the state of
8 the art.

9 DR. OKRENT: When I say, like, you know, every
10 minute as contrasted to every hour. Let me specify that as
11 a definition of continuous.

12 MR. STODDARD: No, it would be on the order of
13 perhaps once an hour, or perhaps more than that. It
14 requires taking a sample at a remote sampling for an
15 external to containment, packaging that sample, transferring
16 it to what amounts to a hot lab, treating that sample
17 perhaps by dilution, and then running a spectrum analysis on
18 it. Your requirement in the Lesson Learned Task Force was
19 to be able to take a sample in one hour and then analyze
20 that sample within two hours.

21 PROFESSOR KERR: Are you talking about analyzing a
22 sample of water?

23 MR. STODDARD: Either of containment water or of
24 containment air. They are both covered in the same
25 requirement under Lessons Learned.

1429 210

176 18 12

SHEE

1 MR. GUPPY: My name is Gerald Guppy of the Nuclear
2 Regulatory Commission Policies and Standards Office,
3 previous experience in the Navy using 1000 channel analyzers
4 and 100 channel analyzers. It would take between an hour
5 and two hours to get the information that you want. That is
6 based on low level background. Dilution with high level, I
7 don't know how long it would take.

8 DR. OKRENT: And what is it, that it takes an
9 hour, in your experience?

10 MR. GUPPY: From the sampling time to the point
11 that you get an answer out as to what you have would take
12 between one and two hours.

13 PROFESSOR KERR: Aren't you talking about rather
14 low levels of isotopes. If you had to do long term
15 counting, what you say is true, but if you have a very high
16 level of cesium, I hope that you would have it calibrated.

17 MR. GUPPY: No, you shouldn't have to do. As I
18 say, I haven't any experience with high level so I don't
19 know what the procedures are when you're counting the high
20 level.

21 DR. OKRENT: I would suggest that you are
22 answering a different question than the one in which I'm
23 interested. I am not going to propose that you hold up the
24 Reg Guide for this purpose, but I would like to suggest that
25 the staff look at what it would take to obtain on what I

1429 211

176 18 13

SHEE

1 would call a semi-continuous basis an estimate -- two, five,
2 or ten percent -- of the amount of cesium, as a good
3 example, and you could add in one or two other existing
4 isotopes -- what it would take to do that, only when you
5 have a substantial amount. I really don't care if it is a
6 low level.

7 PROFESSOR KERR: If continuous means once a
8 minute, does semi-continuous mean once an hour?

9 DR. OKRENT: Let me tell you what I have in mind,
10 and I think you will perhaps judge that once an hour is
11 probably not quite often enough for the purpose.

12 Should you have a substantial amount of activity
13 in the containment, and at the moment, you have only a
14 single gross reading, but you don't really know if this is
15 primarily noble gases; noble gases and iodine; or noble
16 gases, iodine, and cesium -- and I won't go further down the
17 chain -- if you don't know how this is distributed among
18 those, and then should you drop, for anomalous reasons, in
19 containment pressure, suggesting perhaps it opened up, it
20 would be convenient if you had an idea of what had been in
21 the containment when the pressure was high so you could
22 better guide offsite actions because you might, indeed, get
23 rather different information, and the instructions might be
24 different depending on the distribution of the same amount
25 of activity among those isotopes.

1429 212

175 18 14

MOSHEE

1 PROFESSOR KERR: I agree with you wholeheartedly.
2 It seems to me, once a minute -- I think it might be a
3 mistake if you required it that frequently. I don't think
4 you could do it once every fifteen minutes or once every
5 half an hour, maybe.

6 MR. GUPPY: That is probably feasible. I think
7 your limiting factor with high levels is going to be the
8 time to get from drawing your sample and getting to Point A
9 to B and in the analyzation.

10 DR. OKRENT: Again, I think if you stop and think
11 about the objective, one can work back and get an estimate
12 of what is enough accuracy, and you don't look for more.
13 What is the range in which you're interested, and what is
14 the range where you don't care, as it were? And, in fact,
15 you might decide that you can get enough information in the
16 previous thirty minutes, as it were, to have guided you or
17 something. I don't want to guess. I will guess once an
18 hour is not likely to be adequate under all of these
19 scenarios of interest. I will just speculate that way. And
20 I don't know, if you decided you wanted it once every ten
21 minutes, you might be able to automate some feature. It
22 might be handy to be automated anyway if this is the thing
23 you are interested in.

24 Well, let me leave it as a thought for both the
25 staff and the Working Group, and unless this is outside the

1429 213

1/16 18 15

1 range that the Working Group like to think in.

2 DR. CARBON: Chet, is this an appropriate time for
3 Mr. Polanski?

4 DR. SIESS: I think so.

5 DR. CARBON: About how long do you anticipate
6 taking, Mr. Polanski?

7 MR. POLANSKI: About ten minutes.

8 PROFESSOR KERR: Is he going to tell us what AMI
9 is? I presume he will.

10 MR. POLANSKI: Sure. My name is Xavier Polanski.
11 I work for Commonwealth Edison, but I'm here to represent
12 ANS 4.5, which is the Working Group which prepared the
13 standard on which this Reg Guide is based. I am speaking
14 today because the Working Group doesn't think that the Reg
15 Guide in the form it's written is the proper approach to
16 accident monitoring objectives.

17 But before I talk about our view of accident
18 monitoring and the philosophy we used, I would like to
19 mention what we've been doing and what the progress of the
20 standard is going to be.

21 As Al Hintze of the NRC staff mentioned, we
22 started work on the standard in July. By the middle of
23 September, we had a complete draft. Before the standard is
24 issued officially, it has to pass votes by two bodies -- ANS
25 4 and NIPSCO. It has been balloted by ANS 4, but not

1429 214

175 18 16

HEE

1 successfully. We are resolving those comments as best we
 2 can right now. And considering the time that we need for
 3 review and comment in balloting by NIPSCO, we expect a final
 4 approved standard in April or May of 1980.

5 DR. MOELLER: Excuse me, now. What ANS 4.5 is
 6 doing is essentially covering the same ground that Reg Guide
 7 1.91 would cover?

8
 9
 10
 11
 12
 13
 14
 15
 16
 17
 18
 19
 20
 21
 22
 23
 24
 25

do
 -
 9

1429 215

CR 8176

HEER

t-19 mte 1

1 MR. POLANSKI: That is correct. The intent was to
2 prepare an industry standard that would be the basis for a
3 regulatory guide. Now, as we took a look at accident monitor-
4 ing, we had the following objectives in mind.

5 (Slide.)

6 AMI became our abbreviation for accident monitoring
7 instrumentation, and post-accident monitoring has been used
8 before, but we decided this name was better. So this is what
9 AMI stands for.

10 DR. CARBON: Mr. Polanski, would you use a pointer
11 and stand back.

12 MR. POLANSKI: Sure.

13 We think there are three important objectives for
14 accident monitoring instruments:

15 The first, of course, is that we have to be able to
16 characterize the status of the plant, and that means that we
17 have all of the instruments we need, everything that's neces-
18 sary.

19 The second requirement is that the information be
20 clear and understandable, and we felt that human engineering
21 then demands that we provide the minimum instrument set, that
22 which is sufficient. So we need everything which is necessary,
23 but nothing more.

24 And it was with this point of view that we approached
25 this standard of making sure we had what we needed, but only

1 what we needed, so that it would be easiest to use and easiest
2 to install.

3 The other requirement, for it to be clear and
4 understandable, is that of being uniquely identified. And then
5 the third requirement on the instrumentation must be that it
6 is there and available when it is needed.

7 Now, with those objectives in mind, we set out to
8 write the standard.

9 (Slide.)

10 And in order to make sure that we provide what is
11 necessary and sufficient, we took a very systematic approach
12 to the whole accident monitoring subject. The first thing we
13 do in the standard is to define three accident phases, and
14 those are just chronological periods in the course of the
15 accident and post-accident period.

16 The second thing we do is define the accident
17 monitoring functions to be performed. And from this comes the
18 four instrument types or categories earlier mentioned by
19 Al Hintze. We have four in the standard and he has five in
20 the reg guide.

21 And the requirements and qualifications for each
22 of those types of instruments are differing because of their
23 different functions.

24 The third thing we did is to provide for the designer
25 a procedure for selecting the variables he would monitor for

1 the accident and post-accident period. We told him what kind
2 of an analysis to do and gave him guidance in picking the
3 variables.

4 The fourth thing is to put some requirements on
5 the qualification criteria to be applied to the variables,
6 so such things as environmental and seismic qualification,
7 accuracy, display, format, and that kind of thing, are in the
8 standard.

9 And with those four things in the standard, it is
10 our intent that the designer pick the variables and the
11 instruments for his particular plant. We specifically wanted
12 to avoid just writing a checklist so that a designer would
13 figure he had gotten one of each of those and he could forget
14 about the problem.

15 We want the selection of the instruments to accomplish
16 the function to be tied to the design of the plant and the
17 overall safety picture of the plant.

18 (Slide.)

19 Now, an important part of that approach to the
20 problem is the definition of the accident monitoring functions
21 and the four variable types.

22 Type A are the instruments that the operator needs
23 for preplanned manual action, and these are instruments already
24 in the plant. They are safety grade. They are required by
25 the existing safety analysis reports for the postulated

1 accidents in Chapter 15 of the safety analysis report.

2 The second type of variables are those which monitor
3 what we feel are the five critical safety functions for the
4 plant. These are the instruments we propose to cover the
5 operator for those unexpected circumstances and unexpected
6 chains of events.

7 The trouble with monitoring for that whole big set
8 that is the unknown is in limiting it. And so our approach
9 was to say: Well, let's look at these basic safety functions,
10 and if the operator knows that he is accomplishing those,
11 then that is what really matters. And those functions are:
12 controlled reactivity, keeping the core cool, keeping the
13 primary system intact and the containment intact, and keeping
14 track of radioactive effluents.

15 There is a third type of variable we identified
16 and those are those monitoring the three barriers to fission
17 product release, monitoring the fuel and the coolant system
18 and the containment.

19 We identified a fourth type of variable, Type D
20 variables, and those are instruments monitoring the specific
21 performance parameters of specific safety systems, such things
22 as high pressure core spray pump flow. We did not set criteria
23 for those variables, because we felt that they are properly
24 decided when the safety system is designed, should be covered
25 by such standards as IEEE-603.

1 But another reason why we did not deal with them
2 is because we were concentrating on what we felt was essential
3 to safety, and the point of our standard was principally to
4 deal with what is needed, absolutely needed, in the post-
5 accident period.

6 MR. EBERSOLE: May I ask a question? In the point,
7 primary containment breach, the general picture I get from that
8 is a primary containment breach anywhere with some predesigned
9 source term inside the containment to deal with. But in
10 reality, a primary containment breach may well be within the
11 region where penetrations exist.

12 MR. POLANSKI: That's right.

13 MR. EBERSOLE: And these penetrations characteristic-
14 ally are within the boundary of the auxiliary building and
15 face directly into the equipment regions and into the control
16 room regions. If a breach should occur in there, you do not
17 have the benefit of refusion and dispersion, an aspect of
18 getting rid of the fission products. Rather, you have a concen-
19 tration of effluents of all kinds in a critically needed
20 region, and you expect to run on with continued mitigation
21 equipment.

22 As you do this sort of study, are you looking at the
23 potential for running people away, even from the control room,
24 under the present design considerations, which don't allow for
25 these high levels of radioactivity, but rather use the old

1 design basis within which the control room is submerged.

2 MR. POLANSKI: I guess that is a case that I'm not
3 sure anybody is really prepared to deal with.

4 MR. EBERSOLE: But I'm really trying to afford an
5 environment wherein you're going to read all of this fine
6 instrumentation you are providing.

7 MR. POLANSKI: Right. I guess the answer is that
8 that is probably one of the cases that is awfully hard to cover
9 unless you put the control room 15 miles away.

10 MR. EBERSOLE: Well, certainly your efforts are in
11 vain unless you say this instrumentation readout will be within
12 a region of safety.

13 MR. POLANSKI: Yes, except, first of all, there is
14 no guarantee you will have the problem you highlighted.

15 DR. SIESS: The standard says this shall be in the
16 control room.

17 MR. EBERSOLE: Well, you certainly have to have a
18 place to put the instruments.

19 DR. SIESS: Do you think the staff should say that
20 they belong other than in the control room?

21 MR. EBERSOLE: I don't know where they belong. They
22 may belong ten miles away.

23 DR. SIESS: That is an interesting point. Has the
24 staff thought about that?

25 MR. EBERSOLE: They may belong in the control room

1 if they can be made to survive in the core area, along with
2 the people who must read them and do things.

3 DR. SIESS: Well, they have got to survive the
4 environment.

5 MR. POLANSKI: But part of the answer is, if you
6 can't be there to read the instruments, you can't be there to
7 do anything about it.

8 MR. EBERSOLE: So what's the use?

9 MR. POLANSKI: So you put your control room 15 miles
10 away. Now what do you do? You aren't going to start any
11 pumps.

12 MR. EBERSOLE: That means you must multiplex the functions
13 to that distance.

14 MR. BENDER: It seems to me the points you're
15 making would be valid, but I don't understand the concept.
16 Most accidents are not going to require control room evacuation.

17 MR. EBERSOLE: Well, in the fraction which leads to
18 control room evacuation, you might as well not even bother
19 to put the instruments ther.

20 MR. BENDER: Well, that fraction of that fraction,
21 if the control room is contaminated, of course, you can't do
22 anything, and that might be the ultimate case where we have
23 to consider that we have to abandon the system.

24 MR. EBERSOLE: But it's clear within the spectrum
25 of things he's adding is radioactivity monitoring at high

1 levels.

2 PROF. KERR: Well, Jess, it seems to me that if this
3 occurred, at least you would know that you had a serious
4 accident.

5 MR. EBERSOLE: You could then run if you could get
6 out.

7 DR. SIESS: Let me ask a related question. We do
8 have some control capability outside the control room.

9 MR. EBERSOLE: That is not shielded or protected.

10 DR. SIESS: But it is outside the control room,
11 because presumably the control room would not be habitable.
12 Has the staff considered whether any of these instruments
13 should be provided at that location?

14 MR. HINTZE: Yes. It is included in the revision.

15 MR. EBERSOLE: Would that be any of the radioactivity
16 monitoring measurements?

17 MR. HINTZE: We have not defined exactly what those
18 are, and I don't think anybody else has, either.

19 DR. SIESS: Am I correct that most of your thinking
20 in terms of radioactivity monitoring has been in terms of
21 what might get out to the public, rather than what gets to
22 the people in the plant, or both?

23 MR. HINTZE: I think we have considered both, yes.

24 MR. BENDER: I don't really think I understood the
25 answer you just gave. Could you make it more specific?

1429 223

1 MR. HINTZE: It is under Criterion 19, where it
2 concludes, the remote control for hot shutdown. The instru-
3 ments are also indicated; they should be there, also.

4 MR. EBERSOLE: Well, typically that system --

5 DR. SIESS: Are you talking about this reg guide?

6 MR. HINTZE: Yes.

7 MR. EBERSOLE: That remote control system --

8 MR. HINTZE: We added that one to this guide, which
9 was left out of 1.97.

10 MR. EBERSOLE: Well, typically, that remote control
11 or that control for remote shutdown is not anywhere near as
12 well protected as the control room area. It is off in the
13 plant someplace, unshielded, in an environment which is not
14 protected, as is the control room.

15 MR. BENAROYA: It would also be -- the key is in
16 the control center, which is being looked into. And those
17 key parameters would be monitored from there, which would be
18 a distance from the control room.

19 DR. SIESS: Not 15 miles, though? You won't let
20 anybody put it that far?

21 MR. BENAROYA: There will be some in Bethesda, as
22 I understand it.

23 MR. EBERSOLE: How do you get back to control the
24 plant from that distance?

25 MR. BENAROYA: I don't think you can control the

1 plant. That is only for information.

2 MR. EBERSOLE: But the information does you no good
3 unless you can do something with it.

4 DR. SIESS: Isn't the solution to keep the control
5 room habitable?

6 MR. EBERSOLE: Yes, exactly.

7 DR. SIESS: And don't we have some standards on
8 habitability of the control room?

9 MR. EBERSOLE: Not for these conditions.

10 DR. SIESS: For what conditions?

11 MR. EBERSOLE: These beyond design basis conditions.

12 DR. SIESS: By the time you breach containment,
13 everybody is running. You've had it.

14 MR. EBERSOLE: Not if you have hardened the control
15 room, by no means.

16 DR. SIESS: What are you going to do to protect
17 the public after you have breached containment?

18 MR. EBERSOLE: Prevent it from being worse.

19 DR. OKRENT: There are some sequences, at least
20 hypothetical ones, in WASH-1400, where there is a containment
21 failure prior to core melt. I mean, there would be some
22 activity, but not lots.

23 DR. SIESS: I saw some mention of a proposal where
24 the control room would be sealed off, complete internal
25 recirculation, et cetera.

1 MR. EBERSOLE: It may well be that it is possible
2 to modify control rooms with moderate attention to detail to
3 make them invulnerable to these kinds of conditions you postu-
4 late here for accidents. I don't know that, but I think that
5 it may well be that you don't have to go far to fix them.

6 MR. POLANSKI: There are ventilation systems already,
7 but the other problem is shielding from filling up the aux
8 building with containment.

9 MR. EBERSOLE: But that may well be adequate
10 already.

11 MR. POLANSKI: Although I doubt it.

12 MR. EBERSOLE: Well, I know one case where it is.

13 DR. SHEWMON: Could we get on with Mr. Polanski's
14 presentation and just acknowledge that the question is not
15 going to be answered in the next five minutes?

16 DR. CARBON: Go ahead.

17 MR. POLANSKI: Because we are very concerned about
18 this necessary and sufficient set of instruments, and because
19 we were so careful to take a systematic approach to accident
20 monitoring, we have got some objections to some aspects of the
21 way the regulatory guide included and supplemented the
22 ANS 4.5 standard.

23 (Slide.)

24 The first of these is that, as we read the guide
25 and read the two tables, 2 and 3, that list specific

1 instruments or variables to be monitored, that it doesn't
2 appear that a systematic approach was used in developing that
3 list. The format of the list even is by location rather than
4 by function, and we feel that the way you make up a list is
5 by asking yourself what job needs to be done first. And
6 without a clear connection between accident monitoring criteria
7 and the list that you see in the reg guide, you can't really
8 tell anything about the necessity and sufficiency of that
9 list of instruments.

10 And in fact, our working group took the list of
11 instruments in the regulatory guide and reorganized it,
12 resorted it according to our accident monitoring criteria and
13 our four variable types. And I don't have an overhead
14 transparency for it, but that list is within the last three
15 pages of the handout I provided. And if you would just glance
16 at that.

17 The table shows the monitoring functions, and then
18 the Reg Guide 1.97 instruments that we concluded were in there
19 to do that job, and then the ones that we recommended where
20 we made recommendations in the standard. And you can see
21 that in some categories were more than one correspondents --
22 in many others, there are far more instruments than we thought
23 was necessary to accomplish the job. And there is one or two
24 places where the regulatory guide missed an instrument which
25 we had included.

1429 227

1 DR. OKRENT: Could I ask a question or two about
2 that table?

3 MR. POLANSKI: Yes.

4 DR. OKRENT: The Topic E, nice-to-have, which
5 presumably means ANS 4.5, doesn't specify it, and furthermore,
6 it is not covered by some other standard.

7 MR. POLANSKI: Right. That category was invented
8 by the NRC staff for the regulatory guide.

9 DR. OKRENT: Let's see, now.

10 DR. SIESS: The nice-to-have is the staff's termino-
11 logy? The staff added that list on Item E, did it not?

12 MR. POLANSKI: Yes, that is correct.

13 DR. OKRENT: But it is not in 4.5, as I understand
14 it?

15 MR. POLANSKI: That's right.

16 DR. OKRENT: Now can I try a couple? Containment
17 temperature. You feel this is not a relevant measurement
18 under any accident conditions?

19 MR. POLANSKI: No, we feel it is not an essential
20 measurement under any accident conditions of interest. I think
21 on that particular one, we felt that pressure told you more
22 than temperature, and just about in any accident we could think
23 of.

24 DR. OKRENT: Well, I would suggest to you that
25 there might be sequences when the structural people would be

1 interested in knowing what the temperature had been for some
2 hours when they were getting up in pressure. And I for one
3 question the judgment of ANS 4.5 on that particular measure-
4 ment.

5 MR. POLANSKI: Mr. Okrent, of what value would that
6 measurement be? Say the structural people knew what the
7 temperature was.

8 DR. SIESS: Some structural problems vary with
9 temperature.

10 MR. POLANSKI: I understand that. But you're in the
11 control room after the accident and your job is to keep the
12 core cooled and keep the containment system intact. And how
13 will knowing containment temperature make you do anything
14 different than you would have otherwise?

15 DR. SIESS: How would knowing pressure make you do
16 anything different?

17 One reason I want to know pressure is to have some
18 idea of how close I am to breaching containment. Now, if the
19 strength of the containment decreases with temperature and
20 the pressure and temperature are both going up, I need both
21 pieces of information to estimate when I'm going to exceed
22 the strength.

23 MR. POLANSKI: Perhaps.

24 MR. EBERSOLE: There are certain classes of accidents
25 not related to LOCAs, but rather to very small breaks or

1429 229

1 simply dry heatup of the containment from sustained conditions
2 of temperature and pressure of the primary and secondary
3 systems, wherein the containment atmosphere may well approach
4 the 400 to 500 level without much water in the air. This is
5 just dry heatup.

6 MR. POLANSKI: This is an accident scenario?

7 MR. EBERSOLE: It was in small break accidents,
8 where you had some release of steam inside. It is not a
9 LOCA, which tends to suppress the temperature. It is a dry
10 heatup.

11 MR. BENDER: Mr. Chairman, I'm sure we can find a
12 number of places where the reg guide and the ANS group have
13 selected things that are nice to have, and they may be even
14 more than nice to have.

15 DR. SHEWMON: And I want to know of a few others that
16 are on that list.

17 DR. OKRENT: Well, one is enough, because we were
18 told we had a complete set. And I wanted to indicate a ques-
19 tion.

20 MR. BENDER: The thing that we ought to be zeroing
21 in on, though, is the fundamental question of whether the
22 staff's list is too extensive, as opposed to the type of
23 approach that the ANS group has suggested. Now, you can get
24 too much instrumentation and not be able to absorb the infor-
25 mation.

1 I had been a little concerned about how much the
2 staff is asking for. I don't know that I agree with everything
3 that the ANS group is suggesting, though.

4 DR. SIESS: Incidentally, I might mention to the
5 Committee that there was quite a bit of discussion in the
6 Subcommittee about what was going to be done with this instru-
7 mentation and the information presented by it, with this large
8 amount, and whether there would be any possibility of inte-
9 grating it into the status of the plant. And much of this
10 revolved around the man-machine interaction type situation
11 and the staff agreed that they just needed -- that this did
12 need to be considered, and this reg guide addressed itself
13 primarily to what instrumentation that had to be further
14 worked on integrating it into the control room and the control
15 room display.

16 And I think we agreed that there did need to be
17 additional work along those lines.

18

19

20

21

22

23

24

25

1 DR. SHEWMON: Did they also express a willingness to
2 drop one or two things that they felt would be redundant and
3 therefore possibly confusing?

4 DR. SIESS: Well, redundancy is something they are
5 depending upon, I think, because all of these instruments are
6 not going to work, no matter how well they are made. There
7 is always a possibility of failure. And I guess diversity
8 is more important than redundancy, their having two things
9 to look at to know what the situation is.

10 There's a possibility they will drop some of them.
11 If they get enough flack from the industry and the ACRS,
12 they probably will. They have in the past. But right now
13 I think they are pretty well inclined that this is the list.

14 MR. HINTZE: I think it would be well to point out
15 that the difference really is between ANS 4 and the reg guide,
16 are really the Type D instruments. Now, they have zero Type D.
17 But they did not mean that there were going to be zero Type D's
18 selected. They just didn't choose to make a recommendation
19 as to how many or what they should be.

20 The staff took this on and said, we can't ignore
21 that. We will make a list. When we compare what ANS came
22 up with and what the staff came up with, it was a difference
23 of 17 to 11 or 17 to 12.

24 DR. SHEWMON: Could you tell me Type which?

25 MR. HINTZE: Type A and B -- or excuse me, Type B and C.

1429 232

1 I'm talking about D when I say that is the difference between
2 what the reg guide has and the 12 that the standard had.

3 DR. SIESS: But you also added Type B, did you not?

4 MR. HINTZE: That is correct.

5 DR. SIESS: And that is a pretty good list.

6 MR. POLANSKI: And A1, if you count indications
7 rather than variables, redundancy required, and all of that,
8 we got from the NRC list something like, depending how you
9 count the thermocouples, somewhere between 90 and 100 separate
10 Class 1-E safety grade indications, as compared to 24 for the
11 ANS standard.

12 And part of our concern with the ANS standard, again,
13 was because trying to keep to simplicity the use and maintenance
14 and training concerning those Class 1-E instruments, we again
15 aimed at the minimum set rather than anything anybody ever
16 thought might be nice.

17 DR. CARBON: Dave, unless your question is urgent,
18 I would like to urge him to wind up.

19 DR. OKRENT: I have two short questions. And I
20 hope the answers are short.

21 In reading this draft standard, I notice that they
22 propose that these instruments work if you lose off-site
23 power, but they are not required to work if you lose all AC
24 power. I may have read it incorrectly, but that is what I
25 thought it said at one point.

1 What happens to the instrumentation that you would
2 require if you had a station blackout for an extended period
3 of time? Would some of it be available? And if so, what?

4 MR. WENGINER: There are different criteria, whether
5 you use the reg guide or the ANS standard. Let me tell you
6 what the reg guide says on the question of power source. For
7 Type A, we have called for emergency power. For Type B, we
8 have called for the critical bus, if you will, zero time outage,
9 no break power.

10 And for the Type D and E, we have called for
11 emergency power, which allows for outages of something like
12 30 seconds or so to get the diesel started.

13 DR. OKRENT: Again, if I lost all my AC power, would
14 I be able to tell what the pressure was in the containment, if
15 it were going up?

16 MR. WENGINER: The answer is yes, that the zero
17 time outage power would be the DC-backed plus, which we would
18 provide on both the Type D, which is the status of fulfilling
19 the safety functions.

20 DR. OKRENT: All right.

21 MR. WENGINER: But there's a difference between
22 the guide and the standard in this regard. The standard would
23 not have required the zero time outage power in the case of
24 monitoring for the breach of the containment, and so on.

25 DR. OKRENT: The only other thing -- and I will

1429 234

1 just make it as a comment -- I notice that in the guide, in
2 the standard, it is proposed that for an inert containment
3 you measure oxygen, possibly. I would suggest that there
4 would be an interest in knowing the hydrogen concentration
5 and whether the containment is inerted or not. And I will
6 just leave that as a comment.

7 DR. CARBON: Mr. Polanski, will you charge on, then,
8 and try to wind up quickly?

9 MR. POLANSKI: Sure.

10 Our second disagreement with the regulatory guide
11 has to do with the Type D and Type E variables. We chose
12 specifically to address Type D variables with safety system
13 design. We do not feel they are directly related to plant
14 safety during the accident period.

15 The Type E definition defined by the regulatory
16 guide we see as only an open-ended catch-all with no criteria
17 for the inclusion or exclusion of those instruments. And in
18 fact, the definition in the regulatory guide is those variables
19 to be monitored as required to provide defense in depth and
20 for diagnosis and for other useful purposes. And in line
21 with our intent of only including instruments that have good
22 rationale, we just don't see the need for those at all.

23 And then we have listed here some of the differences
24 with the standard that we can discuss if you are interested.

25 'But the major ones are the first two.

1 So in summary, our concern was that the accident
2 monitoring instrumentation set be necessary and sufficient.
3 To make sure of that, we took a systematic approach to the
4 selection of those instruments. And we feel that the reg guide,
5 in the way it incorporates the standard, does not maintain
6 that systematic approach, and adds other instruments that
7 really are not essential. So we disagree with the reg guide
8 in its current form as an answer to the accident-monitoring
9 objective.

10 DR. SIESS: Are there any things that are in the
11 reg guide supplementing the standard that you don't object to?

12 MR. POLANSKI: I guess it depends how you mean it.
13 Many of the things that are in the reg guide supplementing
14 the standard which are not safety grade turn out to be in the
15 plant anyway, and I think most plant designers would put them
16 in anyway.

17 DR. SIESS: But you did not think it was necessary
18 to put them in the standard?

19 MR. POLANSKI: That is correct.

20 Well, I think there is a body of opinion that says
21 maybe such a list should be developed. But we were concentrat-
22 ing on those things we wanted to make sure were in the plan
23 and wanted to make sure were there and available for the
24 accident period. We were trying to identify and concentrate
25 on that minimum and necessary set.

1429 236

1 DR. SIESS: Well, a lot of the instruments that are
2 both in the reg guide and the standard are already in the plan.

3 MR. POLANSKI: That's correct.

4 DR. SIESS: Some of them are already at the grade
5 that is required; is that not correct?

6 MR. POLANSKI: Some of them are, that is correct.

7 DR. SIESS: The reg guide requires that these be
8 identified. I think I said located all in the same place, but
9 that's wrong, isn't it; just identified?

10 So I guess I'm not quite sure. If the instruments
11 are already there, it is just a difference in the scope of
12 the guide and the scope of the standard that you are talking
13 about?

14 MR. POLANSKI: Yes, and also in the consistency.

15 If you follow through the logical conclusion of
16 including many of the things that were inserted in the reg
17 guide supplementary to the ANS standard, we think you'll also
18 have to include a lot of others, too, and we would rather see
19 that done on a systematic criteria-oriented basis, rather
20 than through what sort of looks like a wish list as it appears
21 in the standard.

22 DR. SIESS: I assume that the working group will
23 have some comments in writing to submit during the comment
24 period when this goes out.

25 MR. POLANSKI: If the working group doesn't, other

1 facets of industry certainly will.

2 MR. SOMMERS: Dr. Siess, if I could answer. Excuse
3 me. Dave Sommers from Consumers Power. I was a member of the
4 ANS 4.5 Working Group.

5 To try to get a little more specifically to address
6 your question --

7 DR. CARBON: Hold up, if you will.

8 Chet, I need some guidance. We have got to wind
9 this up quickly, if possible, and get on with our previous
10 topic. What do you suggest here? Can we wind it up soon?

11 DR. SIESS: The only question before the Committee
12 is whether the staff should send this out for comment.
13 Obviously, we are going to have to compare the positions or
14 work with the staff on it once they have gotten their comments
15 and come up with their final recommendation. And right now
16 we can say, yes, send it out for comment, or we can say, no,
17 we want to hash this over.

18 But I think that that primarily requires discussion
19 with the staff and probably more people from the industry
20 than are represented here. So I would suggest that, if the
21 Committee is ready to decide or has heard enough as a basis
22 for deciding whether to permit the staff to send it out for
23 comment, we can either decide now or tomorrow, whenever you
24 wish.

25 DR. CARBON: Do you have a recommendation?

1429 238

1 DR. SIESS: The Subcommittee has a recommendation,
2 that it be sent out for comment.

3 DR. MOELLER: Can't we vote to have it sent out,
4 without saying we endorse it?

5 DR. SIESS: We are not endorsing it. We did not
6 concur. We just tell the staff it looks good enough to send
7 out, get it out. We will give you more comments. You will
8 get more comments. And when you think you've got them resolved,
9 come back.

10 DR. CARBON: Do you care to make a motion?

11 DR. SIESS: I will so move, that the Committee
12 approve the request of the staff to send this out for comment.

13 DR. CARBON: Is there discussion?

14 All in favor, hold their hand.

15 (A show of hands.)

16 DR. CARBON: It is obviously carried.

17 Thank you, Mr. Polanski and Mr. Hintze.

18 Let's take a ten-minute break.

19 (Brief recess.)

20 DR. CARBON: Let's take up Mike's report again.

21 MR. BENDER: Let me first say that Dave Okrent was
22 kind enough to make a list of things that the ACRS has been
23 involved in, good and bad, over the past. And I would like to
24 get that passed out, with the intent of having the Committee
25 take a look at that. I think we need to look at it for a

1 little bit before we discuss it. And I would like to go
2 ahead with the report, suggesting that the Committee look at
3 this list and try to make some judgments about whether things
4 that are in here need to be put in the report in some form.
5 We might collect them into a few items and list them as they
6 are, or not do anything.

7 The other thing I would like to distribute is also
8 something that Dave worked on. He made some corrections in
9 Section 3. They are not, I think, substantive to the report
10 at this time. They are what I would consider minor editorial
11 improvements. But I will pass them out so you know what they
12 are.

13 DR. OKRENT: There was nothing substantive that I
14 changed there.

15 I would like to pick up at Section 7.4. I believe
16 when we stopped, we had just about come to some conclusion
17 what we were going to say about the staff, the section on
18 industry competence.

19 "The nuclear industry infrastructure is broad
20 enough to satisfy any capability need, given the financial
21 support and management backing. Thus far, the industry has
22 tended to limit its interests to complying with the specific
23 requirements of licensing, managing, engineering of the power
24 plants in accordance with conventional utility practices,
25 and developing its operating forces along the line" -- and I'm

1 going to take out this "Nuclear Navy. "Along recognized nuclear
2 plant operating arrangements" or something like that.

3 "The operating organizations rely heavily on outside
4 consulting services for technical guidance, even though some
5 large utilities have established substantial nuclear engineering
6 knowledge. Events of the recent past indicate that the
7 operating units need more basic capability to prepare for
8 accident contingencies, to diagnose and respond to unforeseen
9 accidents, and to provide backup resources in serious
10 emergencies.

11 "The operating organizations cannot become totally
12 knowledgeable about all nuclear steam system transient charac-
13 teristics, but they can strengthen their understanding through
14 training programs and professional staff additions. The
15 organization of this additional capability will have to be
16 adapted to existing operating situations, but it is extremely
17 important that each licensee or license applicant establish
18 direct top level management interest in this capability on
19 a continuing basis. The Nuclear Steam System Suppliers and
20 the Architect-Engineers also need to strengthen their capa-
21 bilities in support of the operational units.

22 "It would be appropriate for the NRC to bring
23 together management representatives from each major partici-
24 pant in the nuclear power plant business to establish a
25 commitment as to where, when, and how to attack the

1 improvement process. Unless such initiative is shown by
2 all of the industrial participants, there is little likelihood
3 that regulatory action alone will satisfy public safety
4 interests."

5 Now, that doesn't say how to do it, but it suggests
6 that if you get all the people together in the right places,
7 they collectively might agree on what we're going to do. My
8 feeling is that that is safer than us trying to decide what
9 to do for them.

10 Any comments on that?

11 (No response.)

12 MR. BENDER: Let me go on to 7.5, then:

13 "The ACRS originally developed a list of safety
14 matters that it believed to need attention, but not of such
15 urgency that they required immediate action with respect
16 to specific license applications. It was intended" -- make
17 that "licensing actions" instead of "applications."

18 DR. MOELLER: Well, I thought, too, that we
19 resolved them on a case by case basis. What made them
20 generic issues; is that what you mean?

21 MR. BENDER: No. That is not what I mean. Quite
22 the opposite, I don't think we have to deal with them on a
23 case by case basis. There are a certain number of things that
24 need to be dealt with, you can set aside and come back to, if
25 you have a resolution.

1 DR. MOELLER: Yes, but we always had to find some
2 acceptable alternative for a given plant. At least that is
3 what I thought. That's the way I have always viewed the
4 generic items.

5 MR. BENDER: Well, it depends upon what you mean by
6 acceptable alternatives. That didn't necessarily mean that
7 we found a way around the problem. And I think to that extent,
8 I think we are on the same wavelength. Maybe I did not say
9 it right, but I will try to fix it up.

10 DR. MOELLER: Well, if you said "final action" or
11 something, in the third line, that they required "final action."

12 MR. BENDER: Okay, let me see. "Final" might be the
13 right word. I would rather leave open what is going to be used
14 there.

15 "It was intended that these matters be treated by
16 the NRC and its licensees over the long term and problems
17 corrected as solutions were found. The rate at which these
18 "generic safety items" were being examined and acted upon
19 was relatively slow and has caused considerable public concern.
20 In the past two years, the NRC staff established a more
21 complete generic items list of its own that incorporated all
22 of the ACRS items and established priorities for addressing
23 these matters. The NRC staff list was much more extensive
24 than the ACRS list, but there was agreement between the ACRS
25 and the staff on most of the high priority matters. Action

1 plans for the high priority matters have been established and
2 an "Unresolved Safety Issue Task Force" was established
3 recently by the staff to assure that the high priority matters
4 are given adequate attention.

5 "Although the NRC staff action in the past have
6 appeared to be tardy in implementing the solutions to generic
7 problems once they are known, current efforts appear to be
8 more aggressive. Some matters cannot be resolved by physical
9 changes in the short term and will require surveillance types
10 of controls to minimize public risk. Others may involve
11 implementation of major plant changes during planned outages.
12 The correction of generic problems can be handled on a longer
13 term basis if the risks are well understood and appropriate
14 defenses are maintained. The current staff actions appear to
15 be responsive to regulatory needs, and they should be
16 continued in an aggressive mode. Establishing positive
17 implementation plans once resolution actions are known is
18 essential to maintaining public confidence in the regulatory
19 process."

20 MR. FRALEY: The first sentence, 125, it seems to
21 me what's really been tardy is the resolution of the generic
22 items.

23 DR. OKRENT: I would say: "Although the NRC staff
24 actions in the past have not always been aggressive in
25 resolving generic problems or timely in implementing the

1429 244

1 solutions once they are known."

2 It's not just the question of appearance.

3 DR. SHEWMON: It seems to me if we want to talk about
4 the pros and cons of what the ACRS has done, this is one of the
5 places where we have been least aggressive. We have sort of
6 watched what has gone on. We have tuned our list and done
7 nothing to get their resolution, except occasional outbursts
8 like this.

9 MR. BENDER: Well, I don't intend to take any credit
10 for the staff not being aggressive.

11 DR. OKRENT: I might note, historically, back in
12 1967, when these were called the asterisked items, but some
13 of them are still the same, the ACRS tried to be aggressive.
14 It was aggressive to the point that it wrote to Harold Price,
15 who was the Director of Regulation, and it wrote to the
16 general manager, whose name I can't recall now, asking what
17 programs they had or would develop to help resolve the
18 asterisked items.

19 I think they get a response from the representative
20 to the general manager that their program was pretty well set,
21 sorry; and from Mr. Price that, well, it is really the respon-
22 sibility of the applicants.

23 So that was not an auspicious beginning.

24

25

76 21 01

98 HEE

1 DR. SHEWMON: I don't think that that is a
2 response to my comment, either. Some of us can remember
3 things that were tried once many decades ago and didn't
4 work.

5 DR. OKRENT: I agree with you and you will find it
6 in the list of deficiencies.

7 MR. BENDER: Well, the committee will have to
8 decide which of the deficiencies and which of the
9 accomplishments it wants to take credit for. Maybe there
10 are some others that aren't on the list in both areas.

11 DR. OKRENT: It is intended to be a trial example
12 list. I'm sure that it can be expanded.

13 MR. BENDER: It didn't say very much about the
14 priority of our reports. Should I go on?

15 DR. CARBON: Yes, why don't you go on?

16 MR. BENDER: Reporting of safety problems.

17 New safety problems will appear in nuclear installations
18 and it is unrealistic to assume that all will be
19 predictable.

20 The NRC requires all licensees to report
21 safety-significant happenings promptly so that necessary
22 regulatory actions can be taken. The comprehensiveness of
23 the reporting requirements may not have been extended
24 adequately to cover all areas of interest or all
25 participants who might make a safety contribution.

1429 246

76 21 02

g HEE 1 Action should be taken to make certain that nuclear plant
2 owners and operators, constructors, nuclear steam system and
3 other equipment suppliers, inspection and service
4 organizations, craftsmen, operating personnel, and even the
5 public at large report matters of public safety significance
6 as soon as they are known.

7 While this may occasionally cause unnecessary reaction to
8 minor safety matters, it will assure that maximum time is
9 available to correct serious difficulties.

10 At the same time, the reporting system should not be
11 excessively burdensome. Effort should be made to define the
12 informational requirements in such a way that those involved
13 in reporting can, without excessive effort, provide
14 information needed to assess the safety significance of such
15 matters.

16 Of particular importance is the need to avoid a
17 prosecutorial environment for those reporting errors,
18 faults, and maloperations when deliberate malfeasance is not
19 evidence.

20 Only in this way can the regulatory system assure a
21 positive response from licensed participants, their
22 contractors, and their employees.

23 MR. FRALEY: Again, when you say that the agency
24 should take action to make certain that the public at large
25 reports safety issues, I think the best the agency can do is

1429 247

76 21 03

gs:HEE 1 encourage the public. It can't make certain in a democracy.

2 MR. BENDER: They can make as certain as they can.

3 DR. CARBON: Other comments on this, or is it
4 acceptable?

5 (No response.)

6 MR. BENDER: I am willing to look at, say, not
7 making certain.

8 DR. CARBON: Then we can go on to 7.7.

9 MR. BENDER: ACRS effectiveness. The ACRS is
10 assigned the responsibility for reviewing nuclear
11 installations prior to licensing and reporting to the NRC.

12 In the committee's view, some monitoring review of
13 current license applications will always be needed to assure
14 current and comprehensive treatment of safety matters.

15 The ACRS review of NRC's safety requirements, as embodied
16 in regulations, standards and standard review plans, must be
17 continued since they provide the basis for staff judgments
18 concerning public safety adequacy.

19 The ACRS also needs to keep itself currently informed of
20 safety research and international nuclear safety matters.
21 When special public safety matters appear, the ACRS will
22 probably be asked to use its range of expertise to assist
23 the regulatory administration in defining a path for
24 minimizing public safety risk.

25 These matters would appear to deserve priority over

1429 248

76 21 04

98 HEE 1 others the ACRS has been asked to address.

2 Since the ACRS members' time is limited because of their
3 part-time employment constraints, the committee should be
4 discriminant in accepting other tasks from the Commission,
5 the NRC staff, the Congress, USDOE, or other federal
6 agencies.

7 Now there is this whole list of things which Dave has
8 here. If you would like, I would just read it.

9 DR. OKRENT: I have an alternate suggestion. I
10 prepared those last night sometime close to midnight just
11 trying to put down some possible items that could go on the
12 good and the bad side.

13 I would myself suggest that the members look at this
14 list, see what they think belongs from there and what
15 doesn't and what could be added, from their point of view.
16 And after they have done that, it might be a better time to
17 talk about it.

18 That would be my own suggestion rather than starting
19 cold.

20 MR. BENDER: Well, let me offer a couple of
21 typical things that aren't on this list to stimulate people.
22 On the positive side, I think considering the amount of time
23 the committee has spent looking at reg guides and the like,
24 it would be appropriate to say that the committee has
25 constructively reviewed the regulatory documents. And I

1429 249

76 21 05

gshHEE

1 think we have.

2 DR. OKRENT: That would have been on except I
3 thought of it after I had gone to bed, as it were. I had
4 put down that we had helped in formulating general design
5 criteria and participated in reg guides.

6 And when I woke up in the morning, it slipped my mind
7 again.

8 MR. BENDER: But it is things like that that could
9 be added to the list as well.

10 DR. OKRENT: I think people should write out the
11 ones -- I don't necessarily propose to write any more. I
12 want to see what others have in mind.

13 MR. BENDER: And on the other side is the clear
14 quality with which our letters are written. They could be
15 held up as models.

16 Let me go on. Public communications. The public
17 anticipates that the NRC will keep it informed in an
18 intelligent and responsible way concerning safety problems,
19 licensing actions, regulatory deficiencies, health effects,
20 waste disposal, and similar matters.

21 The public, as well as the NRC licensees, often have
22 difficulty in determining which sources of information are
23 authoritative and whether information provided by staff
24 members is fact or opinion, official or private, preliminary
25 or final.

1429 250

76 21 06

9 ● NEE 1 Clearly, in connection with an accident like Three Mile
2 Island, a single well-informed spokesman would be very
3 important to avoid confusion in responding to the emergency.

4 The NRC organization should be prepared through a
5 designated spokesman to explain, clarify, correct, modify,
6 amplify, or otherwise inform the public of matters appearing
7 in the public information meeting in a timely fashion so
8 that the public can identify the authoritative regulatory
9 voice and discern the public safety significance of the
10 information.

11 The provision of a designated spokesman to express the
12 official NRC viewpoint, however, should not be a mechanism
13 for stifling expression of divergent views.

14 Indeed, some commissioners and some members of the staff
15 may differ with the official position and they should be
16 encouraged to express those views. But speaker should state
17 whether they are expressing personal views that are not
18 consistent with the collective NRC viewpoint if their intent
19 is so directed.

20 When appropriate, the NRC may even wish to have its
21 spokesman discuss divergent positions that are under
22 consideration. The benefit from having a designated
23 spokesman is that the press and the public can see the
24 regulatory thought processes at work in both the official
25 and the independent positions and can have some

1429 251

16 21 07

g7 HEE

1 understanding of their basis.

2 Although often less directly meaningful to the public,
3 the various relevant safety matters which the NRC finds
4 important to discuss outside the context of actual licensing
5 proceedings could also provide the public benefit from a
6 discussion by a designated spokesman who would give a
7 rounded view of the issue, place it in perspective, and
8 present the current position of the NRC, including its
9 basis.

10 Any comment on that?

11 MR. ETHERINGTON: This is not a unique example,
12 but I'm a little bit embarrassed about this clearly in
13 connection with the action of a single well-informed
14 spokesman.

15 This has been so amply recognized by others that I don't
16 like to see it coming in in the form of a recommendation at
17 this time.

18 DR. SHEWMAN: Do you mean other organizations or
19 other parts of the NRC?

20 MR. ETHERINGTON: Well, I think it was
21 acknowledged in the newspapers in the early days of the
22 accident and the chaos before Denton went up there is a big
23 talking point.

24 Maybe we could say that it has already been recognized.

25 MR. BENDER: Well, that is a point well taken,

1429 252

76 21 08

gshHEE

1 Harold, clearly, as illustrated in the case of the Three
2 Mile Island accident.

3 MR. ETHERINGTON: Yes, I think the point is it is
4 better not to make it look like a recommendation.

5 DR. OKRENT: As has been recognized since Three
6 Mile Island.

7 DR. CARBON: Does that first paragraph end up, and
8 is the aim to say that the NRC ought to always be prepared
9 with a spokesman-designate whenever an accident comes up?
10 Is that what you are saying?

11 MR. BENDER: Well, at least that. I think I'm
12 saying more than that.

13 DR. CARBON: Well, I thought that you had been
14 speaking about a lot more than that. But that is all that I
15 read from this. I'm not sure what you meant.

16 MR. BENDER: Reading from it only that it has to
17 do with an accident.

18 DR. CARBON: That is the impression that I get
19 from it.

20 MR. BENDER: Maybe I ought to work on it a little
21 bit. For an accident, in particular, they need a
22 spokesman. But for practically anything that gets announced
23 in the press as a safety problem, they need somebody to say
24 what its significance is, because otherwise, the only people
25 telling the public what's going on is some newspaper.

1429 253

76 21 09

gshHEE 1 DR. CARBON: I don't get that from this paragraph.

2 MR. BENDER: I will try to fix that up. Any other

3 points?

4 (No response.)

5 MR. BENDER: Let's go to the section on the
6 preservation of the regulatory base.

7 The nuclear power industry has operated without public
8 injury for almost 25 years. I'm going to strike that even
9 though it is true and put something else there instead. I
10 will say something like the safety record of the -- the good
11 safety record of the NRC is largely attributable to its
12 safety regulations and those of its governmental
13 predecessors and to the self-imposed safety constraints of
14 the nuclear industry.

15 In considering the need for change in the regulatory
16 process, care must be taken to preserve the many good
17 qualities of the regulatory system while seeking
18 improvements.

19 The use of the current regulatory documents is well
20 understood, even though some may not be interpreted in a
21 desirable way. Some should be more definitive and some new
22 material is needed.

23 It is important to work with the existing base to the
24 maximum extent practical. If a whole new set of documents
25 were introduced, the interpretation process itself could

1429 254

76 21 10

gsh:HEE

1 lead to regulatory chaos.

2 The experienced people involved in the regulatory process
3 in both the regulatory and licensee organizations are also
4 an important part of the base. Management changes are
5 needed and the definition of responsibility should be
6 improved. But those knowledgeable about the safety logic and
7 the implicit but unstated cost/benefit balance must be
8 permitted to function in a system not overly encumbered by
9 procedural requirements or arbitrary management edicts.

10 DR. SHEWMON: Mike, would you tell me, in other
11 words, what it is you are trying to say in that first
12 paragraph?

13 MR. BENDER: The first paragraph? What I'm trying
14 to say is we have already got a bunch of regulations. We
15 have already got a bunch of regulatory standards. We have
16 got a bunch of documents that have been approved. People
17 know what is in them.

18 It wouldn't be a good idea to start all over and say that
19 we are going to develop a new set of regulations and a new
20 set of criteria and forget about what is already there
21 because you wouldn't have any frame of reference to work
22 from.

23 That is what I was trying to say.

24 DR. HEWMON: Would the report suffer greatly if
25 you just took it out? Is this something that is imminent,

1429 255

76 21 11

9 HEE 1 that we are advising Congress against?

2 MR. BENDER: I don't know whether it is or not. I
3 think there probably is a viewpoint that says that the
4 documentary system and the set of documents is so massive
5 and there is so much in it that nobody can use it or
6 understand it.

7 And there are people that think, well, what you ought to
8 do is boil it down to a few simple things. And I wish that
9 were so. But I really don't think that we can do much but
10 hold on to what we've got and try to fix it up where we can.

11 DR. SHEWMON: I don't know what's the inverse of
12 setting up a straw man so that you can knock it down, but it
13 just seems to me that you are belaboring what doesn't need
14 to be said or sort of poking at a shadow or something.

15 MR. BENDER: I'm not going to sit here and argue
16 very hard for keeping this in. Somebody said that we should
17 make a point of being sure that we remind people that there
18 is a base we are working from.

19 And so I decided to put something in here.

20 The only reason for reminding people there is a base and
21 you ought to retain it is that somebody's thinking about
22 throwing it away.

23 DR. MARK: I think that the most particular
24 content in the third and fourth sentences ought to be
25 preserved. I don't know about saying very much else.

1429 256

176 21 12

9 SHEE 1

MR. BENDER: I do, too, Carson.

2

3

DR. PLESSET: I think they give a defensive flavor to it from the beginning, which, if you leave it out, would be fine.

4

5

Is that what you are getting at?

6

7

8

9

DR. MARK: No. I'm saying that I think the things said in the third and fourth sentences deserve to be said. Maybe in just about that form. Maybe not much else is needed.

10

11

12

13

DR. SHEWMON: Starting with "in considering" or starting with "in the use of"?

14

15

16

17

DR. MARK: Starting with "in considering." That is the third sentence.

18

19

MR. BENDER: That is where I would propose to start.

20

21

22

DR. MOELLER: You're saying that we could delete everything else prior to that?

23

24

25

DR. MARK: Well, I'm not sure it would read very good if you did.

DR. MOELLER: No, it would read all right.

DR. CARBON: I see nothing wrong with the paragraph, personally.

DR. BENDER: Well, making a point that if there has been a good safety record, it is because some safety regulation exists, seems to be something that you could say

1429 257

176 21 13

1 without seeming to blow your horn very much.

2 DR. MARK: It does introduce things.

3 MR. BENDER: Anything else? Let me go to the next
4 item. Back and forward fitting safety improvements.

5 The public risk associated with omitting or delaying
6 desirable safety improvements or correcting safety
7 deficiencies may be quite small if only a few plants are
8 involved and operating organizations can provide
9 compensating surveillance.

10 Changes in existing plants are often costly and redesign
11 sometimes delays the licensing process. These factors must
12 be accounted for when the NRC intends to impose some new
13 requirements or safety improvement.

14 Nevertheless, a limit must be established with respect to
15 the cumulative risk from such actions. Some matters
16 currently under consideration have been deferred for such a
17 long time that they might be viewed as the object of
18 deliberate procrastination.

19 The NRC needs to show how its judgments concerning
20 backfit or forward fit actions are established. Cost and
21 schedule cannot be overriding considerations if there is
22 real concern for public safety.

23 MR. EBERSOLE: In the footnote, the five years
24 should be eleven years.

25 MR. BENDER: For the reactor pump trip?

1429 258

76 21 14

gs:HEE

1 MR. EBERSOLE: Yes.

2 MR. BENDER: I didn't think it was that old.

3 MR. EBERSOLE: I have all the correspondence.

4 DR. OKRENT: From the ACRS point of view, the
5 problem is it is not 11 years old yet, but it is going on
6 11.

7 MR. BENDER: I remember that it was 1972 when there
8 was some discussion about safety.

9 MR. EBERSOLE: You read that little thing I wrote
10 called HEWS?

11 MR. BENDER: I will make it a little longer.

12 MR. EBERSOLE: My experience was in January of '68
13 in San Jose.

14 DR. OKRENT: We began in January of '69.

15 DR. CARBON: Are people happy with the subject?
16 Shall we move on?

17 MR. BENDER: The next section was an attempt to
18 pull out some things. I don't think that I have pulled out
19 everything that was in the report and tried to sum up, to
20 some degree.

21 The regulatory base being used by the NRC is substantial.
22 Over the 25-year period of development, the regulatory
23 process has evolved a methodology for accident assessment.
24 In the interest of public safety that covers virtually all
25 the major issues, the strong points of the regulatory

1429 259

76 21 15

gsh:HEE 1 process include an established review methodology that is
2 commonly understood and used by the regulatory staff and the
3 regulated industry, a regulatory staff on the whole of
4 high caliber who addressed the technological issues
5 knowledgeable and act with dedication and a system for
6 identification of problem areas that draws attention to
7 safety matters in time for corrective action.

8 The shortcomings of the regulatory operation relate
9 mainly to the lack of attention given to operating
10 facilities and to assuring a high level of operating skill.

11 The inspection and enforcement capability is not focused
12 adequately on operational matters and improvement is
13 urgently needed in this area.

14 I suspect that several people will want to say more on
15 that.

16 The nuclear industry has a somewhat diffuse understanding
17 of its public safety responsibility under the Nuclear
18 Regulatory Commission rules. Too much of the response to
19 regulations is directed to compliance with the detailed
20 rules and technical specifications.

21 These details are important, but the upper levels of
22 nuclear industry management need other motivation for being
23 sure that public safety is not jeopardized because of
24 industry error or oversight.

25 The current trends in the industry seem to be directed

1429 260

76 21 16

98 HEE

1 toward the establishment of qualification systems for its
2 personnel and methods along the lines of the successfully
3 developed ASME boiler code for unfired pressure vessels.

4 This is a desirable approach provided it is not too
5 heavily weighted with membership from the electrical utility
6 organizations.

7 Participation by nuclear steam supplier organizations,
8 the several important service industries, and possibly
9 including the U.S. DOE laboratories is essential.

10 Further, the judgment of the group overseeing this
11 activity should include technologically knowledgeable
12 representation from outside the nuclear industry since these
13 representatives might contribute balanced understanding of
14 the public risk associated with the use of nuclear power.

15 There are several areas in the public provisions for
16 regulation of nuclear power to assure acceptable risk that
17 need strengthening. These are discussed in the following.

18 One, risk evaluation methodology is not adequately
19 developed. And the public does not have enough
20 understanding of the relative risk from the use of nuclear
21 power as compared with other societal risks.

22 In the interest of knowledgeable governmental regulation,
23 this methodology must be established in usable form.

24 The siting practices for nuclear installations do not now
25 consider all of the relevant public safety matters. The

1429 261

76 21 17

gshHEE

1 design basis accident assessment methodology being used
 2 allows too much credit for the pre-established behavior of
 3 engineered safety features without consideration of the
 4 consequences of degraded function.

5 The ultimate public safety actions available to the
 6 public, including evacuation of the environs, need to be
 7 established and shown to be workable.

8 The existing installations cannot be resited, but
 9 accident controls can be correlated with realistic site
 10 conditions.

11

12

13

14

15

e-21 16

17

1429 262

18

19

20

21

22

23

24

25

176 22 01

kapHEE

1 "The time taken to implement safety improvements,
2 once the need has been established, seems excessive. More
3 needs to be done to show that regulations requiring physical
4 changes are implemented as fast as practicality would
5 permit.

6 "The information supplied to the public about
7 plant failures and quality deficiencies need clarification
8 in order to help the public understand what matters are
9 important to public safety, as opposed to those of
10 non-safety significance.

11 "The actual split in responsibility between the
12 regulatory function, the regulated industry and other
13 governmental functions, needs to be defined and the actions
14 to assure responsible response need to be established.

15 "The problems of low-level radioactive waste
16 management need definitive solutions.

17 "The skills of the plant operators in coping with
18 accident circumstances and the skills of the regulatory
19 staff in assuring that licensees are responsive to the
20 intent of regulations need improvement.

21 "The regulatory interpretation of public safety
22 assurance requirements should be reexamined with respect to
23 safety feature separation, failure definition and systems
24 interaction.

25 "The methods for correcting these areas of

1429 263

176 22 02

kapHEE

1 weakness need careful scrutiny, and when selected, they
2 should be monitored to determine whether they are really
3 satisfying the need. The Regulatory Organization should
4 establish provision for technical knowledgeable management
5 review independent of its present organizational structure
6 on a continuing basis as a help in guiding the regulatory
7 management.

8 "The existing regulatory system has shortcomings
9 that need improvement. Nevertheless, it cannot be judged a
10 complete failure when its record shows no evidence of
11 measurable public health damage over the entire quarter
12 century of commercial nuclear history. The public
13 perception of its effectiveness has been distorted to a
14 major degree by the sensational type of communications media
15 coverage at Three Mile Island and other events of lesser
16 importance. Contingent provisions for the highly unlikely
17 but nevertheless possible serious accidents is the
18 regulatory area that needs most urgent attention. The good
19 qualities of the regulatory process should be recognized and
20 retained."

21 I throw that out for suggestions. People might
22 want to chew on that quite a bit.

23 DR. CARBON: I don't mean this to be editorial at
24 all, but reading the last paragraph, you said,
25 "Nevertheless, it cannot be judged a complete failure." Did

1429 264

kapHEE 1 you do that --

2 MR. BENDER: I put the word "complete" in. To me,
3 that change is the tenor of the whole paragraph, quite
4 significantly. I read that in.

5 DR. SHEWMON: Mike, back on paragraph 137, you
6 start off in one vein and you end up in another. And down
7 about the third line of A-2, you say "participation," but
8 I'm not at all clear -- by that time, participation in what?
9 And I don't see it by going back up to the first two
10 paragraphs.

11 MR. BENDER: I'm kind of lost.

12 DR. SHEWMON: I was talking about paragraph 137
13 and by the time I get into the middle of it over on the top
14 of page B-2, the second sentence there says: "Participation
15 by nuclear steam supplier organizations" et cetera, but it's
16 not clear what they are participating in.

17 MR. BENDER: I understand what you are saying. I
18 should say the qualification system.

19 DR. SHEWMON: Well, you could start another
20 paragraph there.

21 MR. BENDER: Okay, I will fix that up. I
22 understand what you're talking about.

23 DR. MOELLER: In looking at this list, one item
24 which we discussed yesterday was the need for goals. Do you
25 want to mention that here? What are the goals of the

1429 265

1:6 22 04

kapHEE

1 regulatory process? You couched this in the sense that
2 these are the items that need strengthening.

3 MR. BENDER: I might do it by saying, with
4 reference to the controls listed, because I really don't
5 want to go back and repeat those. I haven't really matched
6 that up. That is something Chet made a point about, and I'm
7 sure he's right. We need to be sure that what we say at the
8 end matches up.

9 DR. MOELLER: And secondly, when we discussed
10 siting, I believe we might acknowledge that they have had
11 the siting task force. Maybe I could give you some words on
12 that.

13 MR. BENDER: Why don't you do that? I think in
14 any case, one of the things we need to do is to try to
15 acknowledge if they are doing something.

16 DR. MOELLER: And a third point, in a general way,
17 on page 8-1, paragraph 136, I think if we itemize the strong
18 points then we ought to itemize the weak points.

19 MR. BENDER: I agree. I do not have a very good
20 list of weak points.

21 DR. OKRENT: I have a general observation that
22 this particular section and the one which discusses the
23 ACRS are areas that we should reflect on. Will we have time
24 for this tomorrow?

25 MR. BENDER: I'm not going to be here, but that

1429 266

16 22 05

kaaHEE 1 doesn't prevent people from thinking about it. As a matter
2 of fact, I had sort of thought that I might try to canvass
3 the committee next week, individually, in some way, to see
4 if people have thought about what is in here and to get any
5 other thoughts you might have. I am going to do some paring
6 down of it.

7 DR. CARBON: We certainly, Dave, could discuss
8 this tomorrow afternoon.

9 DR. OKRENT: Well, it depends upon how the time
10 goes, but anyway, I assume that we will be giving particular
11 attention to that.

12 DR. LAWROSKI: I think 6 could be made more
13 inclusive if you struck out the words "low level," and
14 substituted for the word "definitive solutions" by saying
15 "resolution." We have the technical solutions to the
16 management.

17 DR. CARBON: Carson?

18 DR. MARK: I think I had almost the same point as
19 Steve, except a slight addition that item 6, and all of the
20 things except 6 seem to me to bear on it, on procedural
21 kinds of things, regulatory kinds of things -- 6 looks like
22 a technical problem and it would seem to me, perhaps, that
23 it ought to go down out of the middle of the list, anyway,
24 and come at the end. And perhaps even say problem of a
25 different sort, such as that, needs resolution.

1429 267

76 22 06

K. HEE

1 MR. BENDER: It seems to me that the whole matter
2 of accident recovery probably ought to be included in this.
3 And whether decommissioning belongs in that context or not,
4 I don't know, but I think accident recovery ought to be in
5 there some way.

6 DR. CARBON: Is that a major point?

7 DR. MARK: Well, I don't know. Back on page 7-15,
8 Mike, in the second line of the bottom paragraph, that
9 shouldn't be "correcting deficiencies." it should be
10 "correction of." That is vastly different. The public risk
11 of correcting deficiencies is small, is what it says here
12 now.

13 MR. BENDER: Where is this?

14 DR. MARK: The second line of the bottom
15 paragraph on page 7-15.

16 MR. BENDER: And you are suggesting what, instead?

17 DR. MARK: "Correction of."

18 DR. CARBON: Mike, should we jump back and bring
19 in the letter at this point?

20 MR. BENDER: Yes, let me say about the opening
21 letter, that I wrote it to stimulate thought and I have
22 given less thought to it than a letter like that ought to
23 have. Has it been distributed, Ray?

24 MR. FRALEY: Yes, I have distributed it. I have
25 passed them around.

1429 268

76 22 07

1 DR. PLESSET: We don't have it, Ray.

2 MR. FRALEY: I'm sorry, here it is, right here.

3 MR. BENDER: I will just read it through in total,
4 if you don't mind.

5 DR. CARBON: Fine. Why don't you just let people
6 get their copies?

7 (Pause.)

8 MR. BENDER: Since the accident at Three Mile
9 Island, the ACRS has been continuing its review of the
10 accident implications and concurrently reexamining the
11 regulatory process to identify its strengths and weaknesses
12 and where changes might be desirable. The attached review
13 of regulatory processes and functions provides the substance
14 of that reexamination.

15 The ACRS believes the nuclear regulatory process
16 has been effective in protecting the health and safety of
17 the public. The experience of almost 25 years of public
18 injury-free nuclear power use testified to that belief.
19 However, the experience at Three Mile Island is a dramatic
20 and graphic reminder that some improvements are needed,
21 especially in assuring the effectiveness of the multiple
22 defenses essential to protecting the health and safety of
23 the public.

24 This review points out where attention is needed
25 in both the management and technological areas of nuclear

1429 269

176 22 08

KASHHEE

1 power plant safety. The ACRS believes it is important to
2 clarify to the public how these areas will be addressed,
3 with the intent of bringing the public safety protection to
4 a suitable level of quality and capability.

5 The TMI-2 accident is occasionally used as the
6 frame of reference, but the review applies to all of NRC's
7 nuclear power licensing activities.

8 The initial phases of the accident at Three Mile
9 Island are within the spectrum of events foreseen in the
10 safety basis on which nuclear power plant regulatory
11 practices are founded, but the situation was permitted to
12 degrade to a serious degree by failure to anticipate all of
13 the situations which might require emergency core cooling.
14 The containment did serve the functional need, but the
15 containment itself did not work as expected. That, as well
16 as the specific TMI-2 operational errors, equipment
17 malfunctions and instrumentation weaknesses previously
18 identified, should be the focus of attention. Further
19 attention should be devoted to the integrity and isolation
20 provisions for containment for an array of accidents which
21 may include some events with consequences exceeding those of
22 the design basis accident currently used for containment
23 design.

24 Keep in mind also that while the first line of
25 defense continues to be the primary coolant boundary, the

1429 270

76 22 09

KAPHEE

1 ability to provide continuing core cooling when that
2 boundary fails is an essential safety requirement.

3 Because the emergency core cooling system at TMI-2
4 was not allowed to perform as intended, the serious fuel
5 failure resulted. The containment itself is designed to
6 handle bulk fuel failure provide that core cooling is not
7 disrupted long enough to result in the core becoming
8 distorted into an uncoolable configuration that would
9 ultimately melt through containment. Core melting probably
10 did not occur at TMI but the potential for an uncoolable
11 core existed because all circumstances under which core
12 cooling might be needed had not been taken into account in
13 operator training and operating procedures.

14 The review draws attention to the importance of
15 diversity core cooling provisions to assure coolability as
16 an important aspect of plant design and operation. The
17 review also draws attention to the need for further study of
18 systems interactions, a number of which were important in
19 the TMI accident.

20 The importance of not depending too heavily on
21 engineer perception to assure the health and safety of the
22 public is noted in the ACRS review, but the testability and
23 maintainability are still essential to attaining adequate
24 reliability and TMI-2 showed that deficiencies in these
25 areas exist in licensed power plants. The ACRS review

1429 271

76 22 10

K. NEE

1 indicates that attention to these operational functions in
2 nuclear power plants should be more effectively covered by
3 the regulatory process and management action is required to
4 correct the situation.

5 The review reiterates an ACRS recommendation that
6 study of accident consequences should extend well beyond the
7 regulatory "design basis." The character and consequences
8 of accidents having severity beyond the design basis should
9 be understood and provisions for practical mitigation
10 techniques should be identified to protect the health and
11 safety of the public in the unlikely event that these low
12 probability and unexpected accidents occur. Public
13 evacuation and control of radionuclide releases are
14 particularly relevant to this matter.

15 The problem of low level waste management has been
16 exacerbated by the TMI-2 accident. The accident, as the
17 review points out, has clearly shown that inadequate
18 attention has been given to accident recovery procedures.
19 The handling of water containing low levels of radioactivity
20 is foremost among the matters needing attention.

21 The skills available within the nuclear industry
22 and within the regulatory organization are extensive, but
23 there still seems to be a need for improvement.
24 Understanding of systems interactions, particularly those
25 which involve multiple failures, does not seem to be

1429 272

76 22 11

kasHEE 1 sufficient and the knowledge within the nuclear industry
2 appears to be too fragmented for public safety purposes.
3 The nuclear power plant owner, although carrying the primary
4 licensing responsibility, places high dependence upon the
5 nuclear steam supply system suppliers and the
6 architect-engineer organizations to meet licensing
7 requirements.

8 The review emphasizes the importance of
9 establishing a commitment by the industry to meet licensing
10 obligations. The industry-sponsored Nuclear Operations
11 Institute and the Nuclear Safety Analysis Center seem to be
12 efforts in this direction. But the committee believes that
13 a high level of competence must be established in the
14 organization of each licensee. The committee believes the
15 implementation actions to meet this need require the
16 attention of the industry as well as the regulatory
17 organization.

18 The ACRS has not found in its review that there is
19 any lack of dedication on the part of the regulatory
20 organization as a whole, or any deliberate attempt by the
21 regulated nuclear industry to compromise the health and
22 safety of the public. An inability to implement
23 safety-related decisions is a deficiency in the regulatory
24 process that needs correction. More human motivation is
25 needed and it should be brought about through joint efforts

1429 273

176 22 12

KHEE

1 of the industry and the regulatory functions, rather than
2 prosecutorial threat.

3 The obligation to inform the public responsibly is
4 emphasized in this review. The ACRS believes the public
5 should be able to discern the difference between minor and
6 major safety issues from the information provided by the
7 regulatory organization, taking into account the manner by
8 which it is handled by the communications media. The
9 present manner in which safety information is disseminated
10 is not adequate.

11 The ACRS is aware of the recommendations of the
12 Kemeny Commission report, the active legislative review
13 underway by the U.S. Congress and the internal review by the
14 Rogovin Task Force. The ACRS does not believe that response
15 to its review should be deferred until all of these actions
16 concerning NRC functions have been effected. The large
17 number of nuclear power plants now operating and under
18 construction represent a major national commitment to
19 nuclear power. Reactivation of an expanded nuclear program
20 is unlikely to occur in the near future. Regulatory
21 attention should be focused on the existing plants and those
22 in construction and operational licensing status. Emphasis
23 on other matters would result in unwise use of the limited
24 public safety protection resources.

25 The ACRS wishes to assist the NRC in any way it

1429 274

176 22 13

K. HEE

1 can to reestablish public confidence in the nuclear
2 regulatory process. The committee hopes that its review
3 will be helpful in that respect.

4 I'm sure in the last paragraph we had better say
5 to "maintain" instead of "reestablish." My thought was to
6 send this letter to Mr. Hendrie and to send copies to other
7 agencies that would be interested. You might send a copy to
8 other people. I had thought this letter could represent
9 some kind of executive summary. It is not good enough for
10 that, right this minute.

11 DR. SIESS: I would like to see this letter keyed
12 to the appropriate paragraphs in the report so I could
13 cross-check it.

14 MR. BENDER: I think that is appropriate, Chet.

15 PROF. KERR: I have difficulty with paragraph
16 five, the last sentence, because it seems to me to say that
17 until we can take all circumstances under which core cooling
18 might be needed into account, in operator training and
19 procedures, that we can expect core melting to occur. And
20 I'm not quite sure what my inclination would be to recommend
21 deletion of the sentence.

22 MR. BENDER: I'm not too strongly married to that
23 sentence.

24 DR. SHEWMON: It bothers me, right behind the
25 sentence which equates any core melting to equate uncoolable

1429 275

B176 22 14

KAPHEE

1 configuration, because even if core melting did occur at
2 TMI-2, it is in no way equivalent to what you have in the
3 sentence before.

4 DR. CARBON: Do you have additional comment, Bill?

5 PROF. KERR: Just one. In paragraph 11, I think
6 the first two sentences carry a message but the sentences
7 that begin with "A large number of nuclear power plants,"
8 I'm really not quite sure what we're trying to tell the
9 Commission, unless we're telling them not to worry.

10 DR. PLESSET: I have a fix for that that is
11 simple, I think.

12 PROF. KERR: Well, my fix would be to remove it.

13 DR. PLESSET: Well, that paragraph, I was
14 suggesting since reactivation an expanded nuclear program --

15 PROF. KERR: It just seems to me that we're saying
16 something that is so obvious -- that there are times when
17 one needs to say the obvious and maybe this is one of those
18 times.

19 DR. SIESS: What are we telling them there? Not
20 to wait for other people to go ahead and do these things?

21 PROF. KERR: That is what the first two sentences
22 look like.

23 DR. SIESS: Does the rest of the paragraph relate
24 to the same subject?

25 PROF. KERR: No.

1429 276

76 22 15

KERR
1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

DR. SIESS: Then I had better learn to read differently.

PROF. KERR: I don't think so.

1429 277

176 23 01

P. HEE 1

DR. SIESS: Or Mike could learn to write
2 differently.

3 Let me go back to that one that says don't wait,
4 do all of this right now. Is there anything in here that
5 somebody already hasn't said to do that they haven't started
6 on?

7 MR. BENDER: That I don't know. That is one of
8 the things we need to look at.

9 DR. SIESS: It talks about isolation provisions,
10 and they've already got bulletins out on that.

11 MR. BENDER: It may not be necessary to say start
12 right now. I put that in because it always bothers me that
13 everybody says, "Let's get all the reports in before we do
14 something."

15 DR. SIESS: Well, the staff sure didn't do that
16 here. They have been putting out bulletins and orders like
17 mad. Maybe a little too fast sometimes.

18 It seems to me the two things in the paragraph
19 aren't that separate and that the point is that a lot of
20 these things have to be looked at hard in connection with
21 operating plants. We have got 70 of them. And that may be
22 all we have for a while, is what you are saying.

23 MR. BENDER: Well, that is what I was saying, is
24 there are 70 operating plants, and there are a number of
25 them that are in construction now that we had better find

1429 278

176 23 02

1 out about and do something about them rather than sitting
2 around for two or three years while all of these task force
3 reports are coming in.

4 PROF. KERR: I can see the importance of this
5 paragraph if this report dealt mostly with power plants.
6 But it doesn't. It deals with a lot of the history of
7 regulatory commission and the ACRS and organizational
8 matters. And I would guess maybe -- what -- 40 percent of
9 it deals with power plants.

10 MR. BENDER: That is a good point. A lot of the
11 things are not things that are going to be done. Some
12 things do. We could say "system interaction studies." Any
13 improvements we want to make are not going to be helped by
14 sitting around on their hands while somebody tries to figure
15 out what the Rogovin report says.

16 DR. PLESSET: In your third paragraph, I think you
17 ought to point out that this review is needed. Other people
18 have presented their views.

19 MR. BENDER: But ours is only one.

20 DR. PLESSET: The other thing, in paragraph 5, you
21 start out with this command, "Keep in mind." I think you
22 should say "One should keep in mind."

23 PROF. KERR: Or even "Keeping in mind."

24 DR. PLESSET: I don't like participles.

25 Then on line --

1429 279

176 23 03

P. HEE

1 DR. CARBON: Gentlemen, let me interrupt just a
2 second. We had better wind this up in about 10 minutes.
3 And certainly, we ought to take any major points that anyone
4 has, but I wonder if it would be well to jump at this time
5 to a discussion of planning for what we have got to do
6 between now and December and what we want to do in December
7 so as to hopefully wind this up then. And right now, this
8 next 10 minutes is about the only time we have got for that
9 planning.

10 MR. BENDER: I think you are making a good point.
11 Let's find out whether we get any comments on the letter
12 first.

13 DR. CARBON: Well, people can call you with
14 comments. And I have got some, for example, that I wanted
15 to do so.

16 DR. OKRENT: I have a general comment. I am going
17 to need to go back and look at what I think should be in the
18 final section, which is where any significant
19 recommendations will be, and then go back and try to think
20 about what constitutes a letter. I am unprepared to think
21 seriously enough about the letter until I have looked at
22 what I think should be in that last section.

23 DR. CARBON: What kind of time schedule do we have
24 to be on in terms of having information to you for a final
25 writeup, for example?

1429 280

176 23 04

P. HEE 1

MR. BENDER: To get this thing in in December,
2 what I would like to have is comments from you by the end of
3 next week. I will then try to find a way to put all of
4 those things into one more nearly finished report, and send
5 out copies to everybody. If I get the comments by next
6 week, by the end of the following week, I could have copies
7 to everybody.

8 I think, Mr. Chairman, if we designated people to
9 review several chapters for whatever review individuals can
10 make of them.

11 DR. CARBON: Of the several chapters of your newer
12 version?

13 MR. BENDER: The newer version. I will keep the
14 same organizational structure.

15 PROF. KERR: Which is the newer version?

16 MR. BENDER: It is the one called "Draft 4." Look
17 mainly at the table of contents.

18 DR. CARBON: I am sorry. Maybe I spoke wrong.
19 You're talking about people reviewing each chapter before
20 you send them to us two weeks from now?

21 MR. BENDER: That would be my thought.

22 PROF. KERR: So there is no point in keeping this?

23 MR. BENDER: Not unless you want to comment on it
24 specifically.

25 DR. SIESS: Dave said something about the letter.

1429 281

176 23 05

HEE 1 You want to review the report before the letter. Does the
2 letter have any different status than the report? Is the
3 letter the formal submittal?

4 DR. CARBON: It's my understanding that the two go
5 together.

6 MR. BENDER: I want to propose that the letter --

7 DR. SIESS: Was Dave thinking differently?

8 DR. OKRENT: No. You don't write the summary
9 until you know what it is you're going to summarize.

10 DR. SHEWMON: If you haven't finished the report,
11 why try to write the summary?

12 DR. SIESS: I am not sure it is all in the report
13 now.

14 DR. CARBON: Gentlemen, we have got four weeks
15 from today is the end of the December meeting, so we have
16 got to get comments to Mike a week from today. He gets the
17 report out two weeks from today, and it probably gets in our
18 hands about a day or so before Thanksgiving or about that
19 time, which is just about one week ahead of our December
20 meeting. So, really, effectively, we have got about a week
21 in there.

22 And I think Mike's suggestion of assigning someone
23 to review each chapter makes a lot of sense. And I would
24 propose to do that. And I guess I would welcome volunteers
25 to take particular chapters. And I will call people,

1429 282

75 23 06

p. HEE

1 otherwise, to wind it up and have a review.

2 How much time should we set aside in the December
3 meeting?

4 MR. BENDER: I hate to be controlling the schedule
5 all of the time, but I am planning to be here on Thursday of
6 the December meeting only. By that time, the report ought
7 to be on the table, and I leave it to the committee to
8 decide what it wants to do with it.

9 DR. CARBON: It sounds like we ought to set aside
10 a full day. Thursday.

11 MR. BENDER: If you could do that, I would
12 appreciate it.

13 DR. CARBON: I don't know how much more time we
14 would need.

15 MR. BENDER: I am hopeful that the response we
16 have gotten from the committee sort of indicates that the
17 substantive report is okay. It editorially needs a lot of
18 work. I don't think anybody would argue about that.

19 DR. CARBON: After the reviews of each chapter,
20 should we try for another version before Thursday of the
21 December meeting?

22 MR. BENDER: Well, I was going to make a different
23 suggestion. Even though I said I was coming up on
24 Wednesday, if you could designate the reviewers and find
25 some way for us to have the reviewers get together in

1429 283

76 23 07

py-HEE

1 advance of the full committee meeting, this could expedite
2 things.

3 MR. FRALEY: Well, we are scheduling a meeting of
4 the procedures subcommittee on Wednesday. Why don't we
5 include some time during that meeting?

6 DR. CARBON: How about three hours?

7 MR. BENDER: That would make some sense to me.

8 DR. CARBON: Maybe it would be well if we are
9 going to ask and assign people to review the chapters right
10 now. I presume the chapters aren't going to change.

11 MR. BENDER: We don't necessarily have to leave it
12 as chapters.

13 DR. CARBON: I would think we could take at least
14 the first three chapters as one in bulk, the introduction of
15 goals and the review background. Would someone volunteer to
16 take that?

17 DR. RAY: Sure.

18 DR. CARBON: I think we need someone with a more
19 extensive background than you, Jerry, when we bring in that
20 Chapter 3.

21 Harold, would you take the first three,
22 particularly, because you can take care of Chapter 3 well,
23 the history, the aspects of it?

24 MR. ETHERINGTON: Yes.

25 DR. CARBON: Thank you, however, Jerry.

1429 284

76 23 08

py HEE

1 Chapter 4, the regulatory organization. Do we have
2 a volunteer? Carson?

3 DR. MARK: Okay.

4 DR. CARBON: Chapter 5, the nuclear industry
5 organization.

6 DR. RAY: Okay.

7 DR. CARBON: Fine. Chapter 6, major technological
8 issues. Chapter 5 is Jerry.

9 DR. OKRENT: Well, I will take 6 if nobody else
10 wants it.

11 DR. CARBON: Fine. 7, urgent regulatory
12 management. Chet or Bill, do either of you have time?

13 Bill, were you about to volunteer?

14 PROF. KERR: I learned one thing in my long and
15 distinguished military career.

16 (Laughter.)

17 DR. CARBON: I was in the Army, too.

18 It has been suggested that Dade would be good for
19 7.

20 DR. MOELLER: I will read it.

21 DR. CARBON: All right. Take 7.

22 8, overall assessment.

23 DR. OKRENT: Well, 8, I think the sticking points
24 on Thursday of the next meeting are going to be 8, maybe a
25 little bit on this question of where the ACRS did well or

1429 285

76 23 09

p. MEE 1 not. But that should probably not work out too bad. So, I
2 think 8 is going to be very important, and then the letter,
3 really, and I suggest that everybody pay attention to 8 and
4 the letter, myself.

5 DR. CARBON: That will be fine, unless we want to
6 try and fold something in Wednesday. I guess there will be
7 several people at the meeting Wednesday.

8 DR. OKRENT: Again, on 8, I would suggest that
9 Mike prepare a draft, but we ought to have a collection of
10 all of these submissions on 8, just as maybe those that
11 relate to the ACRS role, so that we can see how they look
12 differently. But I think you should put one together that
13 fits, and we ought to be able to have the raw material.

14 MR. BENDER: I haven't really tried to make sure
15 every one is covered.

16 DR. CARBON: Need we do other things on this now?

17 MR. ETHERINGTON: It would be helpful if we had a
18 copy of any changes that might have been made as a result of
19 today's meeting.

20 MR. BENDER: I think about all I can do is suggest
21 that we try to provide those that want it with a copy of the
22 transcript. There is no master copy.

23 DR. CARBON: A copy of the transcript, though,
24 will be available. We don't have copies. So, let me ask
25 how many people would like copies of the transcript of our

1429 286

76 23 10

1 discussion?

2 DR. SHEWMON: When do you expect to take another
3 crack at this, Mike?

4 MR. BENDER: I plan to start Sunday, if there is
5 something the committee can have, I want to get it in the
6 mail by a week from next Friday, and I will try to send it
7 directly.

8 DR. PLESSET: You are going to send a new copy of
9 the whole thing to everybody?

10 MR. BENDER: Yes.

11 DR. MOELLER: So, we wait and review what we get?

12 DR. CARBON: Well, he is asking for comments by a
13 week from today on everything we have been discussing; and
14 then two weeks from today he hopes to have a new version
15 mailed out to us.

16 Jerry?

17 DR. RAY: You have answered my question.

18 DR. CARBON: If there are no more important things
19 to bring up here, we will take a break and launch into
20 NUREG-0600.

21 (Brief recess.)

22 DR. CARBON: Let's move on to the NUREG-0600
23 activity. Harold, may I call on you.

24 MR. ETHERINGTON: The subcommittee met with the
25 I&E staff on October 30 to review NUREG -0600.

1429 287

76 23 11

p. 1 Representatives of Met Ed were also present and were invited
2 to comment.

3 Today's agenda, which you have, is essentially a
4 contraction of the version that was used by the subcommittee
5 or used at the subcommittee meeting. Your tab 6.4 contains
6 reports by consultants Catton, Michelson, and Lipinski. You
7 also have a good summary of the meeting by Mr. Moeller and
8 some additional comments by Mr. Abbott, a senior fellow.

9 The stated scope of NUREG-0600 is limited to
10 investigation of the licensee's operational actions prior to
11 and during the course of the accident and his actions to
12 control release of radioactive materials and to implement
13 his emergency plan during the course of the accident.
14 Consistent with this limitation, emphasis in the report is
15 placed on departure from technical specifications prior to
16 the accident and departure from the licensee's procedures
17 during the course of the accident, with little consideration
18 of other contributing factors.

19 Other investigations and other NRC group studies
20 have considered not only the actions taken by the licensee,
21 but also other facets of the accident, including review of
22 peculiarities of the nuclear steam supply system intended to
23 inhibit recovery or confuse the operators by having
24 pressures levels and to divisions of the control room and
25 system design that degraded the quality of information

1429 288

16 23 12

py HEE

1 available to the operator. These were not covered by the
2 intended scope of NUREG-0600.

3 NUREG-0600, then, includes a factual chronology of
4 the vent descriptions and the finding of operational and
5 shortcomings and errors. It includes a total of 35 items of
6 potential operational and administrative noncompliance.

7 I&E subsequently, by letter of October 25 to the
8 Met Ed Company, imposed fines in respect to 17 violations,
9 infractions, and deficiencies, many of them multiple
10 occurrences. We don't know at this time whether Met Ed
11 plans to appeal any of these findings.

12 The subcommittee noted that two incidents have not
13 been adequately explained: first, is the sequence of events
14 consequence on water hammer associated with water entering
15 the instrument line and with turbine trip.

c-23

16
17
18
19
20
21
22
23
24
25

1429 289

1 The second is the explanation of the action of
2 tripping the diesel fuel racks and failure to reset them.
3 The Subcommittee believes that, at least on information on
4 water hammer caused by turbine trip, it should be explained,
5 and that it should be possible to obtain more information on
6 the diesel tripping sequence.

7 Because the limited scope of the report tends to lead
8 to a catalogue of violations, with only limited recognition
9 of other factors that contributed to errors by the operators,
10 the Committee has some concern that it may be concluded from
11 the charges that failure to follow accident procedures is
12 automatically a violation. Accident procedures, in the
13 Subcommittee's view, are prepared -- first of all, accident
14 procedures are prepared by the licensee and are not approved
15 by NRC.

16 But the licensee is required to follow his own
17 procedures. The Subcommittee believes that an accident proce-
18 dure cannot be sufficiently detailed to encompass every
19 possible sequence of events; and that they must be based upon
20 the assumption that a particular set of conditions exists.
21 A deviation from this set of conditions may make it necessary
22 to depart from the procedure.

23 As an example, TMI-2 emergency procedure 2202-1.3,
24 loss of reactor coolant/reactor coolant system pressure, which
25 is referred to in NUREG 0600, was examined by one of our

1 consultants and found to provide confusing symptoms and
2 instructions for the case of a loss of reactor coolant at the
3 top of the pressurizer.

4 He also found that emergency procedure 2202-1.5,
5 pressurizer system failure, which calls for pressurizer
6 level control, was unacceptable for the TMI-2 accident and for
7 any other loss of reactor coolant at the top of the pressurizer.

8 The question that arises, then, whether an operator
9 using his best judgment is guilty of a violation if he
10 consciously takes an action that is at variance with procedures
11 which in themselves contain misleading symptoms and instruc-
12 tions, or which may be otherwise incorrect, obviously, this
13 is a difficult question, and it will involve some post facto
14 appraisal of the operator's judgment.

15 Among the lessons learned from the Three Mile Island
16 accident are that the procedures need to be radically improved
17 and more carefully reviewed. This perhaps is somewhat beyond
18 the scope of the Subcommittee's charter, but the Subcommittee
19 did discuss this and believes that procedures should be
20 examined carefully for ambiguity, for consequences of failure
21 to follow procedures, for conditions that may require the
22 operator to depart from written procedures, and for any
23 continuing requirement to conform to tech specs during an
24 accident.

25 When we have an accident, some tech specs go by the

1 board. But apparently they are expected to follow out, as,
2 for example, the prohibition against going solid is a tech
3 spec, and the operators clearly consider that a management
4 requirement.

5 The Committee, because of the limited scope of
6 NUREG-0600, which seems to place essentially all of the blame
7 on the operators, the Committee suggests that consideration
8 be given by NRC to issuing a summary report that puts into
9 context the findings of NUREG-0600 with the actions taken by
10 Bulletins & Orders and by conclusions of the Lessons Learned
11 Task Force, which it is felt will present a better overall
12 picture of the responsibilities associated with the accident.

13 That is all I have to say, Mr. Chairman, at this
14 time.

15 DR. CARBON: Are there any questions of Harold?

16 DR. LAWROSKI: You said there was a report by
17 Miller?

18 MR. ETHERINGTON: It was a handout, wasn't it? You
19 had a summar report.

20 MR. MULLER: Yes, that was a handout yesterday.
21 That was a summary of the meeting.

22 DR. CARBON: Any other questions of Harold or
23 comments by other members of the Subcommittee?

24 PROF. KERR: Did you receive any comment from the
25 staff on your comments about what should happen to procedures

1 and tech specs once one gets into an accident? It struck me
2 as I read the fines and reasons therefore that one seemed to
3 be stretching things a bit to insist that an operator follow
4 all of the procedures once an emergency came into existence.
5 Did the staff react to the Subcommittee's comments at all?

6 MR. ETHERINGTON: These comments were developed mostly
7 during the executive session after the meeting.

8 MR. LEWIS: This specific issue of the extent to
9 which one ought to be authorized to violate tech specs and
10 adjust to the rules in response to an accident is a terribly
11 important issue which needs to be resolved. And just to remind
12 you, the aircraft equivalent situation is that in an emergency
13 a pilot need only say, "I declare an emergency," and then he
14 can violate every rule in the book. Later he is accountable
15 for having done so wisely, but he is authorized to do it
16 automatically.

17 That is quite a different situation, and we need to
18 talk about that.

19 MR. ETHERINGTON: Mr. Chairman, I did not invite you
20 to comment.

21 DR. CARBON: I thought you did an excellent job and
22 I have no additional comments.

23 If there are no further questions, let's then turn
24 to the staff. Vic?

25 MR. STELLO: Thank you, Mr. Chairman. I'm grateful

mte 5

1 to have the opportunity today to come down and talk to the
2 Committee. I have not had an opportunity for quite some time,
3 and there are a number of issues, I think, that have been
4 raised in the summary that I would like to speak to, since I
5 spent quite a bit of time dealing with them.

6 I think this summary was a fine summary that you
7 just heard, and it raised a number of issues that I think are
8 indeed very, very important.

9 One of them I wish to address rather directly, and
10 perhaps by doing so I will be writing part of the summary or
11 a supplement that was suggested to NUREG-0600 about possible
12 misinterpretation. It has never been our intent to point a
13 finger and say that the operators are in fact the cause of
14 this accident.

15 It is my view -- and I think it is shared by many,
16 and I know I have heard Chairman Hendrie also make the
17 comment -- when it comes time to blame individuals and
18 organizations for this accident, that that blame will have to
19 fall on many. It will include -- and I would like to start
20 with, first and foremost, perhaps, the NRC itself. We need
21 to examine ourselves very carefully because we in many
22 respects didn't do the job that we could have and should have
23 done. That could have also prevented this accident.

24 I think the vendor, in terms of what he could have
25 done, could have also prevented this accident. I too believe

1 the operators, by using the basic equipment that was there,
2 could have also prevented this accident. I want to come back
3 and speak to that point a little bit more forcefully.

4 So, to illustrate, if those were the only three that
5 ought to be examined, and each of them could have prevented
6 the accident, then perhaps they each deserve a third of the
7 blame, if that is the right way to characterize it. And I
8 can't say emphatically enough that, because of the limited
9 scope of our report, it unfortunately had the capability to
10 be read in such a way that that was the way it came across.
11 It was not our intent. And I would like to emphasize that,
12 in order to try to find where you come down in terms of that
13 blame, there clearly are other studies that must be finished
14 before we can make that decision.

15 The Kemeny report is now out and it tells the story
16 it does. I have heard some statements made that suggest
17 again clearly an implementation of inadequate operation and
18 management in terms of its responsibility for the accident.
19 And I also think it suggested inadequacies in the system
20 itself. And I think each of you need to read it and have your
21 own reaction to it.

22 I think the Rogovin study will also shed some light
23 on this same issue with regard to blame. So these studies
24 are critical, they are important.

25 Your evaluation and your review is also important

1429 295

mte 7

1 before a final evaluation can be made. So I can't emphasize
2 enough and agree with the summary Harold has just presented
3 to you, that one ought not to do just what has been suggested,
4 say that the blame for this accident lies with that operating
5 staff completely.

6 That is just not our view and I can't emphasize
7 enough that we ought not to allow that conclusion to be drawn.

8 I would be happy to supply you with the letter that
9 Harold Denton and I signed to the Commission, that spoke to,
10 at least in some general way, this particular point and tried
11 to clarify that that ought not to be the interpretation. And
12 if I just might read briefly from part of it. It is a letter
13 dated October 4th, 1979, and if the Committee doesn't have it
14 I will make sure you get a copy. I will check. I think you
15 have a copy. But it says:

16 "Subsequent to the issuance of NUREG-0600, some
17 statements and reports have suggested, contrary to our intent,
18 that inappropriate operator action was essentially the sole
19 cause of this accident. In our opinion, some of these state-
20 men have placed undue emphasis on the operator deficiencies
21 discussed in NUREG-0600. This may have resulted from a
22 misunderstanding as to the scope of the investigation by our
23 Office of Inspection & Enforcement, which is reported in
24 NUREG-0600.

25 "This investigation was limited in its scope to

1429 296

1 the actions of Met Ed over a specific time frame."

2 And then it goes on to explain that there are a number
3 of other studies that have to be done before one can come to
4 that conclusion.

5 I don't know if what I have said puts that in its
6 context. I hope so, because I can't emphasize it enough. Our
7 study was in fact very limited. It is more of the traditional
8 explanation that's done by I&E in a more traditional way.

9 We have, in addition to the study, asked ourselves
10 interally what we learned from the accident, what more is there
11 to be done. And we have transmitted to the Committee, I know,
12 a copy of our lessons learned, in which there are some -- I
13 believe there are about 200 recommendations about what more
14 needs to be done, that look much broader than the immediate
15 implication of the accident itself and NUREG-0600.

16 In addition, the investigators that participated in
17 the NUREG-0600 development have also come up with a number of
18 recommendations and suggestions. I haven't counted them. But
19 there are more than 100 that relate to what we have learned.
20 So there is going to be an awful lot that goes on the table.

21 I think this report is a fine report. It has gotten
22 to the very purpose for which it was intended. It is the
23 result of an awful lot of hard work by a lot of dedicated
24 people. It involved over 200 interviews and it involved
25 15 people essentially full-time -- and I mean nights and

mte9

1 weekends -- from April through August.

2 So the report is a good report. It speaks to the
3 issues it needed to. But one has to be extremely careful that
4 one doesn't get out of the context for which it was intended.

5 One other comment I guess I wanted to make in
6 regard to several other issues that have been raised. One
7 refers to a particular procedure that I personally feel very
8 strongly about, one for which essentially the total fine --
9 that was, the civil penalty imposed on Met Ed relates to a
10 procedure that they had in place, that if they had followed
11 before the accident -- and that procedure was in place for
12 six months -- that that blocked valve would have and should
13 have been closed.

14 Beyond whether you would argue whether it should
15 or shouldn't be closed, having a procedure in a control room
16 for six months that either wasn't being removed, covered,
17 augmented, or changed, is a demonstration of an attitude that
18 I don't think we can tolerate.

19 It is for those kinds of reasons, I think, that
20 the civil penalty on Three Mile Island is what the civil
21 penalty is.

22 There is a number of other things that relate to the
23 accident sequence that are also identified in our notice of
24 civil penalty, for which I recognize there can be considerable
25 debate. We had considerable debate among ourselves as to

1429 298

1 which of these items ought to and ought not to be included,
2 because of the potential, again, misinterpretation of intent.

3 One last comment I would like to make, again related
4 to this same issue, one that was discussed a moment ago, is
5 the issue of the technical specifications. It is my view that
6 once you do have an accident in a plant, the technical speci-
7 fications and the requirements therein are not to be followed.
8 The philosophy which we have built for plants is that you are
9 to have procedures that guide you in the event you have
10 emergencies. Those are the things you ought to try to use to
11 tell you where to go in the event you have an accident and
12 what to do.

13 And, yes, we also have learned that those procedures
14 are not what they should be. They need considerably more
15 work and they are going to get more work and emphasis.

16 The whole question of operator training and the
17 inadequacies the operators have -- again, this whole concept
18 of the human element -- in terms of how much improvement we
19 can get with safety through that mechanism is one clearly you
20 will see in all of the things that we have done since that
21 accident. It is essentially the focus or the theme.

22 There are equipment problems, too, and they are
23 getting attention. But if I had to put my finger on the one
24 issue where I think that that is also the theme and the issue
25 in the Kemeny report, it is that you have to pay attention

1 to the people problem. And that is where we are putting our
2 emphasis, and that is what we will be doing in the future.
3 And I am now taking a lot more time than I thought I was. I
4 thought I only had a few brief comments.

5 And if the Committee has questions of me, I would
6 entertain them.

7 MR. EBERSOLE: One observation. Before you quit
8 leaning on GPU and Met Ed, though, I would call your attention
9 to the fact that I think it is entirely proper that you relieve
10 the operators of what appears to be an undue share of this
11 blame.

12 But if we go into the engineering complex represented
13 in GPU and Met Ed, I believe they should have studied this
14 plant to a greater degree of detail than they did and should
15 have listened harder to what was going on elsewhere, and other-
16 wise prepared themselves to have instructed their operators
17 about the potential inadequacies of their instrumentation
18 system, in a matter in which they did not. I am going to the
19 engineering sector of GPU and Met Ed, not the operators.

20 MR. STELLO: Well, let me just reinforce what you
21 said by citing an example to illustrate this maybe a little
22 more clearly. And I will have to ask someone to help me. I
23 think my memory might fail me. But a question came up some
24 time following the accident whether we ever did or didn't send
25 the Davis-Besse transients in terms of some LER reports and

1 some other reports that we issued.

2 Indeed, we found we did, and that the Met Ed
3 engineering office and the GPU office had them. And the
4 question that came to my mind was: Well, maybe they weren't
5 as adequately written as they should have been. But was that
6 not enough to have engineers ask the question, what does it
7 mean, and get an answer?

8 And I think that is the thrust of what you have said,
9 and that is precisely the point I was trying to make earlier,
10 that that is the kind of thing that has to be examined. And
11 there are problems there, too.

12 MR. EBERSOLE: I agree.

13 DR. CARBON: Other questions?

14 (No response.)

15 DR. CARBON: I guess not for the moment.

16 MR. STELLO: Then if I may, I will turn the briefing
17 over to Mr. Allen, who is going to -- I assume you are going
18 to cover the background.

19 MR. ALLEN: Thank you, Mr. Chairman.

20 I am James Allen. I am the Deputy Director of
21 Region I Office of Inspection & Enforcement. And I will
22 briefly describe the I&E investigation, the scope and methodo-
23 logy.

24 I would like to tell you, though, that we have
25 distributed two memoranda, one dated April 20 and one dated

1 June 8th, to you that does describe in fair detail the scope
2 of the I&E investigation.

3 The Office of Inspection & Enforcement investigation
4 of the March 28th accident at Three Mile Island Unit 2
5 extended over a four-month period. Approximately 3500 man-days
6 of effort were expended by the investigation team and the
7 support functions.

8 The on-site investigation team consisted of 12
9 technical specialists and two investigation specialists drawn
10 from the regional and headquarters staffs of the Office of
11 Inspection & Enforcement.

12 The investigation team was divided into two groups
13 of seven members each, and each group had a team leader. One
14 group was responsible for examining the area of reactor
15 operations, while the other group was responsible for examining
16 the radiological and emergency response actions of the licensee.

17 During the course of the investigation, as Mr. Stello
18 indicated, there were over 200 interviews conducted.

19 The I&E investigation had two basic goals: One, to
20 establish the facts concerning the Three Mile Island accident;
21 and, two, to evaluate the performance of the licensee in
22 association with the accident as a basis for corrective action
23 or enforcement action, as appropriate.

24 The operational part of the investigation covered
25 the time period from the surveillance testing of the

1429 302

mte 14

1 auxiliary feedwater system on March 26th until restart of
 2 reactor coolant pump 1-A about 8:00 p.m. on March 28th. The
 3 radiological part of the investigation was from the beginning
 4 of the accident on the morning of March 28th until midnight
 5 on March 30th.

6 The findings of the investigation team are published
 7 as NUREG-0600. In addition to the report, as Mr. Stello again
 8 had indicated, the investigation team has prepared a list of
 9 items identified during the investigation as individual
 10 concerns, and they have been forwarded to the Office of
 11 Inspection & Enforcement headquarters for evaluation.

e-24

1429 303

12
 13
 14
 15
 16
 17
 18
 19
 20
 21
 22
 23
 24
 25

176 25 01

p. HEE

1 The I&E investigation did not include the
2 following -- and I think this is very important -- any
3 evaluation of the actions of the NRC or any of its
4 organizational components during the course of the accident
5 or during the recovery period, any evaluation of the actions
6 of other agencies during the course of the accident or
7 during the recovery period, any review -- any evaluation of
8 the NRC regulatory process as it relates to the Three Mile
9 Island accident for Lessons Learned.

10 In addition, I&E did not collect information
11 concerning nor evaluate the following: legislative
12 authority of the NRC, rules and regulations of the NRC,
13 safety research, the licensing process, or the inspection
14 and enforcement process.

15 At this time I would like to introduce
16 Mr. Robert Martin, who will discuss the operational aspects
17 of the investigation, and Mr. Al Gibson, who will discuss
18 the radiological aspects. Mr. Martin will discuss the
19 operational aspects first.

20 PROF. KERR: May I ask a question. What is the
21 significance of telling if you did not investigate the
22 legislative authority of the NRC?

23 MR. ALLEN: Again, this was a limited scope of
24 investigation by I&E, and assuming that the other ongoing
25 investigations would look at that process.

1429 304

76 25 02

pvt. EEE

1 PROF. KERR: Well, I guess I am not sure why you
2 would have investigated. I am not sure what you mean.

3 MR. ALLEN: The investigation did not touch on the
4 legislative aspects.

5 MR. JORDAN: I guess what we mean is if there were
6 aspects of the TMI accident that would indicate a change is
7 needed in the Act itself, we were not looking at that
8 aspect.

9 PROF. KERR: Oh, you mean the legal authority that
10 NRC had?

11 MR. JORDAN: That is correct.

12 PROF. KERR: Okay. Thank you.

13 MR. ROBERT MARTIN: Gentlemen, my name is Robert
14 Martin, and I am a section chief in Region 2 of the Nuclear
15 Regulatory Commission office in Atlanta, Georgia, and I was
16 assigned to be the leader of the operational aspects team
17 for th I&E investigation that has generally been described
18 to you. I will not attempt to go through a complete
19 recounting of all of the events as we found them to be.
20 Clearly, you have been dealing with that issue for some
21 period of time.

22 What I will do is summarize some high points and
23 perhaps, although I am not sure it's really needed, just go
24 through some high points of the sequence of activities that
25 occurred and our general findings, and then be prepared to

1429 305

76 25 03

p. 11EE

1 respond to questions as best I can.

2 As was indicated, the period of time of the
3 investigation was from the time of the closure of the
4 emergency feedwater valves on March 26 through the time of
5 the startup of reactor coolant pump 1-A, which reestablished
6 circulation in the core following the accident about 16
7 hours after the start of the accident. The time extension,
8 the previous time of March 26, came about primarily because
9 in the very early stages when we established the time period
10 for the investigation, there is a certain significance
11 attached to those valves, and that was a starting point. We
12 knew that was a clear point at the last time that the valves
13 were manipulated. That was the reason for that particular
14 selection of time sequence.

15 In general terms, the conditions prior to the
16 turbine trip -- and I am sure these are things you are aware
17 of -- the reactor is at 97 percent of the integrated control
18 system in full automatic. The plant was operating under
19 normal makeup and letdown conditions. The volume control
20 was normal.

21 One of the things that we looked at relative to
22 conditions prior to the turbine trip was the maintenance
23 history on the components which were identified as being
24 either apparently or really of great importance to the
25 sequence of events, such as the electrical motor-operated

1429 306

176 25 04

p HEE 1 valve, the safety valves, the feed pumps, the auxiliary
2 feedwater pumps. Their maintenance history, based upon our
3 experience at other plants, did not indicate anything unique
4 in terms of having any higher rate of failure or maintenance
5 problems than other plants we are familiar with. They were
6 in one identified action statement. And it was, I would
7 say, relatively minor in the sense that they were
8 recirculating the borated water storage tank contents. This
9 is a technique for circulation either prior to sampling or
10 to make sure you have a homogenous system.

11 All of their surveillance was current and up to
12 date prior to the accident. Now, I will address that again
13 somewhat later. In fact, at this specific point at which
14 the reactor cooling system unidentified leakage we found to
15 actually be in excess of the technical specification
16 limits. That was because of an error in the calculational
17 method used in the procedure which we came across.

18 So, in fact, they were -- had the procedure been
19 correct and implemented as they had been implemented, but
20 implementing it but had used the correct procedure, they
21 would have determined that in fact they were outside of
22 their unidentified leakage limits, and they would have been
23 forced to shut the plant down.

24 Now, immediately prior, in the four or five hours
25 at the start of the graveyard shift on that day, March 28,

1429 307

76 25 05

p. 1 the 11:00 to 7:00 shift, it turns out that the rate of
2 addition of water to the primary system, which is to
3 maintain the volume available in the makeup tank, did in
4 fact increase substantially. They normally had a makeup
5 rate of about 2600 gallons every shift. That was the normal
6 makeup rate to make up for the total leakage out of the
7 system. It jumped to an equivalent of about 3600 gallons
8 per shift. So, there was a marked increase during that
9 period of time.

10 The EMOV and safety valve tailpipe temperatures
11 were above procedural limits. This has been discussed at
12 some length previously and during the subcommittee meetings
13 that were held. And new procedural guidance was not
14 provided to the operator, so the operators, for some period
15 of time almost since the period of hot functional testing,
16 if my memory serves me right, had in fact been operating at
17 tailpipe temperatures in excess of procedural limits.

18 Staff on duty that night met the technical
19 specification requirements. They had in fact just been
20 coming out of a refueling outage on Unit 1; and as result,
21 they actually had additional staff on hand. There were two
22 shift supervisors on duty, which is not normal staffing for
23 that plant except during a refueling outage.

24 (Slide.)

25 And the last item, item 8, is included only to

1429 308

76 25 06

p. 1 identify the fact that -- oh, by the way, with regard to
2 that previous comment with regard to staffing, we also
3 checked that all the training requirements were up to date.
4 Their retraining of all the staff was up to date. Please
5 note in the context that Mr. Stello mentioned previously,
6 the training was compared against the requirements that they
7 were obligated to have through their FSAR and their tech
8 specs and through the regulations for training requirements
9 on the people.

10 Now, of course, we did look into some of the
11 content of material in those training programs in order to
12 understand some of the operator actions, but with regard to
13 the requirements that were imposed on them during that
14 period of time, all of the training requirements for that
15 staff had been met.

16 DR. MOELLER: The unidentified leakage, was some
17 of that through the relief valve?

18 MR. ROBERT MARTIN: No. That would be considered
19 identified leakage. It was an unidentified leakage that had
20 increased. I had to quickly go back through the numerical
21 evaluation again. I think we would probably ascribe the
22 great majority of that to, based on later events, I think,
23 perhaps to leakage in the letdown and makeup system.

24 MR. EBERSOLE: Was secondary blowdown in
25 operation?

1429 309

76 25 07

1 MR. ROBERT MARTIN: I believe it was. I don't
2 recall them having secured slowdown.

3 MR. EBERSOLE: It is, of course, eating up the
4 secondary feedwater flow, which was nonexistent.

5 MR. ROBERT MARTIN: I am sorry?

6 MR. EBERSOLE: It accelerated the loss of
7 secondary feedwater, if it was left open.

8 MR. ROBERT MARTIN: I am not familiar enough with
9 the isolation logic on that system to know whether or not it
10 would automatically isolate in the event of any transient.

11 All right. There were two auxiliary operators and
12 a foreman working in the condensate polisher area, which is
13 the water purification system for the secondary feedwater.
14 The turbine trip occurred at 0400, 37 seconds, on March 28.
15 It was caused by a loss of all feedwater. We were not able
16 to definitely determine the cause of the loss of feedwater,
17 although we have strong inclinations to believe, based upon
18 looking as we did, that it was related to the actions of the
19 operators working in the area of the condensate polishers.

20 Please understand the way I phrase that sentence,
21 I am not alluding it was an overt action on the part of
22 them, but because of the operations they were conducting.

23 MR. EBERSOLE: Before you leave that, though,
24 wasn't that a sloppy operation which should have been
25 recognized as having the potential to trip the main

1429 510

76 25 08

1 feedwater?

2 MR. ROBERT MARTIN: Based upon their previous
3 history with operations in that area, I would say they were
4 aware of the fact that they had the capability to induce
5 trips working in that area. To speak in terms of a "sloppy
6 operation" --

7 MR. EBERSOLE: I understood it had the potential
8 for getting water into the air system.

9 MR. ROBERT MARTIN: Yes.

10 MR. EBERSOLE: Now, that is not very good
11 practice.

12 MR. ROBERT MARTIN: I would agree that it is not
13 good practice, at a minimum. The reason I am hedging
14 somewhat is that there are many activities that go on in a
15 power plant that, up to March 28, the NRC did not
16 specifically address itself to because they were outside of
17 safety-related systems and safety-related components. I am
18 a little reluctant to assure myself that I am answering you
19 in the context of pre-March 28 inspection activities,
20 considering the eight months that has passed.

21 MR. EBERSOLE: Well, I looked upon it as an
22 analyst plugging in a soldering iron in a control bus.

23 MR. ROBERT MARTIN: I hear what you are saying. I
24 am somewhat reluctant to just respond to it.

25 DR. RAY: And a lot of that goes on.

1429 311

76 25 09

p EE

1 MR. EBERSOLE: We hope not.

2 MR. ROBERT MARTIN: Well, essentially, as you
3 know, there was a turbine trip. That was the nominal
4 initiating event. The detailed sequence is contained in the
5 appendix to the report. If I look at just certain selected
6 aspects, all of which you know, and perhaps I could just
7 very briefly run through, during the -- following the
8 opening of the EMOV, which is an anticipated action
9 following a turbine trip. It failed to reclose. The
10 ultimate effect was a large loss of inventory.

11 (Slide.)

12 The pressurizer level remained high despite the
13 inventory loss. The RCS pressure dropped. The trip reactor
14 coolant pumps tripped at 74 and 101 minutes without
15 establishing natural circulation. That was not successfully
16 achieved. About two hours and 18 minutes after the trip,
17 the EMOV was isolated, but at this point they were not able
18 to either run the reactor coolant pumps and get forced
19 circulation; there was too high a temperature and pressure
20 to be able to establish shutdown cooling, and they weren't
21 solid in the primary system. So that they could not
22 establish natural circulation.

23 So, basically, at this point, even though they
24 isolated the leak, they were now stuck with the difficulty
25 in obtaining any kind of cooling, forced cooling, either by

1429 312

76 25 10

p. NEE 1 natural circulation or by pump circulation of the reactor
2 core.

3 Now, there was some interest, we understood, as to
4 when were we able to establish when core damage occurred. I
5 am very reluctant -- and in fact am not in a position -- to
6 establish when core damage occurred, without a definition of
7 "damage." We can address when the operating staff was aware
8 that there had been fission product release and high
9 radiation levels.

10 I don't think we would have established that at
11 any time during the accident up to and including the time
12 the pumps were returned to operation 16 hours later any
13 member of the operating staff who, as part of a group,
14 believed that the core had been uncovered. They did believe
15 there was fission product release, but during the course of
16 that accident there was not a recognition or an acceptance
17 that the core had ever been uncovered.

18 So, during the period of time that -- basic
19 actions were always with the presumption that they had a
20 covered core. Based on a number of instrumentation reviews,
21 we could say that by 2-1/2 hours into the accident, about
22 6:30 in the morning -- general numbers, 6:30 in the morning
23 -- there seemed to be some evidence of releases of
24 radioactive material from the system. And I think
25 Mr. Gibson will address this to some extent in his review of

1429 313

76 25 11
p. 11EE 1 the radiological aspects.

2 In terms of operator awareness, that occurred at
3 about 7:00 a.m. in terms of the general operating staff,
4 when they attempted a restart of one of the reactor coolant
5 pumps. That was about 6:55, on that order. So, about
6 almost three hours into the accident, when they did that,
7 they received all of the -- basically every radiation alarm
8 in the plant alarmed at that point. And at that point there
9 was a general conviction on the part of the operating staff
10 that they had suffered fission product releases.

11 MR. BENDER: Are you saying that the
12 interpretation of the core --

13 MR. ROBERT MARTIN: I am sorry, sir?

14 MR. BENDER: Are you saying that the main
15 interpretation of the core uncovering came from a
16 recognition that fission products existed?

17 MR. ROBERT MARTIN: No, sir. I am saying that
18 there was no recognition of core uncovering throughout the
19 accident. The recognition of damage, if we include fission
20 product release as core damage, occurred for the operating
21 staff at about 7:00 a.m., about three hours into the
22 accident.

23 DR. SHEWMON: And what caused that? Why did they
24 realize it then?

25 MR. ROBERT MARTIN: That was when they attempted a

1429 314

76 25 12

1 restart of the reactor coolant pump. I think they were able
2 to run it for a matter of -- I don't remember, but it's in
3 the report -- on the order of 19 minutes, I believe, was the
4 time period.

5 And during that period of time, almost immediately
6 after starting the pump, they got every radiation alarm in
7 the plant went off; all of their monitors alarmed, all the
8 radiation monitors alarmed, and at that point they felt they
9 had had a fission product release from the core. But they
10 did not believe that they had had total core uncovering.
11 That did not come up during their deliberations.

12 So, for the remainder of the sequence -- and now I
13 am obviously repeating things you are well aware of -- they
14 attempted to repressurize, to fill the loops, to establish
15 natural convection. That being unsuccessful, they attempted
16 to depressurize in order to use the decay heat system. That
17 similarly was unsuccessful. And they repressurized to fill
18 the loops and start the reactor coolant pumps. That
19 subsequently was successful at about 16 hours after the
20 start of the accident, or at about 8:00 p.m. that evening.

21 DR. LAWROSKI: Did they ever have total core
22 uncovering?

23 MR. ROBERT MARTIN: Total? I think, from what I
24 have been able to understand of analyses that were done
25 elsewhere, my understanding is they had some degree of core

1429 315

176 25 13

1 uncovering. We were never in a position during our review
2 of the information available to the operators to form a
3 conclusion as to whether or not or the extent. Part of that
4 is an input; I am merely indicating that they never alluded
5 to core uncovering during the accident.

6 DR. MOELLER: And the reason, now, for the
7 shutdown of the pump that they restarted was this
8 cavitation, again?

9 MR. ROBERT MARTIN: They received all of the same
10 indicators they had before: loss of flow indicators and
11 vibrations on the pumps. And it was ineffective, and they
12 shut it down.

13 MR. EBERSOLE: You went through G-2 mighty fast by
14 saying they tried to depressurize but couldn't do it. Could
15 you tell me why they couldn't do it? Because I am
16 interested in why, in fact, the RHR system appeared to be
17 unavailable, on the grounds that it should have been
18 available for a LOCA and therefore should have been
19 available for this. It was supposed to be standby, on
20 standby for a LOCA; was it not?

21 MR. ROBERT MARTIN: I believe -- I always get a
22 little uncomfortable moving into the design area -- but I
23 think the decay heat system is more standby in the event of
24 a large LOCA and would only be used in a piggyback mode for
25 a small LOCA to feed water to the high-pressure injection

1429 316

76 25 14

p. 1 pumps because in the small LOCA you have great difficulty
2 depressurizing the system down to the point where you can
3 put decay heat in.

4 MR. EBERSOLE: I understand. But I mean the
5 functional aspect of the decay heat removal system should
6 have been available.

7 MR. ROBERT MARTIN: Oh, yes.

8 MR. EBERSOLE: And why was it not?

9 MR. ROBERT MARTIN: It was available. The
10 functioning system was available. They could not
11 successfully achieve depressurization of the primary system
12 down to the point where they could cut in the decay heat
13 system. It has an interlock on the order of 350 pounds, and
14 they could only bring it down to about 450 to 500 pounds at
15 the low point.

16 MR. EBERSOLE: Now, why couldn't they get it down?

17 MR. ROBERT MARTIN: They couldn't get cooling. It
18 would appear that they could not get sufficient cooling to
19 bring down the pressure in the primary system. They still
20 had enough --

21 MR. EBERSOLE: On natural convection?

22 MR. ROBERT MARTIN: On natural convection.

23 MR. EBERSOLE: So, they locked up because they
24 don't have the main coolant pumps?

25 MR. ROBERT MARTIN: They had neither the main

1429 317

76 25 15

1 coolant pumps, nor did they have natural convection. So, it
2 could not take the energy out of the primary system and
3 depressurize.

4 MR. EBERSOLE: Thank you.

5 MR. BENDER: I might as well --

6 DR. PLESSET: Could I interrupt, Mike?

7 Mr. Moeller reminds me, Mr. Martin, that some
8 people may have to move their cars because 6:25 is the
9 deadline on that. So, maybe we might allow them to do it.

10 DR. MOELLER: Actually, the garage closes at 7:00,
11 but if you've parked on this street, 6:25 departure from
12 here is a good time.

13 DR. PLESSET: If you have your car in a garage,
14 you ought to get it out.

15 MR. BENDER: I don't have one. Can I ask my
16 question, Mr. Chairman?

17 (Laughter.)

18 MR. BENDER: I wanted to follow up on
19 Mr. Ebersole's question for a minute and just ask if more
20 relief valves had been opened up, would they have been able
21 to depressurize enough to have started the reactor heat
22 removal pumps? Has that been established? I never did know
23 whether it was or not.

24 MR. TIM MARTIN: By 10:30 in the morning, the
25 direction had been given to the shift to not secure

1429 318

176 25 16

1 high-pressure injection, so they were running at least one
2 pump delivering at least 100 gpm. There was sufficient --
3 apparently sufficient -- core uncoverage that there was
4 very hot metal in there. With that flow in there, there was
5 not a large enough orifice using both the pressurizer event
6 and the EMOV and its block valve to get the thing
7 depressurized. They were not able to get the flow below
8 400-and-some-odd pounds.

9 MR. BENDER: That's the only valve they could
10 operate?

11 MR. TIM MARTIN: The code safetys cannot be opened
12 from outside. They do have a letdown capability, but
13 everytime they took it above approximately 70 gpm they got
14 high-temperature alarms on their cooling water, and so they
15 cut it back to 70 gpm. So, they were just sitting there
16 draining. They could have used sample lines, but now we
17 have a very high radiation levels; it would have taken them
18 into the auxiliary building. At this point they just could
19 not depressurize.

20 MR. EBERSOLE: Does this exhibit a need for better
21 depressurization capability on the primary loop, like an
22 ADS?

23 MR. TIM MARTIN: I can't speak to that design
24 consideration.

25 MR. EBERSOLE: Well, the BWR, you can always get

1429 319

76 25 17

p. 111

1 down. Here you can lock up. Okay, go ahead.

2 MR. ROBERT MARTIN: I think that falls into the
3 area that everyone is a little aware of. Now we go
4 basically to our conclusions regarding and looking in.

5 (Slide.)

6 Now, as has been discussed, clearly, we looked
7 into the operator actions because during the period of time
8 certainly in the first several hours of that, the only staff
9 members that represented, if you will, the licensee and the
10 licensee's activities were the on-site staff.

11 Basically, part of the background in looking at
12 the aspect of training the operators, the operators had been
13 trained and had been strongly cautioned to avoid a solid
14 pressurizer.

15 MR. EBERSOLE: But that would always be a
16 consequence of a small break in the region of the
17 pressurizer upper head.

18 MR. ROBERT MARTIN: I certainly recognize that
19 now.

20 MR. EBERSOLE: So, the operators were deliberately
21 trained not to respond to a small break in that region?

22 MR. ROBERT MARTIN: I have difficulty phrasing it
23 in that fashion.

24 MR. EBERSOLE: How else would you phrase it?
25

1429 320

1 MR. ROBERT MARTIN: The difficulty I have in phrasing
2 it in that fashion is that they were deliberately trained not
3 to respond to a small break in the upper region of the
4 pressurizer. I think there was not a recognition amongst the
5 training staff and amongst many other people at the time of
6 their training and as of the time of the accident that the
7 result of a break in the top of the pressurizer would be to
8 flood the pressurizer and give the appearance of being solid.

9 MR. EBERSOLE: That is the automatic thing that
10 would occur when they hit the injection system.

11 MR. ROBERT MARTIN: What I am trying to say is that
12 that was not recognized universally, and certainly not at
13 TMI as of the time of that break.

14 MR. EBERSOLE: But every time in a licensing hearing
15 came up, we were always told this would occur and let it
16 occur. You could do nothing about it. The system would go
17 solid.

18 MR. ROBERT MARTIN: I'm sorry. I thought you were
19 speaking of the in-rush as a consequence of the small break
20 on the top of the pressurizer, and that is what I was address-
21 ing myself to.

22 MR. EBERSOLE: No, I'm talking about the solidifica-
23 tion due to high pressure injection.

24 MR. ROBERT MARTIN: All right. In that regard, they
25 were trained to avoid the solid pressurizer and they were

1 trained to be concerned about the possibility of carrying away
2 the safety valves or pumping water through the safety valves.

3 MR. EBERSOLE: They were trained to defeat the
4 automatic safety.

5 MR. ROBERT MARTIN: In that, I would have to agree
6 with your statement.

7 MR. EBERSOLE: Yes.

8 MR. ROBERT MARTIN: By the same token, similarly,
9 the operators were trained that any RCS inventory loss would
10 be seen as a low pressurizer. And there I'm addressing myself
11 to this, to my prior comments. And part of their operating
12 experience based on prior trips that had occurred at the plant
13 was basically that if they recovered pressurizer level in a
14 system with no leaks and no LOCA present, although not in
15 those terms did they recognize it, but if they were able to
16 recover pressurizer level then pressurizer pressure followed
17 shortly behind.

18 So therefore there was a tendency to tend to
19 concentrate on maintenance and control of pressurizer level
20 during such transients, and not a combination of both level
21 and pressure.

22 In reviewing their actions -- and clearly, we have
23 already discussed even this evening the number of critical
24 statements and critical evaluations we have made with regard
25 to operator actions, and that is what a great deal of that

1 report addresses -- there were two items that we would assert
2 to be the most significant actions on the part of the operator,
3 and that was throttling the high pressure injection flow to
4 a minimum when they had low pressure conditions in the reactor
5 coolant system; the other was the failure to isolate the EMOV,
6 which addresses also the prior temperature history of the
7 valve prior to the day of the incident.

8 Now, actions that were also taken which did not, in
9 our view, contribute to the accident as it evolved that day,
10 but might have had adverse effects had the accident taken
11 another direction, was their action to disable the automatic
12 start capability of the emergency diesels after the first
13 high-pressure injection. This was when the diesels had run
14 for approximately 28 minutes and they were tripped by dumping
15 the fuel racks and never reset until about 9:30 that morning,
16 which would make it about five hours after they were tripped.

17 And then a manual remote start capability from the
18 control room was established.

19 MR. EBERSOLE: Is that a plant-unique requirement,
20 to go down and have to manually reset the rack? That is not
21 true of all plants, is it?

22 MR. ROBERT MARTIN: It is true of a large number
23 of plants, when they have an emergency start in which all of
24 the normal interlocks are bypassed except for certain critical
25 interlocks under a safety start condition. So it is not

1479 323

1 atypical.

2 MR. EBERSOLE: I see.

3 MR. ETHERINGTON: At the Subcommittee meeting, I
4 think you hadn't fully explored who did this and why, and I
5 think Mr. Arnold indicated that he knew more about it. Have
6 you any further information on it?

7 MR. ROBERT MARTIN: No, sir, I do not. I do not
8 know if Mr. Arnold has conveyed that further information. As
9 I recall in reading the transcript, he said, we believe we
10 know who did it and we plan to pursue why it was done. I
11 don't recall him saying he planned to report that necessarily,
12 that information, to the Commission.

13 MR. ETHERINGTON: Had you tried to find out, then,
14 or had you not explored it?

15 MR. ROBERT MARTIN: We tried to find out. We found
16 out what had occurred, what actions were taken. We did not --
17 we attempted to some extent to establish who took the actions.
18 But who took the actions was not considered by us to be a
19 critical issue.

20 MR. ETHERINGTON: Except if you found out who, you
21 might understand why.

22 MR. ROBERT MARTIN: That is a reasonable statement.

23 We did not pursue it beyond the point that we felt
24 was reasonable to attempt to ascertain who the person was.

25 And we have not pursued it since that time.

1429 324

1 DR. SIESS: Did you assume or do you know that it
2 was a member of the operating staff?

3 MR. ROBERT MARTIN: We assumed that it was a member
4 of the operating staff, but that would not necessarily be a
5 licensed operator, but a member of the staff that was on duty
6 as part of the operating staff. Because it occurred -- it
7 would have been about 4:40 a.m., and there was a limited
8 number of staff consisting of primarily the operating staff
9 and some auxiliary people during that period of time. And it
10 is a locked building requiring a security key for access. And
11 so therefore it would have been a group of individuals having
12 authority to have access in that fashion.

13 MR. ETHERINGTON: Does automatic start involve
14 moving the rack?

15 MR. ROBERT MARTIN: Moving the rack?

16 MR. ETHERINGTON: Yes. What does automatic start
17 do?

18 MR. TIM MARTIN: The rack controls the fuel
19 injectors into the diesel. If it is not connected to the
20 governor, it will not function. The connection link between
21 the fuel racks and the governor is tripped out of the way by
22 an overspeed trip or it can be done manually.

23 MR. ETHERINGTON: I see.

24 MR. TIM MARTIN: What was done here was that link
25 was broken.

1 MR. EBERSOLE: Well, aren't there designs that can
2 recall the fuel rack to its normal position?

3 MR. TIM MARTIN: Not remotely, sir.

4 MR. EBERSOLE: No designs?

5 MR. TIM MARTIN: If you trip on an overspeed trip,
6 you certainly want the operator to go find out why.

7 MR. EBERSOLE: Is that the rationale?

8 MR. TIM MARTIN: I believe so. I would not want to
9 remotely restart something that had tripped on overspeed.

10 DR. SHEWMON: I understand that the German counter-
11 part of this same plant, when they license it, has that EMOV
12 isolating automatically. I realize that design is not your
13 part.

14 Have you heard why the NRC does not require that
15 same automatic?

16 MR. ROBERT MARTIN: No. I would feel very uncomfortable
17 even attempting to conjecture why.

18 DR. SHEWMON: If I wanted to find out, what part of
19 the NRC should I ask?

20 MR. ROBERT MARTIN: I would presume the licensing
21 function.

22 MR. JORDAN: The licensing function is correct.

23 (Slide.)

24 MR. ROBERT MARTIN: Falling into that same category of
25 actions that were taken which did not affect the sequence of

1 events and the outcome of this particular incident, but also
2 gave us concern because, had the incident gone in another
3 direction it might have been a problem was that during the
4 very early period -- and we are not able to ascertain precisely
5 when this occurred, but we were able to ascertain that during
6 the early depressurization period they isolated the core flood
7 tanks, they closed the EMOVs on the core flood tanks during the
8 first low pressure period.

9 Now, the best we can ascertain is that the rationale
10 was that they did not need the water because they had a full
11 pressurizer and therefore they had a full system, and they
12 didn't need any more water and that could have just complicated
13 things. So they isolated the core flood tanks.

14 They were subsequently unisolated -- and again, I
15 am working on my memory. I don't think that we have ever been
16 able to ascertain, either, when they were isolated, except
17 that the general time frame, and that they were in fact
18 unisolated, because later in the day, when they went to the
19 low pressure period, they did in fact get a partial discharge
20 from the core flood tanks.

21 Now, if we look at the management actions, which
22 was clearly management being a part of the licensee organiza-
23 tion -- if we look at the management actions that took place,
24 and by management we include those people who came to the
25 site in order to support the activities -- that is, personnel

1 of the utility, Met Ed, that arrived at the site to support
2 the emergency recovery -- now, in general terms, we think
3 the plant parameters were in general fairly effectively used
4 in the attempt to recover.

5 Now, you must realize that basically plant management
6 arrived after the reactor coolant pumps had been tripped and
7 during the period where no natural circulation had been
8 established. So basically they were arriving at a position
9 where they had neither natural nor the capability for forced
10 circulation.

11 Now, the exceptions to that was that there was a
12 general disbelief of high system temperatures as displayed
13 by the RTD displays for reactor coolant temperatures; and
14 also, any information that they had obtained off the in-core
15 thermocouple system.

16 So it was basically a general disbelief of the high
17 system and in-core temperatures.

18 When they evaluated, later in the day, the effect of
19 the core flood tanks, it was not recognized that both of these
20 core flood tanks have a large loop-type seal, not as they are
21 drawn in the FSAR drawings, which show basically a straight
22 line from the bottom of the tank and then into the vessel.
23 There is actually, I think, in one tank about a 14-foot loop
24 seal, and I think it is about 16 foot in the other tank. So
25 that when they interpreted the small discharge that occurred

1 from the core flood tanks during the depressurization period
2 as being indicative that the system was solid, and their
3 recognition of the loop seal -- it would well be possible to
4 limit the discharge from the tank without the system being
5 solid. But that was a conclusion they drew.

6 PROF. KERR: Bob, could you speculate on why they
7 disbelieved this temperature indications? Was it because they
8 simply didn't think there was any way you could get that
9 temperature? Or would you prefer not to speculate?

10 MR. ROBERT MARTIN: One of the reasons given to us
11 was the fact that they had, all the individual RTDs, had moved
12 outside the callibrated range. They were indicating levels
13 in excess of 620, which was the limit of the callibration
14 procedure. And therefore there was a conviction -- I won't
15 say a conviction, but a feeling, if you will, that: I don't
16 know what they are telling me, because now they are outside
17 the range.

18 Now, there was an auxiliary recorder in the control
19 room which had an 800-degree display capability, and those
20 same RTDs were displaying on that recorder. I do not recall
21 any reference by the staff to the fact that they had pursued
22 looking at that particular recorder, but they were working off
23 the normal displays for the RTDs

24 Similarly, the in-core thermocouples were addressed
25 in the same fashion. The numbers being received or

1429 529

1 displayed -- well, not displayed, because they had exceeded
2 the display limit of 700 degrees Fahrenheit. So therefore,
3 when they took data by using a resistance box and determining
4 what those RTDs were telling them, they were again concerned
5 because the in-core thermocouples are not safety grade equip-
6 ment.

7 And their rationale was: Since it is not safety
8 grade equipment, I don't know what they are telling me.

9 The one thing with regard to the in-core thermo-
10 couples, recognizing -- the emergency staff which was directing
11 emergency activities and the operating staff that was carrying
12 out orders, it was not -- we know how much data was taken by
13 the instrument technicians who read the in-core thermocouples.
14 We do not know fully how much data was transmitted in to the
15 management people who were making management decisions. The
16 management people allude to the fact that they received a few
17 numbers from zero to 2,000 degrees Fahrenheit.

18 The technicians, at the other end, allude to the
19 fact that they had taken substantially more data. We really
20 were not able to track whether in fact it all got in or just
21 a part of it got in.

22 And then the pressure spike in the building, which
23 occurred about ten hours, about nine hours and 50 minutes into
24 the event, which turned out later to have proven to be a
25 hydrogen de~~te~~tonation.

1429 330

1 MR. EBERSOLE: Excuse me.

2 MR. ROBERT MARTIN: That was not pursued aggressively
3 by the people on the staff at the time.

4 MR. EBERSOLE: Could you briefly tell me from what
5 point that hydrogen got into the containment?

6 MR. ROBERT MARTIN: All during -- if you will permit
7 me to make reference to a thing we had no knowledge of in terms
8 of the report, and that is that hydrogen had been generated
9 some time during the two, three, or four hours after the start
10 of the accident.

11 MR. EBERSOLE: I know.

12 MR. ROBERT MARTIN: And there was a continuous
13 period during one high pressure phase which lasted approximately
14 four hours of venting off the reactor coolant system. Then,
15 similarly, they did a major venting of the reactor coolant
16 system as they came down to depressurize.

17 MR. EBERSOLE: That went out through the PORV?

18 MR. ROBERT MARTIN: That would be my conclusion as
19 to the manner in which it got into the containment. And it
20 was shortly after they had reached that point of minimum
21 pressure in the RCS when the detonation occurred.

22 MR. EBERSOLE: I think what I'm trying to get at,
23 it had to bubble through the water in the pressurizer to get
24 out, which it did.

25 MR. ROBERT MARTIN: I would have to presume that

1 was the only mechanism for it getting out. We know of no other.
2 We can think of no other mechanism right now. Now, it would
3 either be the PORV or the vent valve on the pressurizer. At
4 various times, they would swing between the vent valve on the
5 pressurizer and the PORV, because there was concern about
6 the reliability of, what if the PORV fails again by manipulat-
7 ing it too much. So there was some degree of movement between
8 those two valves.

9 DR. MOELLER: If the pressure spike occurred, as you
10 say, at about ten hours or nine hours and 50 minutes, what
11 would you have assumed they would have done if they had
12 recognized this?

13 MR. ROBERT MARTIN: Our comment was really addressing
14 whether or not management took as much advantage as they could
15 of information that was available to them. We did not try to
16 go into the conjectural, we really didn't. We would have had
17 to start that back at minute one, and I think we never would
18 have completed the fault tree under that condition.

19 Now, in terms of off-site interfaces, our general
20 conclusions are that the off-site interfaces with the licensee
21 engineering staff, with Babcock & Wilcox, with the architect-
22 engineer, and with the NRC -- some degree of interface had
23 been established or attempted. And we find that in general
24 all of these were in effect, they really were, to the course
25 of actions taken during the course of the accident, with two

1 very specific exceptions.

2 There were specific individuals in Met Ed having
3 contact with the plant at the vice president level, and we
4 think we can identify at least two clear decisions that were
5 reached as a result of directives from those people. I would
6 say if you give me the proviso that that particular relation-
7 ship is a little outside of what I am alluding to in the
8 licensee engineering staff, then I would say in general the
9 off-site interfaces did not really affect the course of events
10 that were taken, or actions that were taken, during the
11 accident.

12 The two exceptions to that were the order from the
13 vice president of Met Ed to shut down the steam dump. I don't
14 recall the exact time. We have it postulated. But for
15 something on the order of four to six hours they had lost the
16 turbine because of circ water. They had lost the vacuum on
17 the turbine, so therefore steam dump was not available; and
18 therefore that mechanism for connection to the ultimate heat
19 sink was not available.

20 They shut down the atmospheric steam dump. That
21 eliminated the atmosphere as a potential heat source release.

22 So in both of those cases there was, I think, on the
23 order of a six-hour period in which there was no ultimate heat
24 sink, if you will, available. All the energy was having to
25 be disposed of in other fashions.

1429 333

1 MR. EBERSOLE: When they blew the dump tank early on --

2 MR. ROBERT MARTIN: The reactor coolant drain tank?

3 MR. EBERSOLE: The one that takes the discharge from
4 the PORV.

5 MR. ROBERT MARTIN: Right.

6 MR. EBERSOLE: Was that -- was the position of that
7 disk in such a point as to drain the dump tank?

8 MR. ROBERT MARTIN: The disk is mounted on the top
9 of the tank.

10 MR. EBERSOLE: So it would have remained full of
11 water?

12 MR. ROBERT MARTIN: Except for whatever energy content
13 was in that water and whether or not it would be vaporized.
14 But it of itself will not automatically drain that system.

15 MR. EBERSOLE: Well, did the tank drain?

16 MR. ROBERT MARTIN: I don't know.

17 MR. EBERSOLE: I'm looking toward --

18 MR. ROBERT MARTIN: You see, we had no level indica-
19 tion on that tank. We had pressure indication.

20 MR. EBERSOLE: Well, it may well be a case where it
21 could drain and then it would subsequently fill with hydrogen
22 and oxygen and have the possibility to explode as a vessel.

23 MR. ROBERT MARTIN: I see the route you are going in
24 and I cannot really address definitely whether we know whether
25 or not that tank drained or was emptied during the course of

1 the accident.

2 MR. EBERSOLE: Well, it would afford you to have
3 an opportunity to have a vessel explode.

4 MR. ROBERT MARTIN: I believe, as I recall the
5 drawings, the rupture disk is mounted on the top of that tank.

6 MR. ETHERINGTON: The tank does have a level indica-
7 tion normally, doesn't it?

8 MR. ROBERT MARTIN: I am trying to remember very
9 quickly the controls on that. Tim, can you recall?

10 MR. TIM MARTIN: It does have a level indication,
11 temperature indication, and pressure indication. It so hap-
12 pened that the pressure was patched into the reactimeter, so
13 we have that information. But I don't think we have the
14 others.

15 MR. RAY: You say that the pressure spike was not
16 pursued. When were they aware of it? Did they realize when
17 it happened?

18 MR. ROBERT MARTIN: It depends upon who you are
19 speaking of. There was one shift supervisor who was standing --
20 happened to be positioned in front of the reactor building
21 pressure indicator at the same time that an operator opened
22 the EMOV in a further attempt to try to depressurize the
23 primary.

24 Coincident with him opening the EMOV, the shift
25 supervisor saw the pressure spike occur in the reactor building.

1 And he concluded that apparently they were discharging so much
2 steam into the building that we had better stop using the EMOV.
3 And he went and transmitted the information, as best as we can
4 establish, to the plant manager, that, I think we had better
5 stop using the EMOV, because it appears we are getting pressure
6 spikes.

7 He did not relate the exact nature of the pressure
8 spike.

9 Another shift supervisor was in a different location
10 when it went off, that is, when the pressure spike occurred.
11 They also had two electrical buses go out. At the same time,
12 they got containment spray and all of the alarm associated
13 with high pressure in the containment and the actuation of
14 containment spray.

15 Him, seeing the electrical panels go off, presumed
16 that they were in the same general area as the instrumentation
17 pressure switches which initiate containment spray. And he
18 thought he had an electrical problem, and he actually discharged
19 or dispatched some instrument techs to go down and see what
20 the electrical problem was.

21 They apparently are unrelated to each other, but they
22 occurred. And I'm saying only apparently or relatively
23 unrelated.

24 But there were two interpretations of the same event.
25 But not all of the information ever got fed back to management.

1 MR. RAY: It wasn't recognized?

2 MR. ROBERT MARTIN: It was not. It was not completely
3 fed back in terms of an information chain. A part of it, with
4 an interpretation by the operator of the information, was fed
5 back.

6 Now, also during that period, the plant manager was
7 on his way out of the building and going to brief the
8 Lieutenant Governor. And it virtually occurred while he was
9 getting ready to leave the plant.

10 So there were a number of things going on at the same
11 time.

12 PROF. KERR: Let me make sure I understand your
13 statement. There was one person who interpreted the pressure
14 spike as an electrical equipment malfunction?

15 MR. ROBERT MARTIN: No. He was not looking at the
16 reactor building pressure recorder. He saw the alarms go
17 off indicating containment spray had started. He also saw
18 the electrical panel fault, and those panels are located in
19 the general area where the pressure sensors which trigger
20 containment spray are located. So he thought containment
21 spray had started because of an electrical panel fault. So
22 there were just two actions being taken for different
23 reasons.

24 PROF. KERR: Thank you.

25 MR. EBERSOLE: I think we had a happy state of

1429 337

1 affairs, in that the containment valves were preclosed; is that
2 correct, they were standing closed?

3 MR. ROBERT MARTIN: I don't want to say that
4 unequivocally. The containment had been isolated. Clearly,
5 the containment had isolated when the --

6 MR. EBERSOLE: Well, under placid conditions it had
7 been isolated.

8 MR. ROBERT MARTIN: I don't know whether the purge
9 valves in fact had been closed prior to the start of the
10 incident altogether. But containment isolation had occurred
11 early.

12 MR. TIM MARTIN: A couple of things I would like
13 to add.

14 In reviewing the computer traces, the loss of the
15 motor control centers, the electrical buses, occurred some time
16 after the detonation. And we believe that that was associated
17 with the loads on those buses, which happen to be in the
18 containment, that got sprayed down; and that he connected
19 the two.

20 It is unfortunate because they were separated in
21 time. The various things that occurred during this period --
22 one of them was that the plant manager, who was getting ready
23 to leave with other people, heard, and I quote, "a double
24 thump." And he is quoted as saying, "What was that?" And
25 someone conveyed to him, "Oh, it was probably the ventilation

1 dampers that are being shifted," because they were changing
2 the isolation conditions of the control room.

3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

1429 339

76 27 01

K. HEE

1 Other people, seeing these spikes on the
2 instruments, thought they might be electrical noise. No one
3 really connected the events together. They did allow the
4 spray pumps to run for about five minutes, and that was
5 simply one individual who wasn't ready to turn those off
6 until he was satisfied whatever had caused it was no longer
7 there.

8 MR. LEWIS: Could I understand one point about the
9 one guy who actually saw the pressure increase and
10 interpreted it as a steam discharge through the PORV? I am
11 missing a point. A steam discharge would make a spike or a
12 step increase in pressure in the containment?

13 MR. ROBERT MARTIN: The basic thrust, he was
14 saying, was that as soon as the valve opened, he saw the
15 pressure spike. So he is getting spiking pressure in the
16 containment every time -- in his mind, whenever they open
17 that valve, we'd better stop opening that valve.

18 MR. LEWIS: You led me to believe that he
19 interpreted it as a discharge of steam through the valve.

20 MR. ROBERT MARTIN: No one thought of anything
21 else going through that valve except steam.

22 MR. LEWIS: Right. But I'm trying to understand
23 whether a discharge of steam for that valve would lead to a
24 spike or to simply an increase in containment pressure.

25 MR. ROBERT MARTIN: I cannot answer why he would

1429 340

76 27 02

KHEE

1 believe, or what he felt had occurred to the system, which
2 would now suddenly make the containment exhibit pressure
3 spikes when he opens the PORV.

4 MR. LEWIS: What I'm having trouble with is of
5 thinking of any level.

6 MR. ROBERT MARTIN: I would have to get into his
7 mind and understand why he made that conclusion.

8 PROF. KERR: You may have difficulty believing a
9 lot of things he was seeing at that point.

10 MR. EBERSOLE: Excuse me, the time pressure
11 response must have been rather slow. So the spike was
12 probably a lot more abrupt than it was seen on the
13 instrument; is that true? Do you know what the time
14 constant response was?

15 MR. ROBERT MARTIN: Unfortunately that was the
16 kind of answer I was going to give you. I don't know what
17 the time constant was.

18 MR. EBERSOLE: Well, you may have only seen the
19 instrument time constant and not the real time.

20 MR. ROBERT MARTIN: Well, what I'm trying to
21 remember is: are the same detectors -- and I don't know if
22 this is the case -- is the same detector used for the
23 recorder as are used in the starting logic for the safeguard
24 system which initiates containment spray and the pump
25 operation? Because on the computer output we were also able

1429 341

76 27 03

k HEE 1 to indicate -- get a sequence in terms of seconds, as to the
2 duration that these various safeguards conditions were
3 established and then reset.

4 MR. EBERSOLE: Well, there's no particular need
5 for it to be fact, because it wasn't anticipated that it
6 would measure this thing.

7 MR. ROBERT MARTIN: I would have to agree, but I
8 do not know what it is.

9 MR. ETHERINGTON: I have another question. At the
10 subcommittee meeting, it was mentioned during speculation as
11 to what would cause the pipe vibration, that there is always
12 water hammer when you have a turbine trip.

13 MR. ROBERT MARTIN: Yes, sir.

14 MR. ETHERINGTON: Can you say a little bit more
15 about that?

16 MR. ROBERT MARTIN: No, sir, the gentleman -- I
17 would have to defer to the gentleman who said that. His
18 background credentials include having been an operations
19 supervisor at a three-loop Westinghouse nuclear power plant,
20 and also having extensive experience in the power industry
21 in general. I have heard such comments made by others that
22 you always get some shaking pipes on -- I know he used the
23 expression "water hammer," and I have to defer to his
24 expression, but that you always get shaky pipes or
25 oscillation in the turbine building after every turbine

1429 342

75 27 04

k. HEE 1 trip.

2 MR. EBERSOLE: Well, the main steam stop valve is
3 a monster. It's like a cannon going off.

4 MR. ROBERT MARTIN: Again, what I am doing is
5 deferring. I cannot shed any further light than what the
6 gentleman told you at that point.

7 MR. ETHERINGTON: You agree, Jesse, that it is
8 common?

9 MR. EBERSOLE: Yes, it is absolutely astounding
10 what takes place when the stop valve trips. It would
11 frighten you to death.

12 DR. SEISS: It is water hammer, and not just noise
13 and vibration?

14 MR. EBERSOLE: This is a huge gate valve.

15 MR. LEWIS: You're saying it's not water hammer?

16 MR. EBERSOLE: No, it is impact of steel on
17 steel.

18 MR. ROBERT MARTIN: I think -- I don't want to
19 speak or modify the words that the man used, whether he
20 meant water hammer in the same exact terminology from a
21 technical standpoint that you mean it, or he was talking
22 more in terms of jargon, I cannot address that.

23 DR. CARBON: Any other questions of Mr. Martin?

24 (No response.)

25 DR. CARBON: Well, thank you. I would like to

1429 343

76 27 05

x ● HEE 1 raise a question following his presentation that I think I
2 want to address to you, Ed. It has to do with the breadth
3 or scope of NUREG-0600. The emphasis in 0600 on procedures
4 -- and it pretty much, basically, or essentially compares
5 the action of the operators and how they did or did not
6 follow the procedures -- and yet there was extensive
7 evidence that something else was going wrong, core damage,
8 fission products being released. There were radiation
9 monitors on the scale. At one point they got temperature
10 readings of 2600 degrees. They read a radiation monitor and
11 got something over 1000 R per hour.

12 But during the first 24 hours, they almost didn't
13 mention this. In fact, if you look at the sequence of
14 events, you find that the words "fuel failure" or anything
15 like that, are mentioned only about once, I think, in the
16 first 24 hours.

17 My question to you is: why, in this
18 investigation, in NUREG-0600, didn't you explore and look
19 into one question? Why did the operating staff, and not
20 just the operators, fail to recognize that there was core
21 damage? And why did they fail to recognize that the
22 procedures that they were following weren't appropriate and
23 didn't apply? And then subsequently or consequently, why
24 did they fail to recognize that, Gee, they have got to do
25 something quite different than follow some procedure that

1429 344

76 27 06

K. HEE 1 was not applicable there?

2 My question, again, is: why didn't O600 look into
3 that subject?

4 MR. JORDAN: Dr. Carbon, I think the answer is in
5 the charter of the O600, in trying to establish facts of
6 when they had the opportunities and then what procedures and
7 training they had in terms of using those opportunities.
8 But as far as trying to get into the thought process of the
9 operator, we did not explore that.

10 DR. CARBON: But it seems like it is thought
11 process but also training and so on. And I would think you
12 would have looked into it.

13 MR. JORDAN: I think we established that the
14 training was inadequate in those areas.

15 DR. CARBON: All the way through from the
16 operator, the shift supervisor, the engineers, the
17 management, the plant superintendent.

18 MR. JORDAN: I would think so, because they should
19 have recognized the degree of damage. What Bob was
20 addressing earlier when we tried to cover that was insofar
21 as fuel damage, I think the operators believed that they had
22 gap gas released. And I think that is what the NRC staff
23 believed on the first day, based on bits and pieces of
24 information.

25 But the true magnitude had not been conveyed

1429 345

76 27 07

K. HEE 1 throughout either the licensee, staff, nor certainly back to
2 the NRC.

3 DR. CARBON: And it was deliberately a focus of
4 your report not to look into that kind of thing?

5 MR. JORDAN: It was not the focus of the report to
6 probe into that thought process, or to assign a blame in
7 that fashion.

8 MR. LEWIS: May I just ask -- and I'm tending to
9 react these days -- everyone says the operator training was
10 inadequate and you just said it -- I wonder what we mean by
11 that. Do we mean that they should have had a college
12 education? Or is that simply an acronym for saying we think
13 they should have done better in this accident?

14 MR. JORDAN: Well, I think clearly the staff
15 believes that the accident was preventable, and that the
16 combination of design, training, management and operator
17 action and procedures, all strung out together in this
18 particular case, to cause an accident.

19 MR. LEWIS: I know that the actions were
20 inadequate. It is just the translation of that into the
21 training was inadequate, that I would really like to be able
22 to spell out more in the period to come now, because many
23 people don't go beyond it. And I'm not clear, again,
24 whether you mean that if they had known more about the steam
25 tables, or if they had been trained for this specific

1429 346

76 27 08

K. HEE 1 accident, which is hopeless, because there are many
2 different kinds of accidents -- or they had just spent more
3 years on the job -- I just don't know what is meant by
4 saying that their training was inadequate.

5 MR. JORDAN: Okay. I think that the training,
6 that at least I'm talking about, in understanding the basic
7 principles of the operation of the plant.

8 MR. LEWIS: I see, training on how plants work?

9 MR. JORDAN: Yes.

10 DR. SEISS: If a man with a Ph.D. had been
11 through the same training course they had, do you think they
12 would have done better in the accident?

13 MR. JORDAN: I think, certainly, if the Ph.D. had
14 been in Nuclear Engineering and Core Analysis, yes.

15 DR. SEISS: But what about mechanical engineering?

16 MR. JORDAN: I would hope so.

17 DR. CARBON: I think it is more someone knowing
18 something about thermal hydraulics than nuclear engineering
19 per se.

20 MR. EBERSOLE: Just basic plumbing, where the
21 water level is.

22 MR. ETHERINGTON: I think we should remember that
23 three different individuals forecast this accident, not
24 necessarily at Three Mile Island, and the accident was
25 forecast not from the basis of stupid operators,

1429 347

76 27 09

1 undereducated operators, or undertrained operators, it was
2 based entirely on something else.

3 I agree that the operators need more training. I
4 am not sure that I agree that we should have recognized that
5 in advance.

6 DR. CARBON: Other questions?

7 (No response.)

8 DR. CARBON: Go ahead, then.

9 MR. GIBSON: My name is Al Gibson. I am section
10 chief in Region II of the office of Inspection &
11 Enforcement. And I was assigned as team leader for the
12 radiological aspects of the I&E investigation of the TMI
13 accident.

14 (Slide.)

15 You were told earlier that one of the objectives
16 of the I&E investigation was to determine facts and assess
17 licensee performance regarding the radiological aspects. We
18 sought to assess performance and determine facts relative to
19 emergency preparedness prior to the March 28th accident, and
20 then to assess the response to the in-plant and
21 environmental radiological conditions that existed following
22 the accident.

23 (Slide.)

24 The scope of our investigation can really be
25 explained in a two-fold fashion. First, it was to

1429 348

76 27 10

k. HEE 1 investigate the emergency preparedness that existed prior to
2 the accident, and secondly we investigated the response that
3 the licensee took from the time of the accident until
4 midnight on March 30th — which is a little longer interval
5 of time than the operational aspect included.

6 (Slide.)

7 We conducted our investigation from a trailer at
8 the IMI site, from the period of April through July of this
9 year.

10 (Slide.)

11 The team make-up consisted of specialists in
12 various technical areas. As you will see here, each
13 specialist was from an NRC regional office. Incidentally,
14 Mr. Yuhas is with us today.

15 (Slide.)

16 Sources of information were licensee logs, licensee
17 records, transcripts of telephone communications,
18 discussions with plant staff and many interviews.

19 (Slide.)

20 I would like to very briefly summarize our
21 findings relative to pre-accident conditions. On the
22 morning of March 28th, the normal radiation and protection
23 and chemistry staff was on-site. This consisted of about
24 four technicians. The normal staff at IMI was 39
25 individuals. The normal Health Physics staff was 39

1429 349

76 27 11

k. WEE . . 1 individuals, which included a superintendent of
2 administration and technical support, supervisor of
3 radiation protection and chemistry and supervisor and a
4 radiation protection foreman, and 20 technicians. Seven
5 emergency drills were conducted by the licensee in 1978 to
6 evaluate the adequacy of emergency response capability. One
7 of these drills was observed by an NRC inspector.

8 Critiques were held following each drill to
9 discuss results and define action to correct problems
10 identified. We found in review of these critiques that most
11 identified problems had been corrected to the extent that
12 they did not recur following the March 28th accident.

13 Exceptions to this were an environmental iodine
14 survey instrument was taken from the plant to Goldsboro for
15 use without first verifying that it was operational, and a
16 similar problem had been identified during an earlier
17 drill. Another example was that during a previous drill the
18 need for operations personnel to review site emergency
19 criteria was identified. And as I will discuss later, there
20 was some confusion among operations personnel regarding
21 classification of this event as an emergency.

22 We did review emergency plan training that had
23 been conducted prior to the accident. We found that in
24 addition to drills, the site emergency plan in implementing
25 procedures for personnel who would be assigned emergency

1429 350

76 27 12

ka HEE 1 responsibilities had been carried out. With few exceptions,
2 this training had met the requirements of the site emergency
3 plan. One exception was that off-site monitoring team
4 members had not been trained in the use of instruments which
5 would be used for measuring airborne iodine in the
6 environment. And this lack of training did cause some
7 problems during the accident.

8 We reviewed routine radiation monitor training.
9 Although most of the radiation chemistry technicians
10 received some technical training in their job functions
11 shortly after beginning work with the company, no retraining
12 program had been implemented to maintain their proficiency.
13 Most technicians interviewed expressed concern about their
14 technical competency and their responses to technical
15 questions by investigators revealed the need for more
16 training.

17 We reviewed supplies of radiation protection
18 equipment. Although equipment and supplies were adequate to
19 support normal plant operations, shortages did occur
20 following the accident.

21 In summary, less than one-half of the portable
22 radiation monitoring instruments were operational at the
23 time of the accident, and the 50 self-contained breathing
24 apparatuses and 175 full-face respirators that were
25 available were not adequate to provide respiratory -- all of

1429 351

176 27 13

1 the respiratory protection needed during the accident
2 recovery operations.

3 DR. MOELLER: Were those survey instruments
4 checked out during each of the seven drills?

5 MR. GIBSON: That specific problem was not
6 identified during the drills. Emergency instruments were
7 maintained. Instrumentation dedicated for emergency use was
8 maintained in emergency kits, and these kits had been
9 checked out during the drills. Now, there were only four
10 kits and the instrumentation in these kits certainly would
11 not be adequate alone for recovery operations.

12 DR. MOELLER: Well, the answer -- did they have
13 records on them, when they were calibrated?

14 MR. GIBSON: Yes, the 50 percent that were not
15 operational were in the shop for some kind of calibration or
16 maintenance.

17 MR. EBERSOLE: Are you the folks who are keeping
18 up with the accumulated dose on the plant components now?
19 The soup has been sitting in there for nearly nine months.
20 A case in point -- let's say the main coolant electrical
21 penetrations have been getting a dose of some sort.

22 MR. GIBSON: No, sir. We have not.

23 MR. EBERSOLE: It might be extremely important
24 that these penetrations not be challenged by an inadvertant
25 closure to those switching pumps, because we would surely

1429 352

76 2 / 14

K. WEE 1 see a short-circuit.

2 MR. GIBSON: Yes, sir, I understand your comment.

3 MR. EBERSOLE: Who's keeping up with that sort of
4 thing?

5 MR. GIBSON: I don't know the answer to that. Ed,
6 do you?

7 MR. EBERSOLE: This is the accumulated dose on
8 such matters as the penetrations, and other significant
9 parts of the containment itself. Is this dosage
10 accumulating to any significant level?

11 MR. JORDAN: I'm not personally knowledgeable about
12 that. The staff that is doing the TMI recovery reviews at
13 the site is tracking that as a part of the post mortem. We
14 will be looking at the equivalent performance in terms of
15 their accumulated dose.

16 MR. EBERSOLE: Do you know whether or not the
17 plant is carefully locked out against inadvertant
18 introduction of heavy electrical currents into the now-dead
19 motors inside the plant?

20 MR. JORDAN: I don't personally know that, but the
21 procedures are being reviewed and approved by the NRC at
22 this point, rather than simply sample reviews in the normal
23 operating plant.

24 MR. EBERSOLE: Well, it certainly would be prudent
25 to be sure that the cables are almost sawed in half.

1429 353

76 27 15

k. HEE 1

2 MR. JORDAN: Yes, I agree. I'm just simply not
3 personally aware of that aspect. I am not following the
4 recovery efforts at this point.

5 MR. EBERSOLE: Okay.

6 DR. MOELLER: Mr. Gibson, is there anything in the
7 tech specs that limits the number of instruments that can be
8 in the shop for maintenance and calibration at a given time?

9 MR. GIBSON: No, sir. The routine environmental
10 monitoring program required by tech specs was in effect, and
11 this consisted of environmental air samplers at eight
12 off-site locations and TLDs at 20 locations. We reviewed
13 the status of the rad waste system. The reactor building
14 sump was allowed to pump water to the auxiliary building
15 sump tank. About 800 gallons of surge capacity remained in
16 this tank. Other tanks in the liquid rad waste system were
17 about 60 percent full.

18 The auxiliary building and fuel handling building
19 ventilation system were operating normally, exhausting air
20 to the plants vent via charcoal absorbers and high
21 efficiency filters. The waste gas system, including the
22 vent header, had not been leak-tested since prior to unit
23 operation. But such testing is not required by any
24 regulatory requirement. Small leaks from this system would
25 not normally be of great radiological significance, but
following the accident were probably the prime contributors

1429 354

76 27 16

k HEE 1 to off-site dose.

2 (Slide.)

3 The emergency director, who was the plant manager,
4 when he arrived on-site shortly after 7:00 o'clock, was
5 responsible for classifying the situation as an emergency in
6 accordance with conditions in Table I of the Emergency Plan,
7 and for initiating actions according to this Emergency
8 Plan, and the implementing procedures, and his own best
9 judgment. The Emergency Plan requires the actions listed in
10 Table I be considered for each type of emergency but that
11 these actions or other actions be taken only if they are
12 appropriate.

13 Now, the first criteria listed in Table I for the
14 site emergency plan to have been met for site emergency --

15 (Slide.)

16 -- was Criterion C, which is a loss of reactor
17 coolant pressure coincident with high reactor building
18 pressure and/or high reactor building sump level. Now, I
19 will hasten to add that nowhere in the emergency plan nor
20 nowhere in the implementing procedures are the terms "high
21 reactor building pressure" and "high reactor building sump
22 level" defined. But by 4:15 in the morning, the reactor
23 coolant system pressure had dropped from 2435 psig at the
24 time of the reactor trip to about 1275 psig.

25 (Slide.)

1429 355

76 28 01

gshHEE

1 I have a slide indicating the reactor coolant
2 pressure drop. This pressure that is 1275 psig was below
3 the reactor coolant trip set of 1940 psig and the set point
4 for an emergency core cooling system initiation, which is
5 1600 psig at 4:15. A pressure rise of about 1.4 psig inside
6 the reactor building was detected.

7 The duty shift supervisor was aware of the drop in
8 reactor coolant pressure and increase in reactor building
9 pressure.

10 Initially, he evaluated these conditions in relation to
11 the emergency plan and determined that they were not
12 indicative of an emergency since the primary coolant system
13 pressure had stabilized and there were no increased
14 radiation levels either in or being released from the
15 facility.

16 A high reactor building sump level alarm occurred at 4:11
17 a.m., but the shift supervisor was not aware of this alarm
18 until 4:30, when an operator brought it to his attention.

19 Since a drop in primary system pressure had been
20 stabilized by this time and there were still no alarms on
21 the radiation monitors in the control room, the shift
22 supervisor did not interpret the high reactor building sump
23 level and earlier noted conditions of decreased primary
24 system pressure and increased reactor building pressure to
25 meet the conditions for site emergency.

1429 356

76 28 02

g8 HEE

1 And as I stated earlier, the terms, "loss of primary
2 system pressure" and "high reactor building pressure" are
3 not defined in the site emergency plans or its implementing
4 procedures.

5 The lack of specific definition of these terms appear to
6 contribute to the failure to declare the site emergency
7 earlier.

8 Now the site emergency was actually declared at 6:55
9 a.m. after a brief start of the 2V reactor coolant pump,
10 which, as Mr. Martin mentioned earlier, resulted in several
11 radiation alarms throughout the plant, indicative of some
12 release of fission products into the reactor coolant system.

13 MR. EBERSOLE: On your curve there, do you know
14 what the accumulated dump tank pressure was? Does anybody
15 know?

16 MR. ROBERT MARTIN: Our flood tanks are
17 pressurized at 600 psi.

18 MR. EBERSOLE: Had they been locked out?

19 MR. ROBERT MARTIN: They had been locked out.
20 That is why they did not discharge. Well, the scale does
21 not show the pressure. The RCS goes to 650 pounds, so it
22 did not get down at least to the nominal set point for the
23 injection.

24 MR. EBERSOLE: Were they locked out according to
25 procedures?

1429 357

76 28 03

g. HEE

1 MR. ROBERT MARTIN: No, sir.

2 MR. EBERSOLE: They were just happily locked out?

3 MR. ROBERT MARTIN: No, intentionally locked out.

4 MR. EBERSOLE: Why I said that is had they not been
5 locked out, they would have discharged. Right?

6 MR. TIM MARTIN: They never got down below what
7 would have caused them, the pressure that would have caused
8 them to discharge.

9 MR. EBERSOLE: But the operators were desperately
10 trying to get it down low, as you pointed out earlier, to
11 get RHR on.

12 MR. TIM MARTIN: At this time, if you look at the
13 graph, at about 5:30 to 6:00, they were still running one
14 reactor coolant pump and they didn't understand why their
15 pressure was dropping. They just started an emergency
16 boration, which was collapsing voids. But they didn't know
17 that.

18 MR. EBERSOLE: Well, while they were trying to
19 blow it down to get on RHR, wherein they failed, had they
20 previously locked out the accumulators?

21 MR. TIM MARTIN: By then they had reopened the
22 valves and they were looking for the core flood tanks to
23 discharge.

24 In fact, they were happy to see that they only, and I
25 quote, "just slid in." That indicated to them that the core

1429 358

76 29 04

1 was covered.

2 DR. PLESSET: Somebody evidently was very fond of
3 loop seals.

4 DR. MOELLER: Well, in the increase shown here in
5 6, or whatever it is, in pressure is when they closed,
6 finally closed the relief valve, is it not, or the back-up?

7 MR. GIBSON: Right in here somewhere, yes, sir.

8 MR. TIM MARTIN: That is affirmative.

9 MR. GIBSON: Criterion E in Table 1, which I did
10 not show, but it also requires declaration of the site
11 emergency when the reactor building dome monitor reaches its
12 alert set point.

13 According to the strip chart, that set point was reached
14 at about 6:35 a.m. This went unnoticed. As I stated
15 before, the site emergency was declared at 6:55.

16 (Slide.)

17 A general emergency was declared when the reactor
18 building high range gamma monitor reached its high alarm set
19 point, which occurred shortly before 7:20 a.m.

20 As I recall, it was about 7:18 a.m., and they declared
21 the general emergency at 7:20.

22 (Slide.)

23 Once the site emergency had been declared at 6:55, the
24 emergency organization was implemented as required,
25 generally as required by the emergency plan. Notifications

1429 359

76 28 05

g HEE 1 were made. The duty shift supervisor assumed control as the
2 emergency director until he was relieved at five minutes
3 after 7:00 by the site manager, by the plant manager.

4 A radiation chemistry technician initially assumed
5 control of the emergency control station and a radiation
6 protection foreman took control at 7:15 and was relieved by
7 the supervisor of radiation protection at 7:35.

8 The emergency control station was initially established
9 in the Unit 1 auxiliary building and it is from that
10 location that the director of the ECCS directs activities of
11 the various emergency teams.

12 I would like to point out that the organization was
13 initially set up like this, but as the accident progressed,
14 there were some changes made to it which generally seemed to
15 improve the effectiveness of the organization.







16 (Slide.)



17 Following the turbine trip, about 8000 gallons of reactor
18 coolant were pumped from the reactor building sump to the
19 auxiliary building sump tank. This transfer was terminated
20 at 0438 a.m. and was not resumed.

21 The auxiliary building sump tank overflowed to the
22 auxiliary building sump, causing water containing a
23 relatively low concentration of radioactivity to back up
24 through floor drains onto the floor of the auxiliary and
25 fuel handling building at the 281 foot elevation.





1429 360



IMAGE EVALUATION
TEST TARGET (MT-3)











**IMAGE EVALUATION
TEST TARGET (MT-3)**









**IMAGE EVALUATION
TEST TARGET (MT-3)**





**IMAGE EVALUATION
TEST TARGET (MT-3)**



76 28 06

g. 1 Following fuel damage, the concentration of radioactivity
2 in the reactor coolant increased by several orders of
3 magnitude and the flow of this highly contaminated reactor
4 coolant was maintained through the make-up and purification
5 system for several days following the accident.

6 This flow was the principal pathway by which
7 radioactivity was transferred from the damaged reactor core
8 to the auxiliary and fuel handling buildings, and
9 ultimately, to the environment.

10 Gases evolving from reactor coolant in the make-up and
11 purification system were collected in the waste gas system.
12 Small leaks in the system were of little radiological
13 consequence during normal operation.

14 However, following fuel damage, radioactive gas leaks
15 caused very high concentrations of airborne radioactivity
16 inside the auxiliary and fuel handling buildings and
17 resulted in much higher than normal environmental releases
18 via ventilation exhaust from these buildings.

19 I can show a simple drawing of the purification system to
20 illustrate the pathway by which radioactivity was leaving
21 the containment.

22 (Slide.)

23 DR. MOELLER: And did they consider it essential
24 to keep this system in operation?

25 MR. GIBSON: They did consider it essential, yes.

1430 001

76 28 07

g. VEE 1 sir.

2 DR. MOELLER: Thank you.

3 MR. EBERSOLE: These conditions that you described
4 in the auxiliary building.

5 MR. GIBSON: Yes, sir.

6 MR. EBERSOLE: Can I deduce from what you're
7 telling me there that had the plant in fact experienced a
8 classical LOCA, the ECCS mitigating systems would have
9 performed as designed with these leaking vents and whatnot?

10 MR. GIBSON: If letdown had been maintained -- I'm
11 not sure that I'm qualified to answer that.

12 PROF. KERR: You are referring to the activity
13 problem, particularly?

14 MR. EBERSOLE: The leakage of seals and so forth.

15 PROF. KERR: I mean your statement said that if
16 the activity normally in the water had been present, there
17 would be no problem.

18 MR. GIBSON: That is correct.

19 PROF. KERR: And if you have a LOCA, that is not
20 quite normal, but it is much worse than that.

21 MR. GIBSON: Without fuel damage, there would not
22 have been a significant problem.

23 MR. EBERSOLE: But a LOCA implies fuel damage and
24 I'm talking about a classical LOCA.

25 PROF. KERR: Yes. You're not supposed to penetrate

1430 002

76 28 08

gs HEE 1 any cladding.

2 MR. EBERSOLE: Well, that's true. But it is not
3 this bad, is it?

4 PROF. KERR: No, not nearly.

5 MR. EBERSOLE: Well, I guess it points out maybe
6 the dependence of the ECCS system on not handling dirty
7 water.

8 MR. BENDER: Would you try and trace that path for
9 us?

10 MR. GIBSON: I would be glad to. The radioactive
11 coolant leaves the reactor coolant. Pressure is reduced in
12 the block orifice, which is located in the valve gallery in
13 the fuel handling building. It passes through a process
14 radiation monitor, one of two demineralizer filters.

15 These are actually just filters. They are not
16 demineralizers. They are just filters through
17 demineralizers, another set of filters, and a make-up tank
18 where gases evolve from solution and are periodically vented
19 from the waste gas system through this vent valve, which is
20 a manual operation.

21 And then the reactor coolant is charged back into the
22 reactor coolant system through these pumps here.

23 Because of the high concentration of dissolved
24 radioactive gases in this reactor coolant following fuel
25 damage, and because of the large volume of hydrogen

1430 003

76 28 09

g HEE

1 dissolved in the reactor coolant, there was quite a bit of
2 highly radioactive gas accumulating in the upper portion of
3 the make-up tank which had to be vented to the waste gas
4 system opening this valve here.

5 Once vented --

6 (Slide.)

7 DR. CARBON: Excuse me. Before you leave that,
8 does the block orifice take it down a little bit above
9 atmospheric?

10 MR. GIBSON: It is about 100 psig. Is that right,
11 Bob?

12 MR. ROBERT MARTIN: On that order, yes.

13 DR. LANROSKI: Are there any measurements of the
14 hydrogen concentration?

15 MR. GIBSON: Not to my knowledge.

16 MR. EBERSOLE: For the record, I think I have got
17 to say something here.

18 Bill, it's not my understanding that a classical LOCA
19 does not fail cladding to a substantial degree. And
20 therefore, you are going to be dealing with dirty water in
21 the RHR in a system such as he described.

22 Am I not correct?

23 MR. TIM MARTIN: The letdown system isolates on a
24 containment of high pressure.

25 MR. EBERSOLE: That won't go away because of high

1430 004

76 28 10

9 HEE

1 pressure, but you would be handling dirty water in the RHR
2 system.

3 MR. TIM MARTIN: Your concern is noted, and in
4 fact, they were concerned about the loss of inventory in the
5 borated water storage tank, which would make them go on
6 recirculation, which would then bring highly contaminated
7 floor water into the auxiliary building.

8 They knew the system leaked.

9 MR. EBERSOLE: You're telling me that they are not
10 prepared for a LOCA, then.

11 MR. TIM MARTIN: Not prepared for this event.

12 PROF. KERR: Don't you agree that the fuel damage
13 here was far greater than one would get in a LOCA?

14 MR. EBERSOLE: Well, I don't know. What I'm
15 really trying to get around to, the fact is that do we have
16 an RHR system capable of dealing with a LOCA in an aspect of
17 circulating very dirty water?

18 MR. JORDAN: That is one of the lessons learned in
19 the 0578 report, that the RHR should be more qualified.

20 MR. EBERSOLE: Okay.

21 DR. SIESS: Mr. Chairman, as I recall, and I looked
22 it up in the TMI 2 safety evaluation report, the staff had
23 been looking at releases from the RHR system following a
24 LOCA.

25 I think they postulated a pump seal failure and asked

1430 005

76 28 11

g IEE 1 the applicants to compute the doses, off-site doses, from
2 that.

3 Does anybody here know anything about that? All they
4 said about the amount of release was that the doses were a
5 small fraction of the LOCA release, or a small fraction of
6 the LOCA allowable, which, of course, is what it was at TMI
7 2.

8 MR. JORDAN: That's right, with very modest fuel
9 damage.

10 DR. SIESS: Well, I assume it was calculated for
11 whatever fuel damage went with the LOCA or whatever release
12 went with the LOCA. I don't know.

13 MR. BENDER: Where in the system did the
14 radioactive water get out of the system onto the auxiliary
15 building floor?

16 MR. GIBSON: There are a couple of possibilities
17 for this. Maintenance records showed small leaks in several
18 systems in several components in this system which could
19 have contriouted some.

20 The pressure indication on this system, although not
21 recorded, was described by an operator to be fluctuating as
22 if a relief valve somewhere in the system were lifting.

23 These relief valves here are open to floor drains in the
24 auxiliary building and if they did lift, and I think they
25 may well have lifted, if they did, water would have

1430 006

176 28 12

9 HEE 1 remained on the floor or else gone into the floor drain
2 system and backed up in a different location on the floor in
3 the auxiliary building, because as you will recall, the
4 floor drain system had been filled to overflowing from the
5 auxiliary, -- overflow from the auxiliary building sump tank
6 earlier.

7 So if these relief valves opened, a large amount of water
8 could be released to the floor.

9 Now this release valve right here is described on
10 drawings as being piped to reactor coolant bleed tanks. One
11 operator said he remembered that valve not having a pipe
12 connected to the discharge nozzle.

13 Radiation levels in the valve gallery have been too high
14 for anyone to go in and verify. Other operators have stated
15 that they believe that situation was later corrected and
16 that it is now piped to the bleed tank, but that is a
17 possibility.

18 But we believe that the most likely source of high
19 airborne radioactivity in the auxiliary and fuel handling
20 buildings was not due to gases evolving from water spilled
21 onto the floor, but due to gases that had been vented from
22 the make-up tank to the waste gas system and leaks in the
23 gas waste system.

24 (Slide.)

25 Now the next slide is of the waste gas system. And it

1430 007

176 28 13

9 HEE 1 shows the waste gas vent header, which accepts gas from a
2 number of sources, including the make-up tank vent and gas
3 compressors draw vacuum on this header and discharge into
4 the waste gas decay tanks.

5 And we noted whenever the level in the make-up tank went
6 up, there was a corresponding increase in environmental
7 releases, as indicated by radiation levels in the auxiliary
8 and fuel handling buildings.

9 And it became apparent as time went on that there were
10 leaks somewhere in this waste gas system, either in the vent
11 header, perhaps from loop seals, or drain valves in the vent
12 header, or from the compressors themselves.

13 MR. BENDER: The gases were supposed to go through
14 filters before they went up the stack?

15 MR. GIBSON: Yes, sir. The gases are stored in
16 these tanks. They are released to a pre-filter, a high
17 efficiency filter, and charcoal before they go to the stack.

18 Now gases that enter what is known as the waste gas
19 relief header, which is a pathway accepting gas from relief
20 valves, go out the stack unfiltered.

21 This is also a pathway which is believed to have
22 existed from time to time. The relief valve on the reactor
23 coolant bleed tanks are believed to have lifted and
24 consequently, this was an unfiltered, unprocessed pathway
25 for a period of time.

1430 008

76 28 14

g HEE 1 MR. BENDER: Do you think that that was the
2 predominant pathway?

3 MR. GIBSON: It would be speculation, but probably
4 not because it did not exist for an extended period of time.

5 MR. BENDER: Do I infer from this that the if the
6 filters had been effective, there wouldn't have been as much
7 radioactivity up the stack?

8 MR. GIBSON: Well, certainly, if filters had been
9 more effective. But you should understand that there was
10 not a release through this pathway here. The release was
11 occurring because gas went into the vent header. The vent
12 header leaked into the room air, which was picked up by a
13 ventilation system. And the ventilation system discharged
14 it through this same stack to the environment.

15 But it did go through charcoal and high efficiency
16 filters, which are not shown on this drawing. Oh, yes, they
17 are, right here. This is fuel handling and this is
18 auxiliary building.

19 MR. EBERSOLE: Since relief valves are per se put
20 there to cope with rather unexpected and rather unusual
21 emergencies, what is the logic in not having their through
22 put filter?

23 MR. GIBSON: That's a good question. I don't know
24 the answer to it. Someone familiar with design basis would
25 have to answer that.

1430 009

176 28 15

1 I would just be speculating.

2 DR. MOELLER: So most of the releases did go out,
3 then, a 463-foot stack. So it was well elevated.

4 MR. GIBSON: I believe that's an error on this
5 drawing. That's 463 feet above grade. That would be a very
6 tall stack.

7 DR. MOELLER: Now the gas decay tanks, those are
8 pressurized.

9 MR. GIBSON: Yes, sir.

10 DR. MOELLER: And was their capacity used up? I
11 mean, in other words, they were being vented?

12 MR. GIBSON: Their capacity was not used up. The
13 capacity, as I recall, was on the order of 70 to 80 psig
14 with relief valve set points somewhere around 120.

15 But the compressors were unable to increase the pressure
16 in these tanks.

17 Apparently, there was a problem with the compressors.

18 DR. MOELLER: Thank you.

19 MR. GIBSON: Airborne radioactivity monitors
20 installed in the auxiliary and fuel handling building
21 exhaust systems and station vents were off-scale due to high
22 radiation levels in the vicinity of the detectors.

23 The response of these monitors provided little useful
24 information during the period of the investigation.
25 However, the samples associated with these monitors were

1430 010

76 28 16

9 GEE 1 used to collect iodine and particulate samples that were
2 analyzed in laboratories for after-the-fact determination of
3 the amount of radioactivity released. In order to provide a
4 perspective of the releases for the first three days of the
5 accident, data for the period of March 28th through April
6 30th is tabulated in our report, even though this
7 investigation was generally limited to the period of March
8 28th through March 30th.

9 These data represent approximately 99 percent of all the
10 noble gas releases. The noble gas values shown were
11 calculated by the licensee by applying atmospheric
12 dispersion factors to TLD results.

13 The methodology used by the licensee was reviewed but the
14 calculations were not verified by the investigators.

15 The licensee values are consistent with the preliminary
16 assessment which was made by the NRC staff, which estimated
17 a release of about 1.3 times 10^7 curies for the
18 period of March 28th through April 5th.

19 MR. EBERSOLE: Was there any significant part to
20 the control room environment under these conditions?

21 MR. GIBSON: No, sir. There was some increase in
22 airborne radioactivity in the containment.

23 MR. EBERSOLE: You mean in the control room?

24 MR. GIBSON: In the control room. I'm sorry. At
25 the time this occurred, the licensee had lost his capability

1430 011

76 28 17

g. EEE 1 for performing isotopic analyses on air samples because of
 2 high radiation in the accounting room. And he assumed -- to
 3 be conservative, he assumed it to be iodine and put
 4 respirators on. But it was later concluded that the
 5 radioactivity must have been rabadium 88.

6 So respirators really were not required.

7 (Slide.)

- 8
- 9
- 10
- 11
- 12
- 13
- 14
- 15
- 16
- 17
- 18
- 19
- 20
- 21
- 22
- 23
- 24
- 25

1430 012

e. 28

76 29 01.

J. E.

1 I would like to speak about in-plant radiation
2 protection for a few minutes. The emergency control station
3 was initially established in the Unit 1 Health Physics
4 Control Point in the Unit 1 Auxiliary Building at 6:55 a.m.

5 At 9:10 the Emergency Control Station was moved
6 from the Unit 1 HP Control Point to the Unit 2 Control
7 Room. This move was made because of airborne radioactivity
8 at the Unit 1 HP Control Point, which was caused by
9 collection of a reactor coolant sample at nearby primary
10 coolant sampling sink.

11 At 10:12, due to congestion in the Unit 2 Control
12 Room and due the requirement to wear respirators in this
13 area, the Emergency Control Station was moved to the Unit 1
14 Control Room, where it remained for the remainder of the
15 period of this investigation.

16 Radiation levels increased dramatically inside the
17 Auxiliary and Fuel Handling Building following the
18 accident. Exposure rates increased by several orders of
19 magnitude from a few millirem per hour to hundreds of rem
20 per hour.

21 Numerous entries into these buildings were made
22 for purposes such as operations of valves and circuit
23 breakers, inspection of systems for leakage, and performing
24 surveys.

25 Positive control was not exercised over all

1430 013

76 29 02

jHHE

1 entries into these buildings, although the Supervisor of
2 Radiation Protection and Chemistry briefed some individuals
3 and at times directed radiation chemistry technicians to
4 accompany repair party teams into the auxiliary building.

5 Several entries were made without his knowledge.
6 These entries were made into areas of high airborne
7 radioactivity and whole-body exposure rates in excess of 100
8 rem per hour.

9 In one instance survey instruments were not used.
10 Two individuals who entered the Auxiliary Building received
11 a whole-body dose of radiation in excess of regulatory
12 limits. Others became contaminated and received unnecessary
13 doses.

14 At times high-range pocket dosimeters could not be
15 located and were not worn. Items of protective clothing,
16 such as hoods, were not readily available and were not
17 worn, resulting in several instances of head contamination.

18 Extremity monitoring devices were not worn. Air
19 sampling was not performed in the Auxiliary Building where
20 workers were exposed during the period of the
21 investigation. Appropriate respiratory protective devices
22 were not always worn, and records were not maintained of
23 some radiation doses received.

24 Emergency plan implementing procedures did not
25 adequately address control of sustained in-plant radiation

1430 014

76 29 03

j(H)EE

1 hazards.

2 DR. MOELLER: Were these errors mainly
3 attributable to the confusion? Or was it lack of training?

4 MR. GIBSON: I believe there was confusion. There
5 was also lack of training. I think perhaps it could be
6 summed up by saying they were just not prepared for this
7 kind of an occurrence, and I guess that is lack of training.

8 (Slide.)

9 A nuclear engineer working in the Unit 2 Control
10 Room completed the first off-site dose calculation at about
11 7:10 a.m. The result calculated and recorded was 40 R per
12 hour at Goldsboro. The calculations were not retained, and
13 the basis of this result is unknown.

14 Within the next few minutes the 40 R per hour
15 value was apparently revised to 10 R per hour, and this
16 value was based on the reactor building dome monitor reading
17 and assumed a maximum allowable leakage from containment.
18 The plant staff, including the Supervisor of Radiation
19 Protection and Chemistry, concluded that the value was an
20 overestimate of the actual dose, because the actual reactor
21 building pressure was well below design pressure. And
22 consequently containment should not be leaking at the
23 maximum allowable leak rate.

24 The investigators have since determined that the
25 error in their projected dose rate was due to an engineer

1430 015

76 29 04

JLHEE

1 misreading of the dome monitor. The engineer apparently did
2 not understand the expanded scale feature on the monitor,
3 and a reading of 400 millirem per hour was misinterpreted to
4 be 30,000 millirem per hour.

5 A radiation survey was made on the island, between
6 Goldsboro and the plant at 7:48 a.m. and revealed less than
7 1 millirem per hour. A survey was made at Goldsboro at
8 8:32 a.m. which also showed less than 1 millirem per hour,
9 confirming that the initial dose projection was in error.

10 During the period of March 28th through 30th, the
11 Licensee's land-based on-site and off-site monitoring teams
12 made about 500 direct radiation measurements. These
13 measurements were made primarily to confirm the predicted
14 location of the the noble gas, effluent plume, and to
15 determine the dose rate produced by the plume, the rate of
16 release of radioactivity or source term from the station was
17 periodically calculated based on the dose rate measurements
18 in the plume and meteorological conditions existing at the
19 time of the measurement.

20 The calculated source term was then used to
21 predict those rates in other areas when meteorological
22 conditions changed.

23 Monitoring team survey results were also used to
24 assess the need for protective actions. TLDs were used to
25 perform an after-the-fact assessment of direct radiation

1430 016

76 29 05

LHHE

1 ooses to the public.

2 In general the Licensees, on-site and off-site
3 survey teams performed surveys in appropriate areas at
4 appropriate times. However, during a five-and-one-half-hour
5 period on March 28th and a two-hour period on March 29th no
6 off-site surveys were performed in the plume.

7 Both of these periods of time were within the
8 interval when the majority of the noble gases were released
9 and when the plume was well defined because of sufficient
10 wind speed and almost constant wind direction.

11 Radiation levels on March 28th, with the exception
12 of 50 millirem per hour measured at 1548 hours on
13 Pennsylvania Route 441 at about 1500 feet south of the north
14 gate were not above background until 2238 hours, when a
15 radiation level of 13 millirem per hour was measured near
16 Conkle's School, which is about six miles northwest of the
17 plant.

18 Several radiation levels above background were
19 noted in this general area prior to midnight. However, the
20 1300 millirem per hour value was the highest one measured
21 until 30 millirem per hour was measured in Goldsboro at 600
22 hours on March 29th.

23 Radiation levels during the remainder of
24 March 29th were generally less than one millirem per hour,
25 with the maximum dose rate of three millirem per hour at

1430 017

16 29 06

JIHEE

1 Royalton.

2 DR. MOELLER: Were there measurements made, say,
3 simultaneously, inside and outside an building or in a
4 basement and outside, or anything like that?

5 MR. GIBSON: I'm sure measurements were made in
6 both places, but I don't recall any effort to compare
7 simultaneous measurements.

8 That is all I had planned to say, unless there are
9 further questions.

10 DR. CARBON: Thank you.

11 Are there any additional questions of the other
12 members of the Staff?

13 MR. EBERSOLE: May I ask the Staff a generic
14 question?

15 DR. CARBON: Sure.

16 MR. EBERSOLE: The finding that may be the RHR
17 system is not suitable for handling dirty water; maybe, I
18 guess, generic to these RHR designs. Do you know that to be
19 so?

20 MR. JORDAN: That is understood to be so for this
21 level of activity.

22 MR. EBERSOLE: All plant may have leaky seals
23 then.

24 MR. JORDAN: That's correct. Valve packings,
25 pressurized water reactions. For that matter, BWRs might

1430 018

76 29 07

JLHEE 1 have dirty water, too, after a LOCA, on the RHR system.

2 MR. JORDAN: Yes

3 DR. CARBON: Harold, do you have questions of the
4 Staff?

5 MR. ETHERINGTON: In all these areas where you
6 have a gas leak --

7 MR. JORDAN: You're saying presently?

8 MR. ETHERINGTON: No. I know on the flow diagrams
9 that you showed they were all on the suction side of the
10 pump. Isn't there an attempt to keep them subatmospheric to
11 avoid out-leakage?

12 MR. JORDAN: Are you speaking of the ventilation
13 system of the building or the piping system?

14 MR. ETHERINGTON: The ventilation system.

15 MR. JORDAN: The ventilation systems normally go
16 from a high activity toward the low activity zone.

17 MR. ETHERINGTON: I was talking about the piping.

18 MR. GIBSON: The vent header in the waste gas
19 system, although it is on suction side of the compressor, is
20 maintained at a low positive pressure, 3 or 4 psig.

21 MR. ETHERINGTON: Okay.

22 DR. CARBON: Do you have other questions of the
23 Staff, Harold?

24 MR. ETHERINGTON: No.

25 DR. CARBON: Let me make a comment to the

1430 019

75 29 08

JHEE

1 committee to clarify a point.

2 My questions awhile ago about recognition of fuel
3 failure -- I was asking why the operating staff -- not the
4 operators, but the staff, including those mechanical and
5 nuclear engineers -- why they didn't recognize this.

6 Thank you all for coming.

7 I believe that does it.

8 MR. JORDAN: Thank you, sir.

9 DR. SIESS: Have the clocks stopped, or are we
10 through?

11 (Laughter.)

12 DR. CARBON: If everyone is appropriately stunned,
13 perhaps we could take a first reading of Harold's letter.

14 (Whereupon, at 7:45 p.m., the hearing was
15 adjourned.)

16 * * *

17

18

19

20

21

22

23

24

25

1430 020

check
slates

CHRONOLOGY

SEPT 6	<u>W</u> OWNERS GROUP MEETING
SEPT 9	PSE&G (SALEM 1) LER 79-58
SEPT 14	IE INFORMATION NOTICE 79-22
SEPT 17	LETTER TO ALL LICENSEES - H. DENTON
SEPT 18-20	MEETINGS WITH LICENSEES
OCT 5-9	LICENSEE SUBMITTALS
OCT 15	BASIS FOR CONTINUED OPERATION - D. EISENHUT
OCT 19	AIF/NSAC GENERIC SUBMITTAL
NOV 6	STATUS REPORT
NOV 8	NRC/INDUSTRY MEETING

1430 021

BASIS FOR CONTINUED OPERATION

1. SAFETY CONCERN BUT NO DEMONSTRATED SAFETY PROBLEM
2. MARGINS IN HELB SAFETY ANALYSES
3. SIMILAR UNRESOLVED SAFETY ISSUES
4. OPERATOR CAN COPE

1430 022

INITIAL FINDINGS

1. NO IDENTIFIED SAFETY PROBLEM
2. CONCERN, HOWEVER, REGARDING
 - B&D OF SYSTEMS REVIEWS
 - EQ OF EQUIPMENT
 - OPERATOR ACTION
3. CONCUR WITH REC 9, NUREG 0585

1430 023

CURRENT RELATED ACTIVITIES

- . FIRE PROTECTION REVIEWS
- . EQ OF SAFETY EQUIPMENT
- . DIABLO CANYON SEISMIC PIPE BREAKS
- . TAP - A 17 - SYSTEMS INTERACTION
- . STANDARDS DEVELOPMENT FOR NON-SAFETY GRADE
EQUIPMENT
- . CONSEQUENTIAL CONTROL SYSTEM FAILURE

1430 024

NRC/INDUSTRY STEERING COMMITTEE

- develop Task Action Plan
- establish schedule
- oversee performance

1430 025