

CENTRAL FILE



TURNPIKE ROAD (RT 91)  
WESTBORD MASSACHUSETTS 01581  
617-366-9011

B.4.1.1  
WNY 79-125

November 7, 1979

United States Nuclear Regulatory Commission  
Office of Inspection and Enforcement  
Region I  
631 Park Avenue  
King of Prussia, Pennsylvania 19406

Attention: Mr. Boyce H. Grier, Director

- References:
- (a) License No. DPR-36 (Docket No. 50-309)
  - (b) USNRC Letter to MYAPC dated July 2, 1979  
I&E Bulletin No. 79-14; Revision 1 dated July 18, 1979; and  
Supplement dated August 15, 1979
  - (c) MYAPC Letter to USNRC dated July 24, 1979
  - (d) MYAPC Letter to USNRC dated September 25, 1979
  - (e) MYAPC Letter and USNRC dated May 2, 1979

Dear Mr. Grier:

Subject: Second Supplementary Response to IE Bulletin 79-14

In addition to the field activity reported in our supplementary response to IE Bulletin 79-14, Reference (d), we have also completed a detailed field check of 80 seismic restraints on safety class systems in Maine Yankee, of which fifty are in the containment and the remaining thirty restraints are outside containment. These checks were completed on supports for safety class piping 2 1/2" in diameter and larger.

We have committed in Reference (e) to extensive reanalysis of seismic piping and supports at Maine Yankee as a consequence of the March 13, 1979 Show Cause Order. This commitment involves an extensive detailed field check of seismic restraints. To facilitate the seismic reanalysis, which will yield new support loads, it is necessary to gather the appropriate information; i.e., piping geometry, restraint location and restraint function. In conjunction with the new analyses a detailed check of the as-built seismic supports configuration will be completed. This information will allow a meaningful comparison of loads from the confirmed reanalyses against the structural capabilities of the as-built seismic restraints.

1470 282  
7912040 019


United States Nuclear Regulatory Commission  
Attention: Mr. Boyce H. Grier, Director

November 7, 1979  
Page 2

We have devised this program to meet, and in fact exceed, the intent and concerns expressed in IE Bulletin 79-14. If you require additional information on this subject, please contact us at your convenience.

Very truly yours,

MAINE YANKEE ATOMIC POWER COMPANY



Robert H. Groce  
Senior Engineer - Licensing

MMA/kaf

1470 283