

LICENSEE EVENT REPORT

CONTROL BLOCK: _____ (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 | C | 0 | F | S | V | 1 | 2 | 0 | 0 | - | 0 | 0 | 0 | 0 | 0 | - | 0 | 0 | 3 | 4 | 1 | 1 | 2 | 0 | 4 | _____ | 5
7 8 9 LICENSEE CODE 14 15 LICENSE NUMBER 25 26 LICENSE TYPE 30 57 CAT 58

CON'T
0 1 | REPORT SOURCE | L | 6 | 0 | 5 | 0 | 0 | 0 | 2 | 6 | 7 | 7 | 1 | 0 | 3 | 0 | 7 | 9 | 8 | 1 | 1 | 2 | 9 | 7 | 9 | 9 | 9
7 8 60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)
0 2 | During testing, it was discovered that seven of twelve helium circulator seal mal-
0 3 | function pressure differential switch units tripped outside
0 4 | the limits of LCO 4.4.1, Table 4.4-3. Reportable per Technical Specification AC
0 5 | 7.5.2(b)1 and AC 7.5.2(b)2. No effect on public health or safety. Redundant system
0 6 | available and operable. Similar reports RO 77-47, preliminary reports RO 78-27 and
0 7 | RO 79-32.

0 9 | SYSTEM CODE | C | B | 11 | CAUSE CODE | E | 12 | CAUSE SUBCODE | E | 13 | COMPONENT CODE | I | N | S | T | R | U | 14 | COMP. SUBCODE | S | 15 | VALVE SUBCODE | Z | 16
7 8 9 10 11 12 13 18 19 20
17 | LER/RO REPORT NUMBER | 7 | 9 | 21 22 | SEQUENTIAL REPORT NO. | 0 | 5 | 6 | 24 26 | OCCURRENCE CODE | 0 | 3 | 28 29 | REPORT TYPE | L | 30 | REVISION NO. | 0 | 32
ACTION TAKEN | X | 18 | FUTURE ACTION | X | 19 | EFFECT ON PLANT | Z | 20 | SHUTDOWN METHOD | Z | 21 | HOURS | 0 | 0 | 0 | 0 | 37 40 | ATTACHMENT SUBMITTED | Y | 23 | NPRD-4 FORM SUB. | N | 24 | PRIME COMP. SUPPLIER | N | 25 | COMPONENT MANUFACTURER | B | 0 | 8 | 0 | 26
33 34 35 36 41 42 43 44 47

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)
1 0 | ITT Barton Model 289 pressure differential switches failed to actuate at trip point
1 1 | due to dirt accumulation in electrical switches. Affected switches cleaned and read-
1 2 | justed to proper trip points. Surveillance test successfully completed. Trip
1 3 | settings being checked on a monthly basis. Problem under investigation.

1 5 | FACILITY STATUS | G | 28 | % POWER | 0 | 0 | 0 | 0 | 29 | OTHER STATUS | N/A | 30 | METHOD OF DISCOVERY | B | 31 | DISCOVERY DESCRIPTION | Surveillance Test | 32
7 8 9 10 11 13 44 45 46 80

1 6 | ACTIVITY CONTENT | Z | 33 | RELEASED OF RELEASE | Z | 34 | AMOUNT OF ACTIVITY | N/A | 35 | LOCATION OF RELEASE | N/A | 36
7 8 9 10 11 44 45 80

1 7 | PERSONNEL EXPOSURES | 0 | 0 | 0 | 37 | TYPE | Z | 38 | DESCRIPTION | N/A | 39
7 8 9 11 12 13 80

1 8 | PERSONNEL INJURIES | 0 | 0 | 0 | 40 | DESCRIPTION | N/A | 41
7 8 9 11 12 80

1 9 | LOSS OF OR DAMAGE TO FACILITY | Z | 42 | DESCRIPTION | N/A | 43
7 8 9 10 80

2 0 | PUBLICITY | N | 44 | DESCRIPTION | N/A | 45
7 8 9 10 80
NAME OF PREPARED *J. W. Gahm* J. W. Gahm PHONE: (303) 785-2253
NRC USE ONLY

1473 267
7912040406

0-727-150-6