

LICENSEE EVENT REPORT

CONTROL BLOCK: [] [] [] [] [] [] [] [] [] [] (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

1 | N | C | B | E | P | 1 | (2) | 0 | 0 | - | 0 | 0 | 0 | 0 | - | 0 | 0 | (3) | 4 | 1 | 1 | 1 | 1 | (4) | [] | [] | (5)

1 | REPORT SOURCE | L | (6) | 0 | 5 | 0 | - | 0 | 3 | 2 | 5 | (7) | 1 | 1 | 0 | 1 | 7 | 9 | (8) | [] | [] | [] | [] | (9)

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)
2 | During normal plant operation, the auxiliary operator, on a tour of the Reactor Building, noticed that the RHR flow indicator 1E11-FI-3338, on the Remote Shutdown Panel, was indicating 2500 gpm with the system not in operation.

Technical Specification 3.3.5.2, 6.9.1.9b

SYSTEM CODE [C | F |] (11) CAUSE CODE [E] (12) CAUSE SUBCODE [G] (13) COMPONENT CODE [I | N | S | T | R | U] (14) COMP. SUBCODE [I] (15) VALVE SUBCODE [Z] (16)
17 LER/RO REPR. NUMBER [7 | 9] (17) EVENT YEAR [7 | 9] (21) SEQUENTIAL REPORT NO. [0 | 8 | 4] (24) OCCURRENCE CODE [0 | 3] (28) REPORT TYPE [L] (30) REVISION NO. [0] (32)
ACTION TAKEN [E] (18) FUTURE ACTION [Z] (19) EFFECT ON PLANT [Z] (20) SHUTDOWN METHOD [Z] (21) HOURS [0 | 0 | 0 | 0] (22) ATTACHMENT SUBMITTED [N] (23) NPRD-4 FORM SUB. [Y] (24) PRIME COMP. SUPPLIER [A] (25) COMPONENT MANUFACTURER [I | 1 | 3 | 0] (26)
C/USE DESCRIPTION AND CORRECTIVE ACTIONS (27)

28 | The indicator FI 3338 and the transmitter FI 3338 were calibrated and the system was returned to service. This instrument is calibrated on a quarterly schedule. This is considered an isolated event and no further action is required.

28 FACILITY STATUS [I] (28) % POWER [1 | 0 | 0] (29) OTHER STATUS [N/A] (30) METHOD OF DISCOVERY [A] (31) DISCOVERY DESCRIPTION [Operator Surveillance] (32)
29 ACTIVITY CONTENT [Z] (33) AMOUNT OF ACTIVITY [N/A] (35) LOCATION OF RELEASE [N/A] (36)
30 PERSONNEL EXPOSURES NUMBER [0 | 0 | 0] (37) TYPE [Z] (38) DESCRIPTION [N/A] (39)
31 PERSONNEL INJURIES NUMBER [0 | 0 | 0] (40) DESCRIPTION [N/A] (41)
32 LOSS OF OR DAMAGE TO FACILITY TYPE [Z] (42) DESCRIPTION [N/A] (43)
33 PUBLICITY ISSUED [N] (44) DESCRIPTION [N/A] (45)

1494 002

7912050 480

NAME OF PREPARER A. C. Tollison, Jr.

PHONE: 919 - 457-9521

U.S. NRC FORM 366-222