LICENSEE EVENT REPORT

	CONTROL BLOCK: (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)
0 1	N E C P R 1 2 0 0 - 0 0 0 - 0 0 0 3 4 1 1 1 1 1 6 5 6 EICENSE CODE 14 15 15 LICENSE NUMBER 25 26 LICENSE TYPE 30 57 CAT 58
CON'T	REPORT L 6 0 5 0 0 0 2 9 8 7 1 0 2 1 7 9 8 1 1 1 2 0 7 9 9 EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)
0 2	During normal operation, while pumping water from the torus to radwaste, the drywell
0 3	to torus differential pressure dropped to 1.0 psid vice >1.47 as required by Tech.
0 4	Spec. Section 3.7.E.2. There was no significant occurrence as a result of this
0 5	event. This event is not repetitive. There were no adverse affects to public health
0 6	and safety.
0 7	
0 8	80
7 8	SYSTEM CAUSE CAUSE COMPONENT CODE SUBCODE SUBC
7 8	17 REPORT 19 10 13 13 14 10 15 16 17 18 19 19 19 19 19 19 19
1 0	A differential pressure at the high end of the allowable band coupled with pumping
11	water from the torus, allowed the nitrogen pressure to force the water from the
1 2	downcomers and flow to the torus. The differential pressure was immediately re-
1 3	stored and the instruction letter has been changed to prevent recurrence.
1 4	90
1 5	ACILITY STATUS 30 METHOD OF DISCOVERY DESCRIPTION 32 E 38 0 9 2 29 NA A 44 45 46 Operator Observation 80
	LEASED OF RELEASE AMOUNT OF ACTIVITY (35) LOCATION OF RELEASE (36) NA N
1 7	NUMBER OF TYPE DESCRIPTION (39) NA 1552 251 PERSONNEL INJURIES 3
1 9	NUMBER DESCRIPTION 41) O O O O O O O O O O O O O O O O O O O
20	PUBLICITY SECRETION 45 NEC USE ONLY NEC USE ONLY 10 10 10 10 10 10 10 10 10 1
	NAME OF PREPARER D. L. Phillips PHONE 402-825-3811 9 7912180 389