

79-054-01P



Alabama Power
the southern electric system

P. O. Drawer 470
Ashford, AL 36312
November 7, 1979
FNP-79-1350

Mr. J. P. O'Reilly, Director
U. S. Nuclear Regulatory Commission
101 Marietta Street, N.W.
Atlanta, Georgia 30303

Dear Mr. O'Reilly:

This is to confirm the telephone call to Mr. Bill Bradford (NRC) at 1638 on November 7, 1979 by Mr. W. G. Hairston, III (APCo) in accordance with Tech. Spec. 3.7.11.b.2.a.

As a result of a fire in Cooling Tower B at approximately 1228 on 11-7-79, the Fire Protection Tanks A and B levels fell to 120,000 gallons. Tech. Spec. 3.7.11.1.b requires a minimum level of 250,000 gallons. The fire was extinguished at 1300 hours.

It is anticipated that the tank levels will be returned to minimum acceptable Tech. Spec. levels by approximately 1730 on 11-7-79.

Further details will be provided in the followup report.

Sincerely yours,

W. G. Hairston III

W. G. Hairston, III
Plant Manager
Joseph M. Farley Nuclear Plant

WGH/HMMc:jh

cc: H. O. Thrash
R. D. Hill
File

1552 324

A002
S
1/0

422
7912190 790454
INTERNAL CODE :