


UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION

BEFORE THE ATOMIC SAFETY AND LICENSING BOARD



In the Matter of §
§
HOUSTON LIGHTING & POWER §
COMPANY § Docket No. 50-466
§
(Allens Creek Nuclear §
Generating Station, Unit §
No. 1) §

APPLICANT'S RESPONSE TO JOHN F. DOHERTY'S SIXTH
SET OF INTERROGATORIES TO HOUSTON LIGHTING &
POWER COMPANY

In response to the interrogatories propounded
by John F. Doherty, Houston Lighting & Power Company
(Applicant) answers as follows:

INTERROGATORY NO. 1

How much leakage at the inboard system of
the MSIV control system will be allowed applicant in
standard cubic feet per hour?

ANSWER:

The NRC has limited leakage past Main
Steam Isolation Valves to 11.5 SCFH.

INTERROGATORY NO. 2:

Will ACNGS include a valve stem leakage collection
system that directs leakage to an area served by the
standby gas treatment system (SGTS)?

ANSWER:

Every valve 2 1/2" or greater inside the
drywell is connected to a seal leak collection system
with leakage directed to the drywell sump. The drywell
is served by the SGTS. Outboard Main Steam Isolation

1591 213

7912170246

Valves have a seal leak collection system which directs leakage to an area served by the ECCS Filtered Exhaust System.

INTERROGATORY NO. 3:

Are the isolation valves in the containment purge system now designed to close within five seconds?

ANSWER:

The maximum closure time for the containment ventilation (purge) air supply and exhaust is five seconds. (ACNGS PSAR Table 6.2-12)

INTERROGATORY NO. 4:

If not, what are their closing times as designed?

ANSWER:

Not applicable.

INTERROGATORY NO. 5:

Has Applicant committed to the General Electric resolution of the seven problems listed on page 3 of the "Enclosure" to the letter from Steven A. Varga, Chief of Light Water Reactors, Branch 4, to G. W. Oprea, Jr., of Applicant, dated July 21, 1978, and subject: "Outstanding Safety Review Issues - Allens Creek NGS, Unit 1?"

ANSWER:

Applicant has committed to the General Electric Resolution for the seven areas listed on page 3 of the enclosure of the letter from Steven A. Varga to G. W. Oprea, Jr., dated July 24, 1978. (See ACNGS PSAR, Appendix K, pages KO32.2-1,2.)

INTERROGATORY NO. 6:

Has Applicant committed to design "these supports for the combined load effects of pipe rupture loads in combination with loads resulting from the SSE and other faulted condition loads described in Table 3.9.7 of the PSAR? (This is item 11.6(2) on page 6 of the S. Varga letter cited in Interrogatory No. 5, supra.)

ANSWER:

Table 3.9-7 was corrected by amendment 47 to the PSAR to include pipe rupture loads as part of the Applicant's commitment to design for a faulted plant condition.

INTERROGATORY NO. 7:

Referring to question five (infra.) if not, state which is not in commitment and give every reason for not having done so, or for any delay in compliance.

ANSWER:

Not applicable.


INTERROGATORY NO. 8:

How does Applicant conclude: ". . . it would be impossible for impeller missiles from this pump to strike the combustible gas control system components?" (See Applicant's response to JFD, Second Set of Interrogatories to HL&P, and the assumption if the answer is correct.)

ANSWER:

As shown by PSAR drawing 1.2-8, the combustible gas control system is outside the 5 ft. thick reinforced concrete drywell while the recirculation pumps are within the drywell. Further, the combustible gas control system components are above elevation 207.25' while the recirculation pump impeller is below elevation 135.00'. The location of this system so far above the recirculation pumps plus the drywell wall barrier between these components makes it impossible for a potential missile to intersect the combustible gas control system components.

Respectfully submitted,



J. Gregory Copeland
C. Thomas Biddle, Jr.
Charles G. Thrash, Jr.
3000 One Shell Plaza
Houston, Texas 77002


LOWENSTEIN, NEWMAN, REIS,
AXELRAD & TOLL
1025 Connecticut Avenue, N.W.
Washington, D.C. 20036

Jack R. Newman
Robert H. Culp
1025 Connecticut Avenue, N.W.
Washington, D.C.

ATTORNEYS FOR APPLICANT
HOUSTON LIGHTING & POWER
COMPANY


STATE OF TEXAS §
§
COUNTY OF HARRIS §

BEFORE ME, the undersigned authority, on this day personally appeared Jon G. White, who upon his oath stated that he has answered the foregoing Houston Lighting & Power Company's Response to John F. Doherty's Sixth Set of Interrogatories to Houston Lighting & Power Company in his capacity as Supervising Engineer for Houston Lighting & Power Company, and all statements contained therein are true and correct to the best of his knowledge and belief.



Jon G. White

SUBSCRIBED AND SWORN TO BEFORE ME by the said Jon G. White on this 13th day of November, 1979.



NOTARY PUBLIC IN AND FOR
HARRIS COUNTY, T E X A S

1591 216

UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION

BEFORE THE ATOMIC SAFETY AND LICENSING BOARD

In the Matter of §
§
HOUSTON LIGHTING & POWER COMPANY § Docket No. 50-466
§
(Allens Creek Nuclear Generating §
Station, Unit 1) §

CERTIFICATE OF SERVICE

I hereby certify that copies of the foregoing Applicant's Response to John F. Doherty's Sixth Set of Interrogatories to Houston Lighting & Power Company in the above-captioned proceeding were served on the following by deposit in the United States mail, postage prepaid, or by hand-delivery this 13th day of November, 1979.

Sheldon J. Wolfe, Esq., Chairman
Atomic Safety and Licensing
Board Panel
U.S. Nuclear Regulatory Commission
Washington, D. C. 20555

Dr. E. Leonard Cheatum
Route 3, Box 350A
Watkinsville, Georgia 30677

Mr. Gustave A. Linenberger
Atomic Safety and Licensing
Board Panel
U.S. Nuclear Regulatory Commission
Washington, D. C. 20555

Chase R. Stephens
Docketing and Service Section
Office of the Secretary of the
Commission
U.S. Nuclear Regulatory Commission
Washington, D. C. 20555

R. Gordon Gooch, Esq.
Baker & Botts
1701 Pennsylvania Avenue, N. W.
Washington, D. C. 20006

Richard Lowerre, Esq.
Assistant Attorney General
for the State of Texas
P. O. Box 12548
Capitol Station
Austin, Texas 78711

Hon. Charles J. Dusek
Mayor, City of Wallis
P. O. Box 312
Wallis, Texas 77485

Hon. Leroy H. Grebe
County Judge, Austin County
P. O. Box 99
Bellville, Texas 77418

Atomic Safety and Licensing
Appeal Board
U.S. Nuclear Regulatory
Commission
Washington, D. C. 20555

Atomic Safety and Licensing
Board Panel
U.S. Nuclear Regulatory
Commission
Washington, D. C. 20555

1591 217

Steve Sohinki, Esq.
Staff Counsel
U.S. Nuclear Regulatory Commission
Washington, D. C. 20555

John F. Doherty
4327 Alconbury Street
Houston, Texas 77021

Robert S. Framson
Madeline Bass Framson
4822 Waynesboro Drive
Houston, Texas 77035

Carro Hinderstein
8739 Link Terrace
Houston, Texas 77025

D. Marrack
420 Mulberry Lane
Bellaire, Texas 77401

Brenda McCorkle
6140 Darnell
Houston, Texas 77074

F. H. Potthoff, III
7200 Shady Villa, #110
Houston, Texas 77055

Wayne E. Rentfro
P. O. Box 1335
Rosenberg, Texas 77471

James M. Scott, Jr.
8302 Albacore
Houston, Texas 77074

Bryan L. Baker
1118 Montrose
Houston, Texas 77019

Dorothy F. Carrick
Box 409, Wagon Rd. Rfd. #1
Wallis, Texas 77485

Carolina Conn
1414 Scenic Ridge
Houston, Texas 77043

Elinore P. Cumings
Route 1, Box 138V
Rosenberg, Texas 77471

Stephen A. Doggett, Esq.
P. O. Box 592
Rosenberg, Texas 77471

Robin Griffith
1034 Sally Ann
Rosenberg, Texas 77471

Leotis Johnston
1407 Scenic Ridge
Houston, Texas 77043

Rosemary N. Lemmer
11423 Oak Spring
Houston, Texas 77043

Kathryn Otto
Route 2, Box 62L
Richmond, Texas 77469

Frances Pavlovic
111 Datonia
Bellaire, Texas 77401

Charles Perez
1014 Montrose
Houston, Texas 77019

William Schuessler
5810 Darnell
Houston, Texas 77074

Patricia L. Strelein
Route 2, Box 395C
Richmond, Texas

Glen Van Slyke
1739 Marshall
Houston, Texas 77098

Donald D. Weaver
P. O. Drawer V
Simonton, Texas 77476

Connie Wilson
11427 Oak Spring
Houston, Texas 77043

C. Thomas Biddle Jr

C. Thomas Biddle, Jr.

1591 219