

UPDATE REPORT

Previous Report Date 8/31/79

NRC FORM 366 (7-77)

U. S. NUCLEAR REGULATORY COMMISSION

LICENSEE EVENT REPORT

EXHIBIT A

CONTROL BLOCK: (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 | A | R | A | N | 0 | 1 | 2 | 0 | 0 | - | 0 | 0 | 0 | 0 | - | 0 | 0 | 3 | 4 | 1 | 1 | 1 | 1 | 4 | 5

CON'T 01 | REPORT SOURCE | L | 6 | 0 | 5 | 0 | 0 | 0 | 3 | 1 | 3 | 7 | 0 | 8 | 1 | 0 | 7 | 9 | 8 | 1 | 2 | 0 | 6 | 7 | 9 | 9

02 | With the unit in a Cold Shutdown Condition, Leak Rate Testing of the
03 | Reactor Building Purge valves at penetration V-1 indicated a leak rate
04 | in excess of 50,000 cc/minute, exceeding that allowed per T.S.4.4.1.2.3.
05 | The excessive leakage was determined to be due to the outside isolation
06 | valve, CV-7402. The inside isolation valve, CV-7404, test results were
07 | within acceptable limits. This occurrence is similar to LER's 50-313/
08 | 79-005 & 77-015. Reportable per T.S. 6.12.3.2.b.

09 | SYSTEM CODE | S | I | C | 11 | CAUSE CODE | E | 12 | CAUSE SUBCODE | B | 13 | COMPONENT CODE | V | A | L | V | E | X | 14 | COMP SUBCODE | E | 15 | VALVE SUBCODE | D | 16

10 | Investigation revealed that the valve required an adjustment of the valve
11 | seat shims to match the butterfly with the seating surface. The leak
12 | rate was verified to meet the 60% LA requirement after adjustment. The
13 | testing frequency was modified for testing prior to heatup if operated
14 | since last leak rate test, not to exceed 18 months. Valve operation is
15 | limited to cold shutdown condition (RCS < 200°F).

15 | FACILITY STATUS | D | 28 | % POWER | 0 | 10 | 0 | 12 | OTHER STATUS | Cold Shutdown | 29 | METHOD OF DISCOVERY | B | 31 | DISCOVERY DESCRIPTION | Surveillance Test per T.S.4.4.1

16 | ACTIVITY CONTENT | Z | 33 | Z | 34 | AMOUNT OF ACTIVITY | NA | 35 | LOCATION OF RELEASE | NA | 36

17 | PERSONNEL EXPOSURES | 0 | 37 | 0 | 38 | Z | 39 | DESCRIPTION | NA | 40

18 | PERSONNEL INJURIES | 0 | 40 | 0 | 41 | Z | 42 | DESCRIPTION | NA | 43

19 | LOSS OF OR DAMAGE TO FACILITY | Z | 42 | Z | 43 | DESCRIPTION | NA | 44

20 | PUBLICITY ISSUED | N | 44 | Z | 45 | DESCRIPTION | NA | 46

NAME OF PREPARER: Chris N. Shively PHONE: 501/968-2519

1591 243

7912170269